



Project: Frederick Co Schools

Analytical Results

Project Number: Ballenger Creek Middle School
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
08-Mar-22 15:12

Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K31-07 2075 (KS)	E069922-01	Kitchen	Lead	< 1.0	ug/L	3/5/2022 1:09:25PM	SES
K17-03 2075 (IM)	E069922-02	Teachers Lounge/Room 177	Lead	16.8	ug/L	3/5/2022 1:27:14PM	SES
S23-001 2075 (NO)	E069922-03	Health Room/Room 186	Lead	2.5	ug/L	3/5/2022 1:30:48PM	SES
S23-008 2075 (HE)	E069922-04	Room 152	Lead	1.8	ug/L	3/5/2022 1:34:22PM	SES
S23-009 2075 (HE)	E069922-05	Room 152	Lead	1.5	ug/L	3/5/2022 1:37:56PM	SES
S23-010 2075 (HE)	E069922-06	Room 152	Lead	3.7	ug/L	3/5/2022 1:41:31PM	SES
S23-011 2075 (HE)	E069922-07	Room 152	Lead	3.0	ug/L	3/5/2022 1:45:06PM	SES
S23-012 2075 (HE)	E069922-08	Room 152	Lead	1.5	ug/L	3/5/2022 1:48:41PM	SES
S23-073 2075 (TL)	E069922-09	Teachers Lounge/Room 177	Lead	< 1.0	ug/L	3/5/2022 1:52:15PM	SES
S23-117 2075 (HE)	E069922-10	Room 152	Lead	1.1	ug/L	3/5/2022 2:02:57PM	SES
W01A-01 2075 (DF)	E069922-11	Common Hallway/Cafe	Lead	< 1.0	ug/L	3/5/2022 2:10:04PM	SES
W01A-01 2075 (DF) B	E069922-12	Common Hallway/Cafe	Lead	< 1.0	ug/L	3/5/2022 2:20:46PM	SES
W01A-02 2075 (DF)	E069922-13	Common Hallway/Cafe	Lead	< 1.0	ug/L	3/5/2022 2:24:20PM	SES
W01A-03 2075 (DF)	E069922-14	Common Hallway/Cafe	Lead	1.1	ug/L	3/5/2022 2:27:54PM	SES
W01A-04 2075 (DF)	E069922-15	Cafeteria	Lead	1.1	ug/L	3/5/2022 2:31:29PM	SES
W01A-05 2075 (DF)	E069922-16	Hallway G	Lead	< 1.0	ug/L	3/5/2022 2:35:05PM	SES
W01A-06 2075 (DF)	E069922-17	Hallway C Front	Lead	< 1.0	ug/L	3/5/2022 2:45:49PM	SES
W01A-06 2075 (DF) B	E069922-18	Hallway C Front	Lead	< 1.0	ug/L	3/5/2022 2:49:23PM	SES

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools

Analytical Results

Project Number: Ballenger Creek Middle School

Client Name: TIDEWATER

Project Manager: Meneka Rodrigo

Reported:

08-Mar-22 15:12

W01A-07 2075 (DF)	E069922-19	Hallway C Front	Lead	< 1.0	ug/L	3/5/2022	2:52:57PM	SES
W01A-08 2075 (DF)	E069922-20	Hallway C Front	Lead	< 1.0	ug/L	3/5/2022	2:56:31PM	SES
W01A-09 2075 (DF)	E069922-21	Hallway C Rear	Lead	< 1.0	ug/L	3/5/2022	3:00:05PM	SES
W01A-09 2075 (DF) B	E069922-22	Hallway C Rear	Lead	< 1.0	ug/L	3/5/2022	3:10:47PM	SES
W01A-10 2075 (DF)	E069922-23	Hallway C Rear	Lead	< 1.0	ug/L	3/5/2022	3:14:21PM	SES
W01A-11 2075 (DF)	E069922-24	Hallway C Rear	Lead	< 1.0	ug/L	3/5/2022	3:17:56PM	SES

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools


Analytical Results

Project Number: Ballenger Creek Middle School
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
08-Mar-22 15:12

Notes and Definitions

DET Analyte DETECTED
ND Analyte NOT DETECTED at or above the reporting limit
NR Not Reported
dry Sample results reported on a dry weight basis
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

SITE: BALLENGER CREEK MIDDLE SCHOOL 5525 BALLENGER CREEK PIKE, FREDERICK, MD 21703
 SAMPLER'S NAME: PHILLIP RANKINE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1	K31-07 2075 (KS)	BCMS	Kitchen	6	D2010.60 Plumbing Fixture (Kitchen Sink)	March 4, 2022 4:10
2	K17-03 2075 (IM)	BCMS	Teachers Lounge/Room 177	6	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	March 4, 2022 4:29
3	S23-001 2075 (NO)	BCMS	Health Room/Room 186	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 4, 2022 4:25
4	S23-008 2075 (HE)	BCMS	Room 152	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 4, 2022 4:01
5	S23-009 2075 (HE)	BCMS	Room 152	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 4, 2022 4:18
6	S23-010 2075 (HE)	BCMS	Room 152	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 4, 2022 4:12
7	S23-011 2075 (HE)	BCMS	Room 152	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 4, 2022 4:15
8	S23-012 2075 (HE)	BCMS	Room 152	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 4, 2022 4:14
9	S23-073 2075 (TL)	BCMS	Teachers Lounge/Room 177	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 4, 2022 4:27
10	S23-117 2075 (HE)	BCMS	Room 152	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 4, 2022 4:20
11	W01A-01 2075 (DF)	BCMS	Common Hallway/Cafe	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain) B. Gilman	March 4, 2022 4:00

69922

13

SITE: BALLENGER CREEK MIDDLE SCHOOL 5525 BALLENGER CREEK PIKE, FREDERICK, MD 21703
 SAMPLER'S NAME: PHILLIP RANKINE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
12	W01A-01 2075 (DF) B	BCMS	Common Hallway/Cafe	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain) <i>Drinking Fountain</i>	March 4, 2022 <i>4:01</i>
13	W01A-02 2075 (DF)	BCMS	Common Hallway/Cafe	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 4, 2022 <i>4:02</i>
14	W01A-03 2075 (DF)	BCMS	Common Hallway/Cafe	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 4, 2022 <i>4:03</i>
15	W01A-04 2075 (DF)	BCMS	Cafeteria	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 4, 2022 <i>4:05</i>
16	W01A-05 2075 (DF)	BCMS	Hallway G	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 4, 2022 <i>4:06</i>
17	W01A-06 2075 (DF)	BCMS	Hallway C Front	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain) <i>B. Miller</i>	March 4, 2022 <i>4:32</i>
18	W01A-06 2075 (DF) B	BCMS	Hallway C Front	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 4, 2022 <i>4:33</i>
19	W01A-07 2075 (DF)	BCMS	Hallway C Front	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 4, 2022 <i>4:35</i>
20	W01A-08 2075 (DF)	BCMS	Hallway C Front	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 4, 2022 <i>4:36</i>
21	W01A-09 2075 (DF)	BCMS	Hallway C Rear	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain) <i>S. Miller</i>	March 4, 2022 <i>4:39</i>
22	W01A-09 2075 (DF) B	BCMS	Hallway C Rear	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 4, 2022 <i>4:40</i>

69922

213

69922


SITE: BALLENGER CREEK MIDDLE SCHOOL 5525 BALLENGER CREEK PIKE, FREDERICK, MD 21703
SAMPLER'S NAME: PHILLIP RANKINE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
23	W01A-10 2075 (DF)	BCMS	Hallway C Rear	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 4, 2022
24	W01A-11 2075 (DF)	BCMS	Hallway C Rear	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 4, 2022

8:41

8:42

Phil Rankine


301 332 9084

3/3