



Project: Frederick Co Schools

Analytical Results

Project Number: Crestwood Middle School
 Client Name: TIDEWATER
 Project Manager: Meneka Rodrigo

Reported:
 08-Mar-22 15:08

Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K31-02 2104 (KS)	E069921-01	Kitchen	Lead	1.6	ug/L	3/5/2022 10:35:58AM	SES
K31-03 2104 (KS)	E069921-02	Kitchen	Lead	< 1.0	ug/L	3/5/2022 10:46:40AM	SES
K31-04 2104 (KS)	E069921-03	Kitchen	Lead	< 1.0	ug/L	3/5/2022 10:50:14AM	SES
S23-038 2104 (NO)	E069921-04	Nurses Office	Lead	< 1.0	ug/L	3/5/2022 10:53:49AM	SES
S23-039 2104 (TL)	E069921-05	Front Office Teachers Lounge	Lead	< 1.0	ug/L	3/5/2022 10:57:24AM	SES
S23-109 2104 (HE)	E069921-06	A219/Home-Ec	Lead	< 1.0	ug/L	3/5/2022 11:01:00AM	SES
S23-110 2104 (HE)	E069921-07	A219/Home-Ec	Lead	1.5	ug/L	3/5/2022 11:11:45AM	SES
S23-111 2104 (HE)	E069921-08	A219/Home-Ec	Lead	< 1.0	ug/L	3/5/2022 11:15:21AM	SES
S23-112 2104 (HE)	E069921-09	A219/Home-Ec	Lead	< 1.0	ug/L	3/5/2022 11:18:57AM	SES
S23-113 2104 (HE)	E069921-10	A219/Home-Ec	Lead	< 1.0	ug/L	3/5/2022 11:22:30AM	SES
S23-114 2104 (HE)	E069921-11	A219/Home-Ec	Lead	< 1.0	ug/L	3/5/2022 11:26:02AM	SES
S23-115 2104 (HE)	E069921-12	A219/Home-Ec	Lead	< 1.0	ug/L	3/5/2022 11:36:42AM	SES
S23-116 2104 (HE)	E069921-13	A219/Home-Ec	Lead	< 1.0	ug/L	3/5/2022 11:40:16AM	SES
W01A-01 2104 (DF) L-RE069921-14		By Gym	Lead	< 1.0	ug/L	3/5/2022 11:43:50AM	SES
W01A-01 2104 (DF) L-RE069921-15		By Gym	Lead	< 1.0	ug/L	3/5/2022 11:54:32AM	SES
W01A-02 2104 (DF) L-RE069921-16		By Gym	Lead	< 1.0	ug/L	3/5/2022 11:58:07AM	SES
W01A-02 2104 (DF) L-RE069921-17		By Gym	Lead	< 1.0	ug/L	3/5/2022 12:01:42PM	SES
W01A-02 2104 (DF) L-RE069921-18		By Gym	Lead	< 1.0	ug/L	3/5/2022 12:05:17PM	SES

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools

Analytical Results

Project Number: Crestwood Middle School

Client Name: TIDEWATER

Project Manager: Meneka Rodrigo

Reported:

08-Mar-22 15:08

W01A-03 2104 (DF) L-RE069921-19	Across From B115	Lead	< 1.0	ug/L	3/5/2022	12:08:52PM	SES
W01A-03 2104 (DF) L-RE069921-20	Across From B115	Lead	< 1.0	ug/L	3/5/2022	12:12:25PM	SES
W01A-03 2104 (DF) L-RE069921-21	Across From B115	Lead	< 1.0	ug/L	3/5/2022	12:19:30PM	SES
W01A-04 2104 (DF) L-RE069921-22	Across From A128	Lead	< 1.0	ug/L	3/5/2022	12:37:19PM	SES
W01A-04 2104 (DF) L-RE069921-23	Across From A128	Lead	< 1.0	ug/L	3/5/2022	12:40:53PM	SES
W01A-05 2104 (DF) L-RE069921-24	Across From A225	Lead	< 1.0	ug/L	3/5/2022	12:44:27PM	SES
W01A-05 2104 (DF) L-RE069921-25	Across From A225	Lead	< 1.0	ug/L	3/5/2022	12:48:01PM	SES
W01A-06 2104 (DF) L-RE069921-26	Across From A219	Lead	< 1.0	ug/L	3/5/2022	12:51:36PM	SES
W01A-06 2104 (DF) L-RE069921-27	Across From A219	Lead	< 1.0	ug/L	3/5/2022	12:55:11PM	SES
W01A-06 2104 (DF) L-RE069921-28	Across From A219	Lead	< 1.0	ug/L	3/5/2022	12:58:46PM	SES
W01A-07 2104 (DF) L-RE069921-29	C Wing	Lead	< 1.0	ug/L	3/5/2022	1:02:19PM	SES
W01A-07 2104 (DF) L-RE069921-30	C Wing	Lead	< 1.0	ug/L	3/5/2022	1:05:52PM	SES

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools


Analytical Results

Project Number: Crestwood Middle School
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
08-Mar-22 15:08

Notes and Definitions

DET Analyte DETECTED
ND Analyte NOT DETECTED at or above the reporting limit
NR Not Reported
dry Sample results reported on a dry weight basis
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

SITE: CRESTWOOD MIDDLE SCHOOL 7100 Foxcroft Drive, Frederick, MD 21703
 SAMPLER'S NAME: DUREKA ALUWIHARE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1	K31-02 2104 (KS) Test Point	CMS	Kitchen	3	D2010.60 Plumbing Fixture (Kitchen Sink)	March 4, 2022 3:54
2	K31-03 2104 (KS) Test Point	CMS	Kitchen	3	D2010.60 Plumbing Fixture (Kitchen Sink)	March 4, 2022 3:58
3	K31-04 2104 (KS) Test Point	CMS	Kitchen	3	D2010.60 Plumbing Fixture (Kitchen Sink)	March 4, 2022 4:00
4	S23-038 2104 (NO) Test Point	CMS	Nurses Office	3	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 4, 2022 4:08
5	S23-039 2104 (TL) Test Point	CMS	Front Office Teachers Lounge	3	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 4, 2022 4:10
6	S23-109 2104 (HE) Test Point	CMS	A219/Home-Ec	3	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 4, 2022 4:15
7	S23-110 2104 (HE) Test Point	CMS	A219/Home-Ec	3	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 4, 2022 4:16
8	S23-111 2104 (HE) Test Point	CMS	A219/Home-Ec	3	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 4, 2022 4:17
9	S23-112 2104 (HE) Test Point	CMS	A219/Home-Ec	3	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 4, 2022 4:18
10	S23-113 2104 (HE) Test Point	CMS	A219/Home-Ec	3	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 4, 2022 4:19
11	S23-114 2104 (HE) Test Point	CMS	A219/Home-Ec	3	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 4, 2022 4:20

69921

SITE: CRESTWOOD MIDDLE SCHOOL 7100 Foxcroft Drive, Frederick, MD 21703

SAMPLER'S NAME: DUREKA ALUWIHARE

69921

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
12	S23-115 2104 (HE) Test Point	CMS	A219/Home-Ec	3	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 4, 2022 4:21
13	S23-116 2104 (HE) Test Point	CMS	A219/Home-Ec	3	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 4, 2022 4:22
14	W01A-01 2104 (DF) Test Point L-R (left)	CMS	By Gym	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 4, 2022 4:34
15	W01A-01 2104 (DF) Test Point L-R (right)	CMS	By Gym	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 4, 2022 4:35
16	W01A-02 2104 (DF) Test Point L-R-B (left)	CMS	By Gym	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 4, 2022 4:36
17	W01A-02 2104 (DF) Test Point L-R-B (right)	CMS	By Gym	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 4, 2022 4:37
18	W01A-02 2104 (DF) Test Point L-R-B (bottle filler)	CMS	By Gym	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 4, 2022 4:38
19	W01A-03 2104 (DF) Test Point L-R-B (left)	CMS	Across From B115	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 4, 2022 4:55
20	W01A-03 2104 (DF) Test Point L-R-B (right)	CMS	Across From B115	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 4, 2022 4:56
21	W01A-03 2104 (DF) Test Point L-R-B (bottle filler)	CMS	Across From B115	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 4, 2022 4:57
22	W01A-04 2104 (DF) Test Point L-R (left)	CMS	Across From A128	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 4, 2022 5:00

SITE: CRESTWOOD MIDDLE SCHOOL 7100 Foxcroft Drive, Frederick, MD 21703

SAMPLER'S NAME: DUREKA ALUWIHARE

69921

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
23	W01A-04 2104 (DF) Test Point L-R (right)	CMS	Across From A128	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 4, 2022 5:02
24	W01A-05 2104 (DF) Test Point L-R (left)	CMS	Across From A225	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 4, 2022 4:49
25	W01A-05 2104 (DF) Test Point L-R (right)	CMS	Across From A225	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 4, 2022 4:49
26	W01A-06 2104 (DF) Test Point L-R-B (left)	CMS	Across From A219	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 4, 2022 4:45
27	W01A-06 2104 (DF) Test Point L-R-B (right)	CMS	Across From A219	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 4, 2022 4:46
28	W01A-06 2104 (DF) Test Point L-R-B (bottle filler)	CMS	Across From A219	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 4, 2022 4:47
29	W01A-07 2104 (DF) Test Point L-R (left)	CMS	C Wing	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 4, 2022 5:05
30	W01A-07 2104 (DF) Test Point L-R (right)	CMS	C Wing	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 4, 2022 0:06