



Project: Frederick Co Schools

Analytical Results

Project Number: Emmittsburg Elementary
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
17-Mar-22 15:15

Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K31-01 1040 (KS)	E070044-01	Kitchen	Lead	4.5	ug/L	3/16/2022 11:18:15AM	MAP
S23-03 1040 (TL)	E070044-02	Staff Lounge/Room 101	Lead	17.3	ug/L	3/16/2022 11:28:54AM	MAP
S23-28 1040 (NO)	E070044-03	Health Room	Lead	1.5	ug/L	3/16/2022 11:39:36AM	MAP
W01A-01 1040 (DF) L	E070044-04	Cafeteria	Lead	< 1.0	ug/L	3/16/2022 11:43:10AM	MAP
W01A-01 1040 (DF) R	E070044-05	Cafeteria	Lead	< 1.0	ug/L	3/16/2022 11:46:44AM	MAP
W01A-01 1040 (DF) B	E070044-06	Cafeteria	Lead	< 1.0	ug/L	3/16/2022 11:50:18AM	MAP
W01A-02 1040 (DF)	E070044-07	Room 101	Lead	2.9	ug/L	3/16/2022 11:53:53AM	MAP
W01A-03 1040 (DF)	E070044-08	Across From Room 109	Lead	< 1.0	ug/L	3/16/2022 11:57:29AM	MAP
W01A-03 1040 (DF) B	E070044-09	Across From Room 109	Lead	< 1.0	ug/L	3/16/2022 12:01:04PM	MAP
W01A-04 1040 (DF)	E070044-10	Room 113	Lead	< 1.0	ug/L	3/16/2022 12:04:37PM	MAP
W01A-05 1040 (DF)	E070044-11	Room 118	Lead	3.1	ug/L	3/16/2022 12:08:10PM	MAP
W01A-06 1040 (DF)	E070044-12	Art Room	Lead	1.2	ug/L	3/16/2022 12:25:58PM	MAP
W01A-07 1040 (DF)	E070044-13	Gym Room 133	Lead	1.3	ug/L	3/16/2022 12:29:32PM	MAP
W01A-07 1040 (DF) B	E070044-14	Gym Room 133	Lead	1.6	ug/L	3/16/2022 12:33:06PM	MAP
W01B-01 1040 (DF)	E070044-15	Gym	Lead	7.3	ug/L	3/16/2022 12:36:40PM	MAP

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools


Analytical Results

Project Number: Emmittsburg Elementary
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
17-Mar-22 15:15

Notes and Definitions

DET Analyte DETECTED
ND Analyte NOT DETECTED at or above the reporting limit
NR Not Reported
dry Sample results reported on a dry weight basis
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.


SITE: EMMITSBURG ELEMENTARY SCHOOL 300 S. Seton Avenue, Emmitsburg, MD 21722
 SAMPLER'S NAME: PHILLIP RANKINE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1	K31-01 1040 (KS)	EES	Kitchen	1	D2010.60 Plumbing Fixture (Kitchen Sink)	March 15, 2022 9:35
2	S23-03 1040 (TL)	EES	Staff Lounge/Room 101	1	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 15, 2022 4:42
3	S23-28 1040 (NO)	EES	Health Room	1	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 15, 2022 4:40
4	W01A-01 1040 (DF) L	EES	Cafeteria	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 15, 2022 4:31
5	W01A-01 1040 (DF) R	EES	Cafeteria	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 15, 2022 4:32
6	W01A-01 1040 (DF) B	EES	Cafeteria	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 15, 2022 4:33
7	W01A-02 1040 (DF)	EES	Room 101	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 15, 2022 4:43
8	W01A-03 1040 (DF)	EES	Across From Room 109	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 15, 2022 4:46
9	W01A-03 1040 (DF) B	EES	Across From Room 109	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 15, 2022 4:47
10	W01A-04 1040 (DF)	EES	Room 113	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 15, 2022 4:50

70044

SITE: EMMITSBURG ELEMENTARY SCHOOL 300 S. Seton Avenue, Emmitsburg, MD 21722
 SAMPLER'S NAME: PHILLIP RANKINE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
11	W01A-05 1040 (DF)	EES	Room 118	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 15, 2022 4:55:2
12	W01A-06 1040 (DF)	EES	Art Room	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 15, 2022 4:55:3
13	W01A-07 1040 (DF)	EES	Gym Room 133	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 15, 2022 4:55:5
14	W01A-07 1040 (DF) B	EES	Gym Room 133	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 15, 2022 4:55:6
15	W01B-01 1040 (DF)	EES	Gym	1	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	March 15, 2022 4:55:8


 Phillip Rankine

9/19 3/15/22

Client: Frederick County Public Schools
ATTN: Accounts Payable 191 South East Street
Frederick, MD 21701-

Project: Emmitsburg Elementary School
Emmitsburg Elementary School

Site: Emmitsburg Elementary School
300 S. Seton Ave

Work order: FWC0312

Received at lab: 03/21/22 13:33
Date Reported: 03/23/22 15:54
Collected by: Marc Angleberger; ID: 0659MA
Treatment: N/A

Source: S23-03-1040-TL
(Drinking Water)(Grab - Flushed)

Collected: 3/21/2022 10:20:00AM

Data Analyzed by: Fredericktowne Labs:


Lab ID	Parameter	Result	Units	MRL	Prepared	Analyzed	Analyst	Qual	Method
FWC0312-01	Lead	<0.005	mg/L	0.005	03/23/22 09:26	03/23/22 10:37	KMW		SM3113-B

Source: W01B-01-1040-DF
(Drinking Water)(Grab - Flushed)

Collected: 3/21/2022 10:27:00AM

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	Prepared	Analyzed	Analyst	Qual	Method
FWC0312-02	Lead	<0.005	mg/L	0.005	03/23/22 09:26	03/23/22 10:55	KMW		SM3113-B


Sara E. Randall, President

Rush
FWC0312

CHAIN OF CUSTODY

FREDERICKTOWNE LABS, INC.
3020 VENTRIE CT., PO BOX 245, MYERSVILLE, MD 21773
301-293-3340 OR FAX 301-293-2366

Page: 1 of 1

FTL Acct. No.: 344-				Collected By: (Please Print) <i>MARC Angleberger</i>						Analyses To Be Performed									
Compliance Sample (regulated): Yes <input type="checkbox"/> No <input type="checkbox"/>				Project: <i>Emmitsburg Elementary School</i> <i>300 S. Seton Ave Emmitsburg, MD 21727</i>						Affiliation: Frederick County Public Schools									
Lab ID	Field Sample ID	Site Description	Collection Date		Collection Time		Matrix DW/ WW	pH	Res. Cl	DO	Temp	Grab/Comp	Rec'd Temp (at lab)	Preservation					
			Start	End	Start	End													
	<i>Flush</i>	<i>S23-03-1040-TL</i>	<i>3-21-22</i>		<i>10³⁰ AM</i>		<input checked="" type="checkbox"/>					<input checked="" type="checkbox"/>		<i>Lead</i>					
	<i>Flush</i>	<i>W01B-01-1040-DF</i>	<i>11</i>		<i>10²⁷ AM</i>		<input checked="" type="checkbox"/>					<input checked="" type="checkbox"/>							
Relinquished By: _____ Date/Time _____			Received By: _____ Date/Time _____			Treatment Devices Present: Yes <input type="checkbox"/> No <input type="checkbox"/>													
(Print): <i>MARC R. Angleberger</i> <i>3-21-22</i>			(Print): <i>Kathy Heffner</i> <i>3:21:22</i>			Describe Treatment Device(s):													
(Signature): <i>MARC R. Angleberger</i>			(Signature): <i>Kathy Heffner</i> <i>1333</i>																
Relinquished By: _____ Date/Time _____			Received By: _____ Date/Time _____			Lead & Copper Samples - Water Last Used:													
(Print):			(Print):			Date: _____ Time: _____													
(Signature):			(Signature):			Method of Shipment: Iced: Yes <input type="checkbox"/> No <input type="checkbox"/>													
Relinquished By: _____ Date/Time _____			Received By: _____ Date/Time _____			Condition of Sample(s) upon Receipt:													
(Print):			(Print):																
(Signature):			(Signature):																