



Project: Frederick Co Schools

## Analytical Results

Project Number: Earth & Space Sciences Lab]  
Client Name: TIDEWATER  
Project Manager: Meneka Rodrigo

Reported:  
15-Mar-22 10:16

### Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
S23-07 1006 (TL)	E069996-01	Room 104	Lead	1.1	ug/L	3/13/2022 11:14:39AM	SES
W01A-01 1006 (DF) L-RE069996-02		Outside of Room 104	Lead	< 1.0	ug/L	3/13/2022 11:25:22AM	SES
W01A-01 1006 (DF) L-RE069996-03		Outside of Room 104	Lead	< 1.0	ug/L	3/13/2022 11:28:56AM	SES
W01A-01 1006 (DF) L-RE069996-04		Outside of Room 104	Lead	< 1.0	ug/L	3/13/2022 11:32:31AM	SES

Stephen Shelley, Laboratory Director

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*



Project: Frederick Co Schools


## Analytical Results

Project Number: Earth & Space Sciences Lab]  
Client Name: TIDEWATER  
Project Manager: Meneka Rodrigo

Reported:  
15-Mar-22 10:16

## Notes and Definitions

DET Analyte DETECTED  
ND Analyte NOT DETECTED at or above the reporting limit  
NR Not Reported  
dry Sample results reported on a dry weight basis  
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*




Project: Frederick Co Schools

## Analytical Results

Project Number: Earth & Space Sciences Lab]  
Client Name: TIDEWATER  
Project Manager: Meneka Rodrigo

Reported:  
15-Mar-22 10:16




Stephen Shelley, Laboratory Director

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*


6999L

SITE: EARTH AND SPACE SCIENCES LABORATORY 210 Madison St, Frederick, MD 21701  
SAMPLER'S NAME: PHILLIP RANKINE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1	S23-07 1006 (TL)	ESSL	Room 104	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 10, 2022 4:33
2	W01A-01 1006 (DF) L-R-B (left)	ESSL	Outside of Room 104	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain) <i>Bottle Filler</i>	March 10, 2022 4:49
3	W01A-01 1006 (DF) L-R-B (right)	ESSL	Outside of Room 104	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 10, 2022 4:50
4	W01A-01 1006 (DF) L-R-B (bottle filler)	ESSL	Outside of Room 104	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 10, 2022 4:51

  
Phillip Rankine

301 3328094

  
3/10/22 @ 0907