



Project: Frederick Co Schools

Analytical Results

Project Number: Lincoln A -Success Program

Client Name: TIDEWATER

Project Manager: Meneka Rodrigo

Reported:

15-Mar-22 10:19

Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K17-01 1005 (IM)	E069997-01	Room 110	Lead	< 1.0	ug/L	3/13/2022 11:36:06AM	SES
S23-12 1005 (HE)	E069997-02	Room 138	Lead	< 1.0	ug/L	3/13/2022 11:39:42AM	SES
S23-22 1005 (TL)	E069997-03	Room A131	Lead	< 1.0	ug/L	3/13/2022 11:50:26AM	SES
S23-23 1005 (OT)	E069997-04	Room 139	Lead	< 1.0	ug/L	3/13/2022 11:54:02AM	SES
S23-24 1005 (OT)	E069997-05	Room 139	Lead	< 1.0	ug/L	3/13/2022 11:57:39AM	SES
S23-25 1005 (OT)	E069997-06	Room 139	Lead	< 1.0	ug/L	3/13/2022 12:01:11PM	SES
S23-26 1005 (OT)	E069997-07	Room 139	Lead	1.1	ug/L	3/13/2022 12:04:43PM	SES
W01A-01 1005 (DF)	E069997-08	Entrance to Cafe	Lead	< 1.0	ug/L	3/13/2022 12:15:23PM	SES
W01A-01 1005 (DF) B	E069997-09	Entrance to Cafe	Lead	< 1.0	ug/L	3/13/2022 12:18:56PM	SES
W01A-02 1005 (DF)	E069997-10	Across from A117	Lead	< 1.0	ug/L	3/13/2022 12:22:30PM	SES
W01B-01 1005 (DF) L	E069997-11	Boys and Girls Club	Lead	< 1.0	ug/L	3/13/2022 12:36:49PM	SES
W01B-01 1005 (DF) R	E069997-12	Boys and Girls Club	Lead	< 1.0	ug/L	3/13/2022 12:40:23PM	SES
W01B-02 1005 (DF) L	E069997-13	Back hall by door 8	Lead	< 1.0	ug/L	3/13/2022 12:43:59PM	SES
W01B-02 1005 (DF) R	E069997-14	Back hall by door 8	Lead	< 1.0	ug/L	3/13/2022 12:47:34PM	SES
W01B-02 1005 (DF) B	E069997-15	Back hall by door 8	Lead	< 1.0	ug/L	3/13/2022 12:51:09PM	SES

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools


Analytical Results

Project Number: Lincoln A -Success Program
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
15-Mar-22 10:19

Notes and Definitions

DET Analyte DETECTED
ND Analyte NOT DETECTED at or above the reporting limit
NR Not Reported
dry Sample results reported on a dry weight basis
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

69997

SITE: LINCOLN A - SUCCESS PROGRAM 250 Madison Street, Frederick, MD 21701
SAMPLER'S NAME: PHILLIP RANKINE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
12	W01B-01 1005 (DF) R	SP	Boys and Girls Club	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	March 10, 2022 4:41
13	W01B-02 1005 (DF) L	SP	Back hall by door 8	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	March 10, 2022 4:29
14	W01B-02 1005 (DF) R	SP	Back hall by door 8	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	March 10, 2022 4:31
15	W01B-02 1005 (DF) B	SP	Back hall by door 8	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	March 10, 2022 4:33

Phillip Rankine

301 332 81094

69997


SITE: LINCOLN A - SUCCESS PROGRAM 250 Madison Street, Frederick, MD 21701
 SAMPLER'S NAME: PHILLIP RANKINE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1	K17-01 1005 (IM)	SP	Room 110	6	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	March 10, 2022 4:16
2	S23-12 1005 (HE)	SP	Room 138	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 10, 2022 4:25
3	S23-22 1005 (TL)	SP	Room A131	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 10, 2022 4:27
4	S23-23 1005 (OT)	SP	Room 139	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 10, 2022 4:19
5	S23-24 1005 (OT)	SP	Room 139	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 10, 2022 4:20
6	S23-25 1005 (OT)	SP	Room 139	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 10, 2022 4:22
7	S23-26 1005 (OT)	SP	Room 139	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 10, 2022 4:23
8	W01A-01 1005 (DF)	SP	Entrance to Cafe	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain) <i>Leak</i>	March 10, 2022 4:16
9	W01A-01 1005 (DF) B	SP	Entrance to Cafe	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain) <i>Leak</i>	March 10, 2022 4:18
10	W01A-02 1005 (DF)	SP	Across from A117	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 10, 2022 4:38
11	W01B-01 1005 (DF) L	SP	Boys and Girls Club	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain) <i>Leak</i>	March 10, 2022 4:50


6999L

SITE: EARTH AND SPACE SCIENCES LABORATORY 210 Madison St, Frederick, MD 21701
SAMPLER'S NAME: PHILLIP RANKINE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1	S23-07 1006 (TL)	ESSL	Room 104	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 10, 2022 4:33
2	W01A-01 1006 (DF) L-R-B (left)	ESSL	Outside of Room 104	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain) <i>Bottle Filler</i>	March 10, 2022 4:49
3	W01A-01 1006 (DF) L-R-B (right)	ESSL	Outside of Room 104	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 10, 2022 4:50
4	W01A-01 1006 (DF) L-R-B (bottle filler)	ESSL	Outside of Room 104	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 10, 2022 4:51


Phillip Rankine

301 3329094


3/10/22 @ 0907