



Project: Frederick Co Schools

Analytical Results

Project Number: Middletown Middle School
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
11-Apr-22 16:04

Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K17-02 2031 (IM)	E070303-01	Kitchen	Lead	< 1.0	ug/L	4/9/2022 2:32:08PM	SES
K31-01 2031 (KS) L	E070303-02	Kitchen	Lead	7.3	ug/L	4/9/2022 2:35:43PM	SES
K31-01 2031 (KS) R	E070303-03	Kitchen	Lead	4.5	ug/L	4/9/2022 2:39:18PM	SES
S23-002 2031 (TL)	E070303-04	Faculty Lounge In Corner	Lead	3.4	ug/L	4/9/2022 2:42:53PM	SES
S23-094 2031 (HE)	E070303-05	Room 127 Home Ec Kitchen #1	Lead	15.4	ug/L	4/9/2022 2:46:28PM	SES
S23-095 2031 (HE)	E070303-06	Room 127 Home Ec Kitchen #2	Lead	10.4	ug/L	4/9/2022 2:57:14PM	SES
S23-096 2031 (HE)	E070303-07	Room 127 Home Ec Kitchen #3	Lead	11.5	ug/L	4/9/2022 3:00:49PM	SES
S23-097 2031 (HE)	E070303-08	Room 127 Home Ec Kitchen #4	Lead	12.4	ug/L	4/9/2022 3:04:26PM	SES
S23-098 2031 (HE)	E070303-09	Room 127 Home Ec Kitchen #5	Lead	5.7	ug/L	4/9/2022 3:07:58PM	SES
S23-099 2031 (HE)	E070303-10	Room 127 Home Ec Kitchen #6	Lead	3.9	ug/L	4/9/2022 3:11:30PM	SES
S23-118 2031 (NO)	E070303-11	Health Room	Lead	5.2	ug/L	4/9/2022 3:22:10PM	SES
W01A-01 2031 (DF)	E070303-12	Girl's Restroom #1	Lead	26.8	ug/L	4/9/2022 3:25:43PM	SES
W01A-02 2031 (DF)	E070303-13	Girl's Restroom #2	Lead	< 1.0	ug/L	4/9/2022 3:29:17PM	SES
W01A-02 2031 (DF) B	E070303-14	Girl's Restroom #2	Lead	< 1.0	ug/L	4/9/2022 3:40:00PM	SES
W01A-03 2031 (DF)	E070303-15	Hallway 6 at School Store	Lead	2.3	ug/L	4/9/2022 3:43:35PM	SES
W01A-03 2031 (DF) B	E070303-16	Hallway 6 at School Store	Lead	2.3	ug/L	4/9/2022 3:47:10PM	SES
W01A-04 2031 (DF)	E070303-17	Hallway 6 at Main Office	Lead	1.3	ug/L	4/9/2022 3:50:45PM	SES
W01A-05 2031 (DF)	E070303-18	Hallway 6 at Gym	Lead	< 1.0	ug/L	4/9/2022 3:54:20PM	SES

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools

Analytical Results

Project Number: Middletown Middle School
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
11-Apr-22 16:04

W01A-05 2031 (DF) B	E070303-19	Hallway 6 at Gym	Lead	< 1.0	ug/L	4/9/2022	3:57:53PM	SES
W01A-07 2031 (DF)	E070303-20	Cafeteria	Lead	7.8	ug/L	4/9/2022	4:04:58PM	SES
W01A-09 2031 (DF)	E070303-21	Hallway 13 By Room 201	Lead	< 1.0	ug/L	4/9/2022	4:22:47PM	SES
W01A-09 2031 (DF) B	E070303-22	Hallway 13 By Room 201	Lead	< 1.0	ug/L	4/9/2022	4:26:20PM	SES
W01A-10 2031 (DF)	E070303-23	Hallway 8 at Conditioning Room	Lead	< 1.0	ug/L	4/9/2022	4:29:55PM	SES
W01A-11 2031 (DF)	E070303-24	Hallway 10 Work Room	Lead	< 1.0	ug/L	4/9/2022	4:33:29PM	SES

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools


Analytical Results

Project Number: Middletown Middle School
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
11-Apr-22 16:04

Notes and Definitions

DET Analyte DETECTED
ND Analyte NOT DETECTED at or above the reporting limit
NR Not Reported
dry Sample results reported on a dry weight basis
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

70303

SITE: MIDDLETOWN MIDDLE SCHOOL 100 Martha Mason Street, Middletown, MD 21769
 SAMPLER'S NAME: CHRISTOPHER WILCOME

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1	K17-02 2031 (IM)	MMS	Kitchen	2	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	April 8, 2022 6:07
2	K31-01 2031 (KS) L	MMS	Kitchen	2	D2010.60 Plumbing Fixture (Kitchen Sink)	April 8, 2022 6:08
3	K31-01 2031 (KS) R	MMS	Kitchen	2	D2010.60 Plumbing Fixture (Kitchen Sink)	April 8, 2022 6:08
4	S23-002 2031 (TL)	MMS	Faculty Lounge In Corner	2	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 8, 2022 6:05
5	S23-094 2031 (HE)	MMS	Room 127 Home Ec Kitchen #1	2	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 8, 2022 6:17
6	S23-095 2031 (HE)	MMS	Room 127 Home Ec Kitchen #2	2	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 8, 2022 6:16
7	S23-096 2031 (HE)	MMS	Room 127 Home Ec Kitchen #3	2	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 8, 2022 6:15
8	S23-097 2031 (HE)	MMS	Room 127 Home Ec Kitchen #4	2	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 8, 2022 6:14
9	S23-098 2031 (HE)	MMS	Room 127 Home Ec Kitchen #5	2	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 8, 2022 6:14
10	S23-099 2031 (HE)	MMS	Room 127 Home Ec Kitchen #6	2	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 8, 2022 6:14

SITE: MIDDLETOWN MIDDLE SCHOOL 100 Martha Mason Street, Middletown, MD 21769
 SAMPLER'S NAME: CHRISTOPHER WILCOME

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
11	S23-118 2031 (NO)	MMS	Health Room	2	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 8, 2022 6:18
12	W01A-01 2031 (DF)	MMS	Girls Restroom #1	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 8, 2022 6:02
13	W01A-02 2031 (DF)	MMS	Girls Restroom #2	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 8, 2022 6:00
14	W01A-02 2031 (DF) B	MMS	Girls Restroom #2	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 8, 2022 6:00
15	W01A-03 2031 (DF)	MMS	Hallway 6 at School Store	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 8, 2022 5:57
16	W01A-03 2031 (DF) B	MMS	Hallway 6 at School Store	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 8, 2022 5:57
17	W01A-04 2031 (DF)	MMS	Hallway 6 at Main Office	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 8, 2022 6:09
18	W01A-05 2031 (DF)	MMS	Hallway 6 at Gym	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 8, 2022 6:12
19	W01A-05 2031 (DF) B	MMS	Hallway 6 at Gym	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 8, 2022 6:12
20	W01A-07 2031 (DF)	MMS	Cafeteria	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 8, 2022 6:03

SITE: MIDDLETOWN MIDDLE SCHOOL 100 Martha Mason Street, Middletown, MD 21769
SAMPLER'S NAME: CHRISTOPHER WILLCOME

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
21	W01A-09 2031 (DF)	MMS	Hallway 13 By Room 201	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 8, 2022 6:21
22	W01A-09 2031 (DF) B	MMS	Hallway 13 By Room 201	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 8, 2022 6:21
23	W01A-10 2031 (DF)	MMS	Hallway 8 at Conditioning Room	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 8, 2022 6:29
24	W01A-11 2031 (DF)	MMS	Hallway 10 Work Room	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 8, 2022 6:21

Client: Frederick County Public Schools
ATTN: Accounts Payable 191 South East St
Frederick, MD 21701

Project: Middletown Middle School

Site: N/A

Work order: FWD0351

Received at lab: 04/13/22 11:35
Date Reported: 04/15/22 15:16
Collected by: Marc Angleberger ID: MA-0659
Treatment: N/A

Source: S23-098-2031-HE
(Drinking Water)(Grab - Flushed)

Collected: 4/13/2022 10:54:00AM

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	Prepared	Analyzed	Analyst	Qual	Method
FWD0351-01	Lead	<5	ppb	5	04/14/22 11:28	04/14/22 11:58	KMW		SM3113-B

Source: S23-097-2031-HE
(Drinking Water)(Grab - Flushed)

Collected: 4/13/2022 10:56:00AM

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	Prepared	Analyzed	Analyst	Qual	Method
FWD0351-02	Lead	<5	ppb	5	04/14/22 11:28	04/14/22 12:06	KMW		SM3113-B

Source: S23-096-2031-HE
(Drinking Water)(Grab - Flushed)

Collected: 4/13/2022 10:57:00AM

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	Prepared	Analyzed	Analyst	Qual	Method
FWD0351-03	Lead	<5	ppb	5	04/14/22 11:28	04/14/22 12:15	KMW		SM3113-B

Source: S23-095-2031-HE
(Drinking Water)(Grab - Flushed)

Collected: 4/13/2022 10:58:00AM

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	Prepared	Analyzed	Analyst	Qual	Method
FWD0351-04	Lead	<5	ppb	5	04/14/22 11:28	04/14/22 12:24	KMW		SM3113-B

Source: S23-094-2031-HE
(Drinking Water)(Grab - Flushed)

Collected: 4/13/2022 11:00:00AM

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	Prepared	Analyzed	Analyst	Qual	Method
FWD0351-05	Lead	<5	ppb	5	04/14/22 11:28	04/14/22 12:33	KMW		SM3113-B

Sara E. Randall
Sara E. Randall, President

Fredericktowne Labs, Inc. is a State Certified Water Quality Laboratory
Maryland Cert. No. 116 Virginia Cert. No. 00444
West Virginia Cert. 415 MDOT WBE Cert. No.: 91-158

Client: Frederick County Public Schools
ATTN: Accounts Payable 191 South East St
Frederick, MD 21701

Project: Middletown Middle School

Site: N/A

Work order: FWD0351

Received at lab: 04/13/22 11:35
Date Reported: 04/15/22 15:16
Collected by: Marc Angleberger ID: MA-0659
Treatment: N/A

Source: W01A-07-2031-DF

(Drinking Water)(Grab - Flushed)

Collected: 4/13/2022 11:03:00AM

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	Prepared	Analyzed	Analyst	Qual	Method
FWD0351-06	Lead	8	ppb	5	04/14/22 11:28	04/14/22 12:42	KMW		SM3113-B

Source: K31-01-2031-KS

(Drinking Water)(Grab - Flushed)

Collected: 4/13/2022 11:06:00AM

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	Prepared	Analyzed	Analyst	Qual	Method
FWD0351-07	Lead	<5	ppb	5	04/14/22 11:28	04/14/22 12:50	KMW		SM3113-B


Source: W01A-01-2031-DF

(Drinking Water)(Grab - Flushed)

Collected: 4/12/2022 11:10:00AM

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	Prepared	Analyzed	Analyst	Qual	Method
FWD0351-08	Lead	11	ppb	5	04/14/22 11:28	04/14/22 12:59	KMW		SM3113-B


Sara E. Randall, President

