



Project: Frederick Co Schools

Analytical Results

Project Number: Orchard Grove ES
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
08-Feb-22 11:29

Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K17-01 1018 (IM)	E069613-01	Kitchen	Lead	3.5	ug/L	2/7/2022 12:36:26PM	SES
K31-02 1018 (KS)	E069613-02	Kitchen	Lead	< 1.0	ug/L	2/7/2022 12:40:01PM	SES
S23-18 1018 (TL)	E069613-03	Staff Lounge	Lead	< 1.0	ug/L	2/7/2022 12:43:36PM	SES
S23-83 1018 (NO)	E069613-04	Nurses Office	Lead	< 1.0	ug/L	2/7/2022 12:54:21PM	SES
W01A-01 1018 (DF)	E069613-05	Main Entrance	Lead	1.5	ug/L	2/7/2022 12:57:57PM	SES
W01A-02 1018 (DF)	E069613-06	Main Entrance	Lead	< 1.0	ug/L	2/7/2022 1:01:33PM	SES
W01A-03 1018 (DF)	E069613-07	Cafeteria	Lead	< 1.0	ug/L	2/7/2022 1:05:05PM	SES
W01A-04 1018 (DF) B (fE069613-08)	E069613-08	Cafeteria	Lead	< 1.0	ug/L	2/7/2022 1:08:38PM	SES
W01A-04 1018 (DF) B (tE069613-09)	E069613-09	Cafeteria	Lead	< 1.0	ug/L	2/7/2022 1:19:17PM	SES
W01A-05 1018 (DF) B (fE069613-10)	E069613-10	2nd Floor by Room 207	Lead	< 1.0	ug/L	2/7/2022 1:22:51PM	SES
W01A-05 1018 (DF) B (tE069613-11)	E069613-11	2nd Floor by Room 207	Lead	< 1.0	ug/L	2/7/2022 1:26:24PM	SES
W01A-06 1018 (DF) L-RE069613-12	E069613-12	1st Floor by 103	Lead	< 1.0	ug/L	2/7/2022 1:37:07PM	SES
W01A-06 1018 (DF) L-RE069613-13	E069613-13	1st Floor by 103	Lead	< 1.0	ug/L	2/7/2022 1:40:42PM	SES
W01A-07 1018 (DF) L-RE069613-14	E069613-14	2nd Floor By Room 219	Lead	< 1.0	ug/L	2/7/2022 1:44:17PM	SES
W01A-07 1018 (DF) L-RE069613-15	E069613-15	2nd Floor By Room 219	Lead	< 1.0	ug/L	2/7/2022 1:47:52PM	SES

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools


Analytical Results

Project Number: Orchard Grove ES
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
08-Feb-22 11:29

Notes and Definitions

DET Analyte DETECTED
ND Analyte NOT DETECTED at or above the reporting limit
NR Not Reported
dry Sample results reported on a dry weight basis
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

SITE: ORCHARD GROVE ELEMENTARY SCHOOL 5898 HANNOVER DRIVE, FREDERICK, MD 21703
SAMPLER'S NAME: DUREKA ALUWIHARE


08612

Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1 K17-01 1018 (IM)	OGES	Kitchen	6	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	February 4, 2022 04:21g
2 K31-02 1018 (KS)	OGES	Kitchen	6	D2010.60 Plumbing Fixture (Kitchen Sink)	February 4, 2022 04:21
3 S23-18 1018 (TL)	OGES	Staff Lounge	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 4, 2022 04:27
4 S23-83 1018 (NO)	OGES	Nurses Office	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 4, 2022 04:33
5 W01A-01 1018 (DF)	OGES	Main Entrance	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 4, 2022 04:38
6 W01A-02 1018 (DF)	OGES	Main Entrance	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 4, 2022 04:38
7 W01A-03 1018 (DF)	OGES	Cafeteria	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 4, 2022 04:41
8 W01A-04 1018 (DF) B (fountain)	OGES	Cafeteria	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 4, 2022 04:50
9 W01A-04 1018 (DF) B (bottle filler)	OGES	Cafeteria	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 4, 2022 04:51
10 W01A-05 1018 (DF) B (fountain)	OGES	2nd Floor by Room 207	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 4, 2022 04:58
11 W01A-05 1018 (DF) B (bottle filler)	OGES	2nd Floor by Room 207	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 4, 2022 04:58

69613

SITE: ORCHARD GROVE ELEMENTARY SCHOOL 5898 HANNOVER DRIVE, FREDERICK, MD 21703
SAMPLER'S NAME: DUREKA ALUWIHARE

Name	Site	Area-Room number	Area	Category	Sampling Date and Time
12 W01A-06 1018 (DF) L-R (left)	OGES	1st Floor by 103	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 4, 2022 05:09
13 W01A-06 1018 (DF) L-R (right)	OGES	1st Floor by 103	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 4, 2022 05:04
14 W01A-07 1018 (DF) L-R (left)	OGES	2nd Floor By Room 219	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 4, 2022 05:21
15 W01A-07 1018 (DF) L-R (right)	OGES	2nd Floor By Room 219	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 4, 2022 05:21


Dureka Aluwihare

2/4/22 08:25