



Project: Frederick Co Schools

Analytical Results

Project Number: Parkway Elementary
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
15-Mar-22 10:22

Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K19-02 1002 (OT)	E069998-01	Kitchen	Lead	1.3	ug/L	3/13/2022 12:54:42PM	SES
K31-02 1002 (KS)	E069998-02	Kitchen	Lead	< 1.0	ug/L	3/13/2022 1:01:47PM	SES
S23-25 1002 (NO)	E069998-03	Health Room	Lead	< 1.0	ug/L	3/13/2022 1:19:37PM	SES
S23-27 1002 (TL)	E069998-04	Room 16	Lead	< 1.0	ug/L	3/13/2022 1:23:11PM	SES
W01A-01 1002 (DF) B (fE069998-05		Across From Cafeteria	Lead	< 1.0	ug/L	3/13/2022 1:26:45PM	SES
W01A-01 1002 (DF) B (tE069998-06		Across From Cafeteria	Lead	< 1.0	ug/L	3/13/2022 1:30:20PM	SES
W01A-02 1002 (DF) B (fE069998-07		1st Floor By Custodial Office	Lead	< 1.0	ug/L	3/13/2022 1:33:54PM	SES
W01A-02 1002 (DF) B (tE069998-08		1st Floor By Custodial Office	Lead	< 1.0	ug/L	3/13/2022 1:37:30PM	SES
W01A-04 1002 (DF) B (fE069998-09		2nd Floor Across From Library	Lead	< 1.0	ug/L	3/13/2022 1:41:05PM	SES
W01A-04 1002 (DF) B (tE069998-10		2nd Floor Across From Library	Lead	< 1.0	ug/L	3/13/2022 1:44:38PM	SES
W01A-05 1002 (DF) B (fE069998-11		2nd Floor By Boy's Br	Lead	< 1.0	ug/L	3/13/2022 1:48:11PM	SES
W01A-05 1002 (DF) B (tE069998-12		2nd Floor By Boy's Br	Lead	< 1.0	ug/L	3/13/2022 1:51:44PM	SES
W01B-03 1002 (DF)	E069998-13	By Front Entrance	Lead	< 1.0	ug/L	3/13/2022 2:09:33PM	SES

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools


Analytical Results

Project Number: Parkway Elementary
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
15-Mar-22 10:22

Notes and Definitions

DET Analyte DETECTED
ND Analyte NOT DETECTED at or above the reporting limit
NR Not Reported
dry Sample results reported on a dry weight basis
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

SITE: PARKWAY ELEMENTARY SCHOOL 300 Carroll Parkway, Frederick, MD 21701
 SAMPLER'S NAME: PHILLIP RANKINE


69998

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1	K19-02 1002 (OT)	PES	Kitchen	3	E1030.80 Foodservice Equipment (Kettle, Steam, Fixed Or Tilt)	March 10, 2022 5:34
2	K31-02 1002 (KS)	PES	Kitchen	3	D2010.60 Plumbing Fixture (Kitchen Sink)	March 10, 2022 5:32
3	S23-25 1002 (NO)	PES	Health Room	3	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 10, 2022 5:45
4	S23-27 1002 (TL)	PES	Room 16	3	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 10, 2022 5:51
5	W01A-01 1002 (DF) B (fountain)	PES	Across From Cafeteria	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain) <i>Office</i>	March 10, 2022 5:41
6	W01A-01 1002 (DF) B (bottle filler)	PES	Across From Cafeteria	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 10, 2022 5:42
7	W01A-02 1002 (DF) B (fountain)	PES	1st Floor By Custodial Office	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain) <i>Office</i>	March 10, 2022 6:05
8	W01A-02 1002 (DF) B (bottle filler)	PES	1st Floor By Custodial Office	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 10, 2022 6:09
9	W01A-04 1002 (DF) B (fountain)	PES	2nd Floor Across From Library	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 10, 2022 5:47
10	W01A-04 1002 (DF) B (bottle filler)	PES	2nd Floor Across From Library	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 10, 2022 5:49
11	W01A-05 1002 (DF) B (fountain)	PES	2nd Floor By Boy's Br	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 10, 2022 6:06

69998

SITE: PARKWAY ELEMENTARY SCHOOL 300 Carroll Parkway, Frederick, MD 21701
SAMPLER'S NAME: PHILLIP RANKINE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
12	W01A-05 1002 (DF) B (bottle filler)	PES	2nd Floor By Boy's Br	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 10, 2022 6:07
13	W01B-03 1002 (DF)	PES	By Front Entrance	3	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	March 10, 2022 5:55


Phillip Rankine

30133374024

and for SLL
3/11/22 @ 0901