



Project: Frederick Co Schools

## Analytical Results

Project Number: Sugarloaf Elementary School  
 Client Name: TIDEWATER  
 Project Manager: Meneka Rodrigo

Reported:  
 03-May-22 10:47

### Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K17-01 1072 (IM)	E070489-01	C112	Lead	< 1.0	ug/L	5/1/2022 12:37:38PM	SES
K17-03 1072 (IM)	E070489-02	A113/Staff Lounge	Lead	< 1.0	ug/L	5/1/2022 12:41:12PM	SES
K17-04 1072 (IM)	E070489-03	A113/Staff Lounge	Lead	1.8	ug/L	5/1/2022 12:51:55PM	SES
K31-01 1072 (KS)	E070489-04	Kitchen	Lead	< 1.0	ug/L	5/1/2022 12:55:30PM	SES
S23-016 1072 (TL)	E070489-05	A113/Staff Lounge	Lead	< 1.0	ug/L	5/1/2022 12:59:06PM	SES
S23-019 1072 (NO)	E070489-06	A102	Lead	< 1.0	ug/L	5/1/2022 1:02:41PM	SES
W01A-01 1072 (DF) L	E070489-07	A1 Hallway By A128	Lead	< 1.0	ug/L	5/1/2022 1:20:39PM	SES
W01A-01 1072 (DF) R	E070489-08	A1 Hallway By A128	Lead	< 1.0	ug/L	5/1/2022 1:17:03PM	SES
W01A-02 1072 (DF) L	E070489-09	First Floor Main Hallway By A110A	Lead	< 1.0	ug/L	5/1/2022 1:27:52PM	SES
W01A-02 1072 (DF) R	E070489-10	First Floor Main Hallway By A110A	Lead	< 1.0	ug/L	5/1/2022 1:31:24PM	SES
W01A-02 1072 (DF) B	E070489-11	First Floor Main Hallway By A110A	Lead	< 1.0	ug/L	5/1/2022 1:34:57PM	SES
W01A-03 1072 (DF) L	E070489-12	Cafeteria By Restrooms	Lead	< 1.0	ug/L	5/1/2022 1:45:36PM	SES
W01A-03 1072 (DF) R	E070489-13	Cafeteria By Restrooms	Lead	< 1.0	ug/L	5/1/2022 1:49:10PM	SES
W01A-03 1072 (DF) B	E070489-14	Cafeteria By Restrooms	Lead	< 1.0	ug/L	5/1/2022 1:52:44PM	SES
W01A-04 1072 (DF) L	E070489-15	Gym By Restrooms	Lead	< 1.0	ug/L	5/1/2022 2:07:22PM	SES
W01A-04 1072 (DF) R	E070489-16	Gym By Restrooms	Lead	< 1.0	ug/L	5/1/2022 2:18:06PM	SES
W01A-04 1072 (DF) B	E070489-17	Gym By Restrooms	Lead	< 1.0	ug/L	5/1/2022 2:21:40PM	SES
W01A-05 1072 (DF) L	E070489-18	Park & Rec Lobby	Lead	< 1.0	ug/L	5/1/2022 2:25:16PM	SES

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools

## Analytical Results

Project Number: Sugarloaf Elementary School  
Client Name: TIDEWATER  
Project Manager: Meneka Rodrigo

Reported:  
03-May-22 10:47

W01A-05 1072 (DF) R E070489-19	Park & Rec Lobby	Lead	< 1.0	ug/L	5/1/2022	2:28:51PM	SES
W01A-05 1072 (DF) B E070489-20	Park & Rec Lobby	Lead	< 1.0	ug/L	5/1/2022	2:32:24PM	SES
W01A-06 1072 (DF) L E070489-21	B1 Hallway By B109	Lead	< 1.0	ug/L	5/1/2022	2:39:29PM	SES
W01A-06 1072 (DF) R E070489-22	B1 Hallway By B109	Lead	< 1.0	ug/L	5/1/2022	2:57:18PM	SES
W01A-07 1072 (DF) L E070489-23	B2 Hallway By B221	Lead	< 1.0	ug/L	5/1/2022	3:00:52PM	SES
W01A-07 1072 (DF) R E070489-24	B2 Hallway By B221	Lead	< 1.0	ug/L	5/1/2022	3:04:26PM	SES
W01A-08 1072 (DF) L E070489-25	A2 Hallway By A222	Lead	< 1.0	ug/L	5/1/2022	3:08:01PM	SES
W01A-08 1072 (DF) R E070489-26	A2 Hallway By A222	Lead	< 1.0	ug/L	5/1/2022	3:11:35PM	SES

Stephen Shelley, Laboratory Director

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*



Project: Frederick Co Schools


## Analytical Results

Project Number: Sugarloaf Elementary School  
Client Name: TIDEWATER  
Project Manager: Meneka Rodrigo

Reported:  
03-May-22 10:47

## Notes and Definitions

DET Analyte DETECTED  
ND Analyte NOT DETECTED at or above the reporting limit  
NR Not Reported  
dry Sample results reported on a dry weight basis  
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

SITE: SUGARLOAF ELEMENTARY SCHOOL 3400 STONE BARN DRIVE, FRDERICK, MD 21704  
 SAMPLER'S NAME: Phillip Rankine

No.	Name	Site	Area-Room number	Region	Category	Sampling Date and Time
1	K17-01 1072 (IM)	SUES	C112	7	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	April 29, 2022 4:21
2	K17-03 1072 (IM)	SUES	A113/Staff Lounge	7	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	April 29, 2022 4:29
3	K17-04 1072 (IM)	SUES	A113/Staff Lounge	7	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	April 29, 2022 4:31
4	K31-01 1072 (KS)	SUES	Kitchen	7	D2010.60 Plumbing Fixture (Kitchen Sink)	April 29, 2022 4:23
5	S23-016 1072 (TL)	SUES	A113/Staff Lounge	7	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 29, 2022 4:28
6	S23-019 1072 (NO)	SUES	A102	7	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 29, 2022 4:33
7	W01A-01 1072 (DF) L	SUES	A1 Hallway By A128	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:35
8	W01A-01 1072 (DF) R	SUES	A1 Hallway By A128	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:37
9	W01A-02 1072 (DF) L	SUES	First Floor Main Hallway By A110A	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:13
10	W01A-02 1072 (DF) R	SUES	First Floor Main Hallway By A110A	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:15

70489

**SITE: SUGARLOAF ELEMENTARY SCHOOL      3400 STONE BARN DRIVE, FRDERICK, MD 21704**  
**SAMPLER'S NAME: Phillip Rankine**

No.	Name	Site	Area-Room number	Region	Category	Sampling Date and Time
11	W01A-02 1072 (DF) B	SUES	First Floor Main Hallway By A110A	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:12
12	W01A-03 1072 (DF) L	SUES	Cafeteria By Restrooms	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:18
13	W01A-03 1072 (DF) R	SUES	Cafeteria By Restrooms	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:19
14	W01A-03 1072 (DF) B	SUES	Cafeteria By Restrooms	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:17
15	W01A-04 1072 (DF) L	SUES	Gym By Restrooms	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:40
16	W01A-04 1072 (DF) R	SUES	Gym By Restrooms	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:41
17	W01A-04 1072 (DF) B	SUES	Gym By Restrooms	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:39
18	W01A-05 1072 (DF) L	SUES	Park & Rec Lobby	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:44
19	W01A-05 1072 (DF) R	SUES	Park & Rec Lobby	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:45
20	W01A-05 1072 (DF) B	SUES	Park & Rec Lobby	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:43

20289

SITE: SUGARLOAF ELEMENTARY SCHOOL 3400 STONE BARN DRIVE, FRDERICK, MD 21704  
 SAMPLER'S NAME: Phillip Rankine

No.	Name	Site	Area-Room number	Region	Category	Sampling Date and Time
21	W01A-06 1072 (DF) L	SUES	B1 Hallway By B109	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:47
22	W01A-06 1072 (DF) R	SUES	B1 Hallway By B109	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:48
23	W01A-07 1072 (DF) L	SUES	B2 Hallway By B221	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:50
24	W01A-07 1072 (DF) R	SUES	B2 Hallway By B221	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:51
25	W01A-08 1072 (DF) L	SUES	A2 Hallway By A222	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:55
26	W01A-08 1072 (DF) R	SUES	A2 Hallway By A222	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:56

*Phillip Rankine*

*Phillip Rankine*  
 30183220814

70489