



Project: Frederick Co Schools

## Analytical Results

Project Number: Urbana Elementary School  
Client Name: TIDEWATER  
Project Manager: Meneka Rodrigo

Reported:  
14-Feb-22 15:56

### Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K17-01 1071 (IM)	E069668-01	C118/Kitchen	Lead	< 1.0	ug/L	2/11/2022 1:36:48PM	RAS
K17-03 1071 (IM)	E069668-02	Teachers Lounge Refrigerator	Lead	< 1.0	ug/L	2/11/2022 1:47:31PM	RAS
K17-04 1071 (IM)	E069668-03	Teachers Lounge Refrigerator	Lead	< 1.0	ug/L	2/11/2022 1:51:05PM	RAS
K31-01 1071 (KS)	E069668-04	C118/Kitchen	Lead	< 1.0	ug/L	2/11/2022 1:54:40PM	RAS
S23-100 1071 (TL)	E069668-05	A113/Teachers Lounge	Lead	< 1.0	ug/L	2/11/2022 1:58:15PM	RAS
S23-104 1071 (NO)	E069668-06	A102/Health Room	Lead	< 1.0	ug/L	2/11/2022 2:01:51PM	RAS
S23-105 1071 (NO)	E069668-07	A102A/Nurses Office	Lead	< 1.0	ug/L	2/11/2022 2:12:35PM	RAS
W01A-01 1071 (DF) L-RE069668-08		C133/Gym	Lead	< 1.0	ug/L	2/11/2022 2:16:11PM	RAS
W01A-01 1071 (DF) L-RE069668-09		C133/Gym	Lead	< 1.0	ug/L	2/11/2022 2:19:48PM	RAS
W01A-01 1071 (DF) L-RE069668-10		C133/Gym	Lead	< 1.0	ug/L	2/11/2022 2:23:20PM	RAS
W01A-02 1071 (DF) L-RE069668-11		By B109	Lead	< 1.0	ug/L	2/11/2022 2:26:52PM	RAS
W01A-02 1071 (DF) L-RE069668-12		By B109	Lead	< 1.0	ug/L	2/11/2022 2:37:32PM	RAS
W01A-03 1071 (DF) L-RE069668-13		By B221	Lead	< 1.0	ug/L	2/11/2022 2:41:05PM	RAS
W01A-03 1071 (DF) L-RE069668-14		By B221	Lead	< 1.0	ug/L	2/11/2022 2:44:39PM	RAS
W01A-04 1071 (DF) L-RE069668-15		By A227	Lead	< 1.0	ug/L	2/11/2022 2:55:22PM	RAS
W01A-04 1071 (DF) L-RE069668-16		By A227	Lead	< 1.0	ug/L	2/11/2022 2:58:57PM	RAS
W01A-05 1071 (DF) L-RE069668-17		By Door #1, A Wing Exit	Lead	< 1.0	ug/L	2/11/2022 3:06:07PM	RAS
W01A-05 1071 (DF) L-RE069668-18		By Door #1, A Wing Exit	Lead	< 1.0	ug/L	2/11/2022 3:09:42PM	RAS

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools

## Analytical Results

Project Number: Urbana Elementary School

Client Name: TIDEWATER

Project Manager: Meneka Rodrigo

Reported:

14-Feb-22 15:56

W01A-06 1071 (DF) L-RE069668-19	By C114	Lead	< 1.0	ug/L	2/11/2022	3:13:15PM	RAS
W01A-06 1071 (DF) L-RE069668-20	By C114	Lead	< 1.0	ug/L	2/11/2022	3:16:47PM	RAS
W01A-06 1071 (DF) L-RE069668-21	By C114	Lead	< 1.0	ug/L	2/11/2022	3:20:20PM	RAS
W01A-07 1071 (DF) L-RE069668-22	C116/Café	Lead	< 1.0	ug/L	2/11/2022	3:38:08PM	RAS
W01A-07 1071 (DF) L-RE069668-23	C116/Café	Lead	< 1.0	ug/L	2/11/2022	3:41:42PM	RAS
W01A-07 1071 (DF) L-RE069668-24	C116/Café	Lead	< 1.0	ug/L	2/11/2022	3:45:16PM	RAS

Stephen Shelley, Laboratory Director

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*



Project: Frederick Co Schools


## Analytical Results

Project Number: Urbana Elementary School  
Client Name: TIDEWATER  
Project Manager: Meneka Rodrigo

Reported:  
14-Feb-22 15:56

## Notes and Definitions

DET Analyte DETECTED  
ND Analyte NOT DETECTED at or above the reporting limit  
NR Not Reported  
dry Sample results reported on a dry weight basis  
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

SITE: URBANA ELEMENTARY SCHOOL 3554 URBANA PIKE, FREDERICK, MD 21704  
 SAMPLER'S NAME: DUREKA ALUWHARE

Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1 K17-01 1071 (IM)	UES	C118/Kitchen	7	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	February 10, 2022 9:10
2 K17-03 1071 (IM)	UES	Teachers Lounge Refrigerator	7	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	February 10, 2022 4:22
3 K17-04 1071 (IM)	UES	Teachers Lounge Refrigerator	7	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	February 10, 2022 4:22
4 K31-01 1071 (KS)	UES	C118/Kitchen	7	D2010.60 Plumbing Fixture (Kitchen Sink)	February 10, 2022 4:30
5 S23-100 1071 (TL)	UES	A113/Teachers Lounge	7	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 10, 2022 4:33
6 S23-104 1071 (NO)	UES	A102/Health Room	7	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 10, 2022 4:45
7 S23-105 1071 (NO)	UES	A102A/Nurses Office	7	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 10, 2022 4:45
8 W01A-01 1071 (DF) L-R-B (left)	UES	C133/Gym	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 10, 2022 4:50
9 W01A-01 1071 (DF) L-R-B (right)	UES	C133/Gym	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 10, 2022 4:52
10 W01A-01 1071 (DF) L-R-B (bottle filler)	UES	C133/Gym	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 10, 2022 4:53

69168

SITE: URBANA ELEMENTARY SCHOOL 3554 URBANA PIKE, FREDERICK, MD 21704  
 SAMPLER'S NAME: DUREKA ALUWIHARE

Name	Site	Area-Room number	Area	Category	Sampling Date and Time
11 ✓ W01A-02 1071 (DF) L-R(left)	UES	By B109	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 10, 2022 5:00
12 ✓ W01A-02 1071 (DF) L-R (right)	UES	By B109	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 10, 2022 5:02
13 ✓ W01A-03 1071 (DF) L-R (left)	UES	By B221	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 10, 2022 5:06
14 ✓ W01A-03 1071 (DF) L-R (right)	UES	By B221	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 10, 2022 5:07
15 ✓ W01A-04 1071 (DF) L-R (left)	UES	By A227	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 10, 2022 5:13
16 ✓ W01A-04 1071 (DF) L-R (right)	UES	By A227	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 10, 2022 5:14
17 ✓ W01A-05 1071 (DF) L-R (left)	UES	By Door #1, A Wing Exit	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 10, 2022 5:19
18 ✓ W01A-05 1071 (DF) L-R (right)	UES	By Door #1, A Wing Exit	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 10, 2022 5:20
19 ✓ W01A-06 1071 (DF) L-R-B (left)	UES	By C114	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 10, 2022 5:25
20 ✓ W01A-06 1071 (DF) L-R-B (right)	UES	By C114	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 10, 2022 5:27

SITE: URBANA ELEMENTARY SCHOOL 3554 URBANA PIKE, FREDERICK, MD 21704  
 SAMPLER'S NAME: DUREKA ALUWHARE

Name	Site	Area-Room number	Area	Category	Sampling Date and Time
21 ✓ W01A-06 1071 (DF) L-R-B (bottle filler)	UES	By C114	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 10, 2022 5:25
22 W01A-07 1071 (DF) L-R-B (left)	UES	C116/Café	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 10, 2022 5:31
23 W01A-07 1071 (DF) L-R-B (right)	UES	C116/Café	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 10, 2022 5:32
24 W01A-07 1071 (DF) L-R-B (bottle filler)	UES	C116/Café	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 10, 2022 5:33

*Handwritten signature*  
 2/10/22 OSIS