



Project: Frederick Co Schools

Analytical Results

Project Number: Centerville ES
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
24-Jan-22 16:22

Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K31-03 1083 (KS) Test FE069478-01		Kitchen By Walk-In Boxes	Lead	4.3	ug/L	1/21/2022 12:15:55PM	RAS
S23-04 1082 (NO) Test FE069478-02		Room 114A	Lead	< 1.0	ug/L	1/21/2022 12:27:18PM	RAS
S23-39 1082 (TL) Test PE069478-03		Room 131	Lead	< 1.0	ug/L	1/21/2022 12:31:06PM	RAS
W01A-01 1082 (DF) TesE069478-04		100 Hallway by Group Bathrooms	Lead	< 1.0	ug/L	1/21/2022 12:34:54PM	RAS
W01A-02 1082 (DF) TesE069478-05		100 Hallway by Group Bathrooms	Lead	< 1.0	ug/L	1/21/2022 12:38:43PM	RAS
W01A-02 1082 (DF) TesE069478-06		101 Hallway by Group Bathrooms	Lead	< 1.0	ug/L	1/21/2022 12:42:32PM	RAS
W01A-03 1082 (DF) TesE069478-07		100 Hallway by Room 226	Lead	< 1.0	ug/L	1/21/2022 12:54:00PM	RAS
W01A-04 1082 (DF) TesE069478-08		100 Hallway by Room 226	Lead	< 1.0	ug/L	1/21/2022 12:57:50PM	RAS
W01A-05 1082 (DF) TesE069478-09		300 Hallway	Lead	< 1.0	ug/L	1/21/2022 1:01:39PM	RAS
W01A-06 1082 (DF) TesE069478-10		300 Hallway	Lead	< 1.0	ug/L	1/21/2022 1:05:30PM	RAS
W01A-07 1082 (DF) TesE069478-11		400 Hallway	Lead	< 1.0	ug/L	1/21/2022 1:16:55PM	RAS
W01A-08 1082 (DF) TesE069478-12		400 Hallway	Lead	< 1.0	ug/L	1/21/2022 1:20:43PM	RAS
W01A-08 1082 (DF) TesE069478-13		400 Hallway	Lead	< 1.0	ug/L	1/21/2022 1:24:31PM	RAS
W01A-09 1082 (DF) TesE069478-14		Gym by Office	Lead	< 1.0	ug/L	1/21/2022 1:28:19PM	RAS
W01A-10 1082 (DF) TesE069478-15		Gym by Office	Lead	< 1.0	ug/L	1/21/2022 1:43:36PM	RAS

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools


Analytical Results

Project Number: Centerville ES
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
24-Jan-22 16:22

Notes and Definitions

DET Analyte DETECTED
ND Analyte NOT DETECTED at or above the reporting limit
NR Not Reported
dry Sample results reported on a dry weight basis
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

SITE: CENTERVILLE ELEMENTARY SCHOOL 3601 CARRIAGE HIL DRIVE, FREDERICK, MD 21704
 NAME: CHRISTOPHER WILCOMBE

69478

Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1 K31-03 1083 (KS) Test Point	CES	Kitchen By Walk-In Boxes	7	D2010.60 Plumbing Fixture (Kitchen Sink)	January 20, 2022 4:55
2 S23-04 1082 (NO) Test Point	CES	Room 114A	7	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	January 20, 2022 4:57
3 S23-39 1082 (TL) Test Point	CES	Room 131	7	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	January 20, 2022 4:58
4 W01A-01 1082 (DF) Test Point	CES	100 Hallway by Group Bathrooms	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	January 20, 2022 5:03
5 W01A-02 1082 (DF) Test Point B (fountain)	CES	100 Hallway by Group Bathrooms	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	January 20, 2022 5:04
6 W01A-02 1082 (DF) Test Point B (bottle filler)	CES	101 Hallway by Group Bathrooms	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	January 20, 2022 5:05
7 W01A-03 1082 (DF) Test Point	CES	100 Hallway by Room 226	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	January 20, 2022 5:07
8 W01A-04 1082 (DF) Test Point	CES	100 Hallway by Room 226	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	January 20, 2022 5:08
9 W01A-05 1082 (DF) Test Point	CES	300 Hallway	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	January 20, 2022 5:11
10 W01A-06 1082 (DF) Test Point	CES	300 Hallway	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	January 20, 2022 5:13

SITE: CENTERVILLE ELEMENTARY SCHOOL 3601 CARRIAGE HIL DRIVE, FREDERICK, MD 21704
NAME: CHRISTOPHER WILLCOME

Name	Site	Area-Room number	Area	Category	Sampling Date and Time
11 W01A-07 1082 (DF) Test Point	CES	400 Hallway	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	January 20, 2022 <i>S116</i>
12 W01A-08 1082 (DF) Test Point B (fountain)	CES	400 Hallway	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	January 20, 2022 <i>S117</i>
13 W01A-08 1082 (DF) Test Point B (bottle filler)	CES	400 Hallway	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	January 20, 2022 <i>S117</i>
14 W01A-09 1082 (DF) Test Point	CES	Gym by Office	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	January 20, 2022 <i>S120</i>
15 W01A-10 1082 (DF) Test Point	CES	Gym by Office	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	January 20, 2022 <i>S121</i>