



Project: Frederick Co Schools

Analytical Results

Project Number: Carroll Manor Elementary
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
15-Mar-22 10:24

Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K17-02 1070 (IM)	E069999-01	Staff Lounge/ Room 158	Lead	< 1.0	ug/L	3/13/2022 2:13:07PM	SES
K31-01 1070 (KS)	E069999-02	Kitchen	Lead	< 1.0	ug/L	3/13/2022 2:16:41PM	SES
S23-39 1070 (TL)	E069999-03	Room 158	Lead	< 1.0	ug/L	3/13/2022 2:20:16PM	SES
S23-71 1070 (NO)	E069999-04	Health Room/Room 156	Lead	< 1.0	ug/L	3/13/2022 2:23:51PM	SES
W01A-01 1070 (DF)	E069999-05	Front Office Hallway	Lead	< 1.0	ug/L	3/13/2022 2:27:26PM	SES
W01A-02 1070 (DF)	E069999-06	Main Office Hallway	Lead	< 1.0	ug/L	3/13/2022 2:31:01PM	SES
W01A-03 1070 (DF) B (fE069999-07)		Hallway By Room 110	Lead	< 1.0	ug/L	3/13/2022 2:34:35PM	SES
W01A-03 1070 (DF) B (tE069999-08)		Hallway By Room 110	Lead	< 1.0	ug/L	3/13/2022 2:45:18PM	SES
W01A-04 1070 (DF)	E069999-09	Hallway By Room 117	Lead	< 1.0	ug/L	3/13/2022 2:52:25PM	SES
W01A-05 1070 (DF) B (fE069999-10)		Hallway By Room 137	Lead	< 1.0	ug/L	3/13/2022 3:03:06PM	SES
W01A-05 1070 (DF) B (tE069999-11)		Hallway By Room 137	Lead	< 1.0	ug/L	3/13/2022 3:06:40PM	SES
W01A-06 1070 (DF)	E069999-12	Gym	Lead	< 1.0	ug/L	3/13/2022 3:10:15PM	SES
W01A-07 1070 (DF)	E069999-13	Hallway By Room 219	Lead	< 1.0	ug/L	3/13/2022 3:13:50PM	SES
W01A-08 1070 (DF)	E069999-14	Hallway By Room 219	Lead	< 1.0	ug/L	3/13/2022 3:17:25PM	SES
W01A-09 1070 (DF)	E069999-15	Hallway By Room 219	Lead	< 1.0	ug/L	3/13/2022 3:28:10PM	SES
W01A-10 1070 (DF)	E069999-16	Hallway By Room 219	Lead	< 1.0	ug/L	3/13/2022 3:31:43PM	SES
W01A-11 1070 (DF)	E069999-17	Hallway Between Room 229-231	Lead	< 1.0	ug/L	3/13/2022 3:35:18PM	SES
W01A-12 1070 (DF)	E069999-18	Hallway Between Room 229-231	Lead	< 1.0	ug/L	3/13/2022 3:38:52PM	SES

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools


Analytical Results

Project Number: Carroll Manor Elementary
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
15-Mar-22 10:24

Notes and Definitions

DET Analyte DETECTED
ND Analyte NOT DETECTED at or above the reporting limit
NR Not Reported
dry Sample results reported on a dry weight basis
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

SITE: CARROLL MANOR ELEMENTARY SCHOOL 5624 Adamstown Road, Adamstown, MD 21710
 SAMPLER'S NAME: CHRISTOPHER WILCOMBE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1	K17-02 1070 (IM)	CMES	Staff Lounge/ Room 158	6	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	March 11, 2022 04:40
2	K31-01 1070 (KS)	CMES	Kitchen	6	D2010.60 Plumbing Fixture (Kitchen Sink)	March 11, 2022 04:42
3	S23-39 1070 (TL)	CMES	Room 158	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 11, 2022 04:48
4	S23-71 1070 (NO)	CMES	Health Room/Room 156	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 11, 2022 04:44
5	W01A-01 1070 (DF)	CMES	Front Office Hallway	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 11, 2022 04:46
6	W01A-02 1070 (DF)	CMES	Main Office Hallway	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 11, 2022 04:46
7	W01A-03 1070 (DF) B (fountain)	CMES	Hallway By Room 110	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 11, 2022 4:50
8	W01A-03 1070 (DF) B (bottle filler)	CMES	Hallway By Room 110	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 11, 2022 4:51
9	W01A-04 1070 (DF)	CMES	Hallway By Room 117	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 11, 2022 4:52
10	W01A-05 1070 (DF) B (fountain)	CMES	Hallway By Room 137	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 11, 2022 4:54
11	W01A-05 1070 (DF) B (bottle filler)	CMES	Hallway By Room 137	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 11, 2022 4:55

60299

69999

SITE: CARROLL MANOR ELEMENTARY SCHOOL 5624 Adamstown Road, Adamstown, MD 21710
SAMPLER'S NAME: CHRISTOPHER WILCOME

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
12	W01A-06 1070 (DF)	CMES	Gym	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 11, 2022 4:57
13	W01A-07 1070 (DF)	CMES	Hallway By Room 219	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 11, 2022 5:00
14	W01A-08 1070 (DF)	CMES	Hallway By Room 219	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 11, 2022 5:01
15	W01A-09 1070 (DF)	CMES	Hallway By Room 219	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 11, 2022 5:03
16	W01A-10 1070 (DF)	CMES	Hallway By Room 219	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 11, 2022 5:04
17	W01A-11 1070 (DF)	CMES	Hallway Between Room 229-231	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 11, 2022 5:05
18	W01A-12 1070 (DF)	CMES	Hallway Between Room 229-231	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 11, 2022 5:06