



Project: Frederick Co Schools

Analytical Results

Project Number: Deer Crossing Elementary
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
08-Apr-22 15:57

Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K17-01 1057 (IM)	E070235-01	Kitchen	Lead	< 1.0	ug/L	4/2/2022 3:58:25PM	SES
K31-01 1057 (KS)	E070235-02	Kitchen	Lead	5.2	ug/L	4/2/2022 4:01:59PM	SES
K31-02 1057 (KS)	E070235-03	Kitchen	Lead	< 1.0	ug/L	4/2/2022 4:05:34PM	SES
S23-90 1057 (TL)	E070235-04	Staff Lounge	Lead	< 1.0	ug/L	4/2/2022 4:09:09PM	SES
S23-96 1057 (NO)	E070235-05	Health Room	Lead	< 1.0	ug/L	4/2/2022 4:12:44PM	SES
W01A-01 1057 (DF)	E070235-06	Cafeteria	Lead	< 1.0	ug/L	4/2/2022 4:16:18PM	SES
W01A-01 1057 (DF) B	E070235-07	Cafeteria	Lead	< 1.0	ug/L	4/2/2022 4:27:00PM	SES
W01A-02 1057 (DF)	E070235-08	Cafeteria	Lead	< 1.0	ug/L	4/2/2022 4:34:07PM	SES
W01A-03 1057 (DF)	E070235-09	Main Entrance	Lead	< 1.0	ug/L	4/2/2022 4:44:49PM	SES
W01A-03 1057 (DF) B	E070235-10	Main Entrance	Lead	< 1.0	ug/L	4/2/2022 4:48:23PM	SES
W01A-04 1057 (DF)	E070235-11	Main Entrance	Lead	< 1.0	ug/L	4/2/2022 4:51:58PM	SES
W01A-04 1057 (DF) B	E070235-12	Main Entrance	Lead	< 1.0	ug/L	4/2/2022 4:55:33PM	SES
W01A-05 1057 (DF)	E070235-13	A Wing	Lead	< 1.0	ug/L	4/2/2022 4:59:08PM	SES
W01A-05 1057 (DF) B	E070235-14	A Wing	Lead	< 1.0	ug/L	4/2/2022 5:09:52PM	SES
W01A-06 1057 (DF)	E070235-15	A Wing	Lead	< 1.0	ug/L	4/2/2022 5:13:26PM	SES
W01A-06 1057 (DF) B	E070235-16	A Wing	Lead	< 1.0	ug/L	4/2/2022 5:17:00PM	SES
W01A-07 1057 (DF)	E070235-17	Gym	Lead	< 1.0	ug/L	4/2/2022 5:20:34PM	SES
W01A-08 1057 (DF) B	E070235-18	100 Hallway	Lead	< 1.0	ug/L	4/2/2022 5:24:08PM	SES

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools

Analytical Results

Project Number: Deer Crossing Elementary

Client Name: TIDEWATER

Project Manager: Meneka Rodrigo

Reported:

08-Apr-22 15:57

W01A-08 1057 (DF) B E070235-19	100 Hallway	Lead	< 1.0	ug/L	4/2/2022	5:34:50PM	SES
W01A-09 1057 (DF) B E070235-20	200 Hallway	Lead	< 1.0	ug/L	4/2/2022	5:38:24PM	SES
W01A-09 1057 (DF) B E070235-21	200 Hallway	Lead	< 1.0	ug/L	4/2/2022	5:41:59PM	SES

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools


Analytical Results

Project Number: Deer Crossing Elementary
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
08-Apr-22 15:57

Notes and Definitions

DET Analyte DETECTED
ND Analyte NOT DETECTED at or above the reporting limit
NR Not Reported
dry Sample results reported on a dry weight basis
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

SITE: DEER CROSSING ELEMENTARY SCHOOL 10601 Finn Drive, New Market, MD 21774
 SAMPLER'S NAME: Dureka Aluwihare

70235

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1	K17-01 1057 (IM)	DCES	Kitchen	8	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	April 1, 2022 4:55
2	K31-01 1057 (KS)	DCES	Kitchen	8	D2010.60 Plumbing Fixture (Kitchen Sink)	April 1, 2022 4:56
3	K31-02 1057 (KS)	DCES	Kitchen	8	D2010.60 Plumbing Fixture (Kitchen Sink)	April 1, 2022 4:56
4	S23-90 1057 (TL)	DCES	Staff Lounge	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 1, 2022 5:00
5	S23-96 1057 (NO)	DCES	Health Room	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 1, 2022 5:02
6	W01A-01 1057 (DF)	DCES	Cafeteria	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 1, 2022 5:08
7	W01A-01 1057 (DF) B	DCES	Cafeteria	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 1, 2022 5:08
8	W01A-02 1057 (DF)	DCES	Cafeteria	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 1, 2022 5:08
9	W01A-03 1057 (DF)	DCES	Main Entrance	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 1, 2022 5:12
10	W01A-03 1057 (DF) B	DCES	Main Entrance	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 1, 2022 5:12
11	W01A-04 1057 (DF)	DCES	Main Entrance	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 1, 2022 5:2

SITE: DEER CROSSING ELEMENTARY SCHOOL 10601 Finn Drive, New Market, MD 21774
 SAMPLER'S NAME: Dureka Aluwihare

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
12 ✓	W01A-04 1057 (DF) B	DCES	Main Entrance	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 1, 2022 5:12
13 ✓	W01A-05 1057 (DF)	DCES	A Wing	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 1, 2022 5:25
14 ✓	W01A-05 1057 (DF) B	DCES	A Wing	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 1, 2022 5:25
15 ✓	W01A-06 1057 (DF)	DCES	A Wing	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 1, 2022 5:25
16 ✓	W01A-06 1057 (DF) B	DCES	A Wing	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 1, 2022 5:25
17 ✓	W01A-07 1057 (DF)	DCES	Gym	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 1, 2022 5:28
18 ✓	W01A-08 1057 (DF) B	DCES	100 Hallway	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 1, 2022 5:30
19 ✓	W01A-08 1057 (DF) B	DCES	100 Hallway	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 1, 2022 5:30
20 ✓	W01A-09 1057 (DF) B	DCES	200 Hallway	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 1, 2022 5:25
21 ✓	W01A-09 1057 (DF) B	DCES	200 Hallway	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 1, 2022 5:25