



Project: Frederick Co Schools

## Analytical Results

Project Number: Gov Thos Johnson Middle School  
 Client Name: TIDEWATER  
 Project Manager: Meneka Rodrigo

Reported:  
 10-Mar-22 15:40

### Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K17-01 2027 (IM)	E069948-01	Kitchen	Lead	< 1.0	ug/L	3/9/2022 12:15:11PM	MAP
K17-04 2027 (IM)	E069948-02	Room 236/Home-Ec	Lead	< 1.0	ug/L	3/9/2022 12:33:00PM	MAP
K17-05 2027 (IM)	E069948-03	Room 236/Home-Ec	Lead	< 1.0	ug/L	3/9/2022 12:36:34PM	MAP
K17-06 2027 (IM)	E069948-04	Room 236/Home-Ec	Lead	< 1.0	ug/L	3/9/2022 12:40:08PM	MAP
K17-07 2027 (IM)	E069948-05	Room 236/Home-Ec	Lead	< 1.0	ug/L	3/9/2022 12:43:43PM	MAP
K17-08 2027 (IM)	E069948-06	Room 236/Home-Ec	Lead	< 1.0	ug/L	3/9/2022 12:47:17PM	MAP
K17-10 2027 (IM)	E069948-07	Faculty Lounge	Lead	< 1.0	ug/L	3/9/2022 12:50:52PM	MAP
K31-02 2027 (KS)	E069948-08	Kitchen	Lead	1.2	ug/L	3/9/2022 12:54:27PM	MAP
K31-05 2027 (KS)	E069948-09	Kitchen	Lead	1.1	ug/L	3/9/2022 12:58:01PM	MAP
K31-06 2027 (KS)	E069948-10	Kitchen	Lead	3.0	ug/L	3/9/2022 1:08:43PM	MAP
S23-016 2027 (NO)	E069948-11	Room 160/Nurses Office	Lead	< 1.0	ug/L	3/9/2022 1:12:17PM	MAP
S23-021 2027 ((TL)	E069948-12	Room 158/Teachers Lounge	Lead	< 1.0	ug/L	3/9/2022 1:22:57PM	MAP
S23-185 2027 (HE)	E069948-13	Room 236/Home-Ec	Lead	< 1.0	ug/L	3/9/2022 1:26:31PM	MAP
S23-186 2027 (HE)	E069948-14	Room 236/Home-Ec	Lead	< 1.0	ug/L	3/9/2022 1:30:05PM	MAP
S23-187 2027 (HE)	E069948-15	Room 236/Home-Ec	Lead	< 1.0	ug/L	3/9/2022 1:33:40PM	MAP
S23-188 2027 (HE)	E069948-16	Room 236/Home-Ec	Lead	< 1.0	ug/L	3/9/2022 1:37:15PM	MAP
S23-189 2027 (HE)	E069948-17	Room 236/Home-Ec	Lead	1.7	ug/L	3/9/2022 1:40:51PM	MAP
S23-190 2027 (HE)	E069948-18	Room 236/Home-Ec	Lead	< 1.0	ug/L	3/9/2022 1:51:35PM	MAP

Stephen Shelley, Laboratory Director

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*



Project: Frederick Co Schools

## Analytical Results

Project Number: Gov Thos Johnson Middle School  
 Client Name: TIDEWATER  
 Project Manager: Meneka Rodrigo

Reported:  
 10-Mar-22 15:40

W01A-01 2027 (DF) L	E069948-19	Cafeteria	Lead	< 1.0	ug/L	3/9/2022	1:55:09PM	MAP
W01A-01 2027 (DF) R	E069948-20	Cafeteria	Lead	< 1.0	ug/L	3/9/2022	1:58:42PM	MAP
W01A-02 2027 (DF) L	E069948-21	By Room 161	Lead	< 1.0	ug/L	3/9/2022	2:05:50PM	MAP
W01A-02 2027 (DF) R	E069948-22	By Room 161	Lead	< 1.0	ug/L	3/9/2022	2:16:32PM	MAP
W01A-02 2027 (DF) B	E069948-23	By Room 161	Lead	< 1.0	ug/L	3/9/2022	2:20:06PM	MAP
W01A-03 2027 (DF) L	E069948-24	By Room 159	Lead	< 1.0	ug/L	3/9/2022	2:23:41PM	MAP
W01A-03 2027 (DF) R	E069948-25	By Room 159	Lead	< 1.0	ug/L	3/9/2022	2:34:25PM	MAP
W01A-04 2027 (DF) L	E069948-26	By Room 137	Lead	< 1.0	ug/L	3/9/2022	2:38:01PM	MAP
W01A-04 2027 (DF) R	E069948-27	By Room 137	Lead	< 1.0	ug/L	3/9/2022	2:41:36PM	MAP
W01A-04 2027 (DF) B	E069948-28	By Room 137	Lead	< 1.0	ug/L	3/9/2022	2:45:10PM	MAP
W01A-05 2027 (DF) L	E069948-29	By Room 110	Lead	< 1.0	ug/L	3/9/2022	2:48:45PM	MAP
W01A-05 2027 (DF) R	E069948-30	By Room 110	Lead	< 1.0	ug/L	3/9/2022	2:52:19PM	MAP
W01A-06 2027 (DF) L	E069948-31	By Room 120	Lead	< 1.0	ug/L	3/9/2022	2:55:53PM	MAP
W01A-06 2027 (DF) R	E069948-32	By Room 120	Lead	< 1.0	ug/L	3/9/2022	3:13:44PM	MAP
W01A-07 2027 (DF) L	E069948-33	By Room 130	Lead	< 1.0	ug/L	3/9/2022	3:17:19PM	MAP
W01A-07 2027 (DF) R	E069948-34	By Room 130	Lead	< 1.0	ug/L	3/9/2022	3:20:53PM	MAP
W01A-08 2027 (DF) L	E069948-35	Gym	Lead	< 1.0	ug/L	3/9/2022	3:24:28PM	MAP
W01A-08 2027 (DF) R	E069948-36	Gym	Lead	< 1.0	ug/L	3/9/2022	3:28:03PM	MAP
W01A-09 2027 (DF) L	E069948-37	Girl's Locker Room	Lead	< 1.0	ug/L	3/9/2022	3:31:39PM	MAP
W01A-09 2027 (DF) R	E069948-38	Girl's Locker Room	Lead	< 1.0	ug/L	3/9/2022	3:35:14PM	MAP
W01A-10 2027 (DF) L	E069948-39	Boy's Locker Room	Lead	< 1.0	ug/L	3/9/2022	3:38:48PM	MAP

Stephen Shelley, Laboratory Director

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*



Project: Frederick Co Schools

## Analytical Results

Project Number: Gov Thos Johnson Middle School

Client Name: TIDEWATER

Project Manager: Meneka Rodrigo

Reported:

10-Mar-22 15:40

W01A-10 2027 (DF) R	E069948-40	Boy's Locker Room	Lead	< 1.0	ug/L	3/9/2022	3:42:23PM	MAP
W01A-11 2027 (DF) L	E069948-41	By Room 210	Lead	< 1.0	ug/L	3/9/2022	3:49:32PM	MAP
W01A-11 2027 (DF) R	E069948-42	By Room 210	Lead	< 1.0	ug/L	3/9/2022	4:07:25PM	MAP
W01A-12 2027 (DF) L	E069948-43	By Room 220	Lead	< 1.0	ug/L	3/9/2022	4:11:00PM	MAP
W01A-12 2027 (DF) R	E069948-44	By Room 220	Lead	< 1.0	ug/L	3/9/2022	4:14:35PM	MAP
W01A-12 2027 (DF) B	E069948-45	By Room 220	Lead	< 1.0	ug/L	3/9/2022	4:18:10PM	MAP
W01A-13 2027 (DF) L	E069948-46	By Room 230	Lead	< 1.0	ug/L	3/9/2022	4:21:46PM	MAP
W01A-13 2027 (DF) R	E069948-47	By Room 230	Lead	< 1.0	ug/L	3/9/2022	4:25:21PM	MAP

Stephen Shelley, Laboratory Director

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*



Project: Frederick Co Schools


## Analytical Results

Project Number: Gov Thos Johnson Middle School  
Client Name: TIDEWATER  
Project Manager: Meneka Rodrigo

Reported:  
10-Mar-22 15:40

## Notes and Definitions

DET Analyte DETECTED  
ND Analyte NOT DETECTED at or above the reporting limit  
NR Not Reported  
dry Sample results reported on a dry weight basis  
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

SITE: GOVERNOR THOMAS JOHNSON MIDDLE SCHOOL

1799 Schifferstadt Blvd, Frederick, MD 21701

SAMPLER'S NAME: PHILLIP RANKINE

69948

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1	K17-01 2027 (IM)	GTJMS	Kitchen	5	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	March 8, 2022 4:10
2	K17-04 2027 (IM)	GTJMS	Room 236/Home-Ec	5	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	March 8, 2022 4:08
3	K17-05 2027 (IM)	GTJMS	Room 236/Home-Ec	5	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	March 8, 2022 4:10
4	K17-06 2027 (IM)	GTJMS	Room 236/Home-Ec	5	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	March 8, 2022 4:12
5	K17-07 2027 (IM)	GTJMS	Room 236/Home-Ec	5	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	March 8, 2022 4:13
6	K17-08 2027 (IM)	GTJMS	Room 236/Home-Ec	5	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	March 8, 2022 4:14
7	K17-10 2027 (IM)	GTJMS	Faculty Lounge	5	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	March 8, 2022 4:15
8	K31-02 2027 (KS)	GTJMS	Kitchen	5	D2010.60 Plumbing Fixture (Kitchen Sink)	March 8, 2022 4:10
9	K31-05 2027 (KS)	GTJMS	Kitchen	5	D2010.60 Plumbing Fixture (Kitchen Sink)	March 8, 2022 4:13
10	K31-06 2027 (KS)	GTJMS	Kitchen	5	D2010.60 Plumbing Fixture (Kitchen Sink)	March 8, 2022 4:38

**SITE: GOVERNOR THOMAS JOHNSON MIDDLE SCHOOL      1799 Schifferstadt Blvd, Frederick, MD 21701**  
**SAMPLER'S NAME: PHILLIP RANKINE**

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
11	S23-016 2027 (NO)	GTJMS	Room 160/Nurses Office	5	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 8, 2022 5:18
12	S23-021 2027 (TL)	GTJMS	Room 158/Teachers Lounge	5	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 8, 2022 5:16
13	S23-185 2027 (HE)	GTJMS	Room 236/Home-Ec	5	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 8, 2022 4:17
14	S23-186 2027 (HE)	GTJMS	Room 236/Home-Ec	5	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 8, 2022 4:32
15	S23-187 2027 (HE)	GTJMS	Room 236/Home-Ec	5	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 8, 2022 4:32
16	S23-188 2027 (HE)	GTJMS	Room 236/Home-Ec	5	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 8, 2022 4:31
17	S23-189 2027 (HE)	GTJMS	Room 236/Home-Ec	5	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 8, 2022 4:30
18	S23-190 2027 (HE)	GTJMS	Room 236/Home-Ec	5	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 8, 2022 4:29
19	W01A-01 2027 (DF) L	GTJMS	Cafeteria	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 4:48
20	W01A-01 2027 (DF) R	GTJMS	Cafeteria	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 4:45

**SITE: GOVERNOR THOMAS JOHNSON MIDDLE SCHOOL      1799 Schifferstadt Blvd, Frederick, MD 21701**  
**SAMPLER'S NAME: PHILLIP RANKINE**

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
21	W01A-02 2027 (DF) L	GTJMS	By Room 161	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 <i>CR 41</i>
22	W01A-02 2027 (DF) R	GTJMS	By Room 161	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 <i>4:47</i>
23	W01A-02 2027 (DF) B	GTJMS	By Room 161	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 <i>4:48</i>
24	W01A-03 2027 (DF) L	GTJMS	By Room 159	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 <i>4:50</i>
25	W01A-03 2027 (DF) R	GTJMS	By Room 159	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 <i>4:52</i>
26	W01A-04 2027 (DF) L	GTJMS	By Room 137	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 <i>4:55</i>
27	W01A-04 2027 (DF) R	GTJMS	By Room 137	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 <i>4:56</i>
28	W01A-04 2027 (DF) B	GTJMS	By Room 137	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 <i>4:57</i>
29	W01A-05 2027 (DF) L	GTJMS	By Room 110	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 <i>4:59</i>
30	W01A-05 2027 (DF) R	GTJMS	By Room 110	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 <i>8:00</i>


SITE: GOVERNOR THOMAS JOHNSON MIDDLE SCHOOL      1799 Schifferstadt Blvd, Frederick, MD 21701  
 SAMPLER'S NAME: PHILLIP RANKINE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
31	W01A-06 2027 (DF) L	GTJMS	By Room 120	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 <i>5:09</i>
32	W01A-06 2027 (DF) R	GTJMS	By Room 120	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 <i>5:02</i>
33	W01A-07 2027 (DF) L	GTJMS	By Room 130	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 <i>5:02</i>
34	W01A-07 2027 (DF) R	GTJMS	By Room 130	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 <i>5:04</i>
35	W01A-08 2027 (DF) L	GTJMS	Gym	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 <i>5:06</i>
36	W01A-08 2027 (DF) R	GTJMS	Gym	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 <i>5:08</i>
37	W01A-09 2027 (DF) L	GTJMS	Girl's Locker Room	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 <i>5:10</i>
38	W01A-09 2027 (DF) R	GTJMS	Girl's Locker Room	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 <i>5:11</i>
39	W01A-10 2027 (DF) L	GTJMS	Boy's Locker Room	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 <i>5:13</i>
40	W01A-10 2027 (DF) R	GTJMS	Boy's Locker Room	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 <i>5:14</i>



**SITE: GOVERNOR THOMAS JOHNSON MIDDLE SCHOOL      1799 Schifferstadt Blvd, Frederick, MD 21701**  
**SAMPLER'S NAME: PHILLIP RANKINE**

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
41	W01A-11 2027 (DF) L	GTJMS	By Room 210	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain) L	March 8, 2022  4:18
42	W01A-11 2027 (DF) R	GTJMS	By Room 210	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain) R	March 8, 2022  4:19
43	W01A-12 2027 (DF) L	GTJMS	By Room 220	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022  4:21
44	W01A-12 2027 (DF) R	GTJMS	By Room 220	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022  4:22
45	W01A-12 2027 (DF) B	GTJMS	By Room 220	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022  4:22
46	W01A-13 2027 (DF) L	GTJMS	By Room 230	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022  4:24
47	W01A-13 2027 (DF) R	GTJMS	By Room 230	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022  4:25

  
 Phillip Rankine  
 301 332 0044