



Project: Frederick Co Schools

## Analytical Results

Project Number: Heather Ridge School

Client Name: TIDEWATER

Project Manager: Meneka Rodrigo

Reported:

01-Mar-22 12:05

### Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K31-01 3008 (KS) L	E069831-01	Kitchen	Lead	< 1.0	ug/L	2/28/2022 10:37:18AM	MAP
K31-01 3008 (KS) R	E069831-02	Kitchen	Lead	< 1.0	ug/L	2/28/2022 10:48:03AM	MAP
S23-10 3008 (HE)	E069831-03	Media - See Map	Lead	< 1.0	ug/L	2/28/2022 10:51:38AM	MAP
S23-19 3008 (NO)	E069831-04	Health Room Restroom - See Map	Lead	1.0	ug/L	2/28/2022 10:55:14AM	MAP
S23-22 3008 (TL)	E069831-05	Staff Lounge - See Map	Lead	< 1.0	ug/L	2/28/2022 11:05:59AM	MAP
W01A-01 3008 (DF) L	E069831-06	Lower Hallway	Lead	< 1.0	ug/L	2/28/2022 11:09:35AM	MAP
W01A-01 3008 (DF) R	E069831-07	Lower Hallway	Lead	< 1.0	ug/L	2/28/2022 11:13:11AM	MAP
W01A-01 3008 (DF) B	E069831-08	Lower Hallway	Lead	< 1.0	ug/L	2/28/2022 11:16:44AM	MAP
W01A-02 3008 (DF)	E069831-09	Tech Ed	Lead	< 1.0	ug/L	2/28/2022 11:20:17AM	MAP
W01A-03 3008 (DF)	E069831-10	Gym Boy's Locker	Lead	< 1.0	ug/L	2/28/2022 11:23:49AM	MAP
W01A-04 3008 (DF)	E069831-11	Gym Girl's Locker	Lead	< 1.0	ug/L	2/28/2022 11:27:23AM	MAP
W01A-05 3008 (DF)	E069831-12	Hallway By Office	Lead	< 1.0	ug/L	2/28/2022 11:38:04AM	MAP
W01A-05 3008 (DF) B	E069831-13	Hallway By Office	Lead	< 1.0	ug/L	2/28/2022 11:48:48AM	MAP
W01A-06 3008 (DF)	E069831-14	C Pod Hallway	Lead	< 1.0	ug/L	2/28/2022 11:52:22AM	MAP
W01A-06 3008 (DF) B	E069831-15	C Pod Hallway	Lead	< 1.0	ug/L	2/28/2022 11:55:57AM	MAP
W01A-07 3008 (DF)	E069831-16	D Pod Hallway	Lead	< 1.0	ug/L	2/28/2022 11:59:32AM	MAP
W01A-07 3008 (DF) B	E069831-17	D Pod Hallway	Lead	< 1.0	ug/L	2/28/2022 12:03:08PM	MAP
W01B-01 3008 (DF)	E069831-18	Gym	Lead	< 1.0	ug/L	2/28/2022 12:06:41PM	MAP

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools


## Analytical Results

Project Number: Heather Ridge School  
Client Name: TIDEWATER  
Project Manager: Meneka Rodrigo

Reported:  
01-Mar-22 12:05

## Notes and Definitions

DET Analyte DETECTED  
ND Analyte NOT DETECTED at or above the reporting limit  
NR Not Reported  
dry Sample results reported on a dry weight basis  
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

SITE: HEATHER RIDGE SCHOOL 1445 TANNEY AVENUE #4311, FREDERICK, MD 21702  
 NAME: PHILLIP RANKINE

Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1 K31-01 3008 (KS) L	HRS	Kitchen	4	D2010.60 Plumbing Fixture (Kitchen Sink)	February 25, 2022 4:45
2 K31-01 3008 (KS) R	HRS	Kitchen	4	D2010.60 Plumbing Fixture (Kitchen Sink)	February 25, 2022 4:47
3 S23-10 3008 (HE)	HRS	Media - See Map	4	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 25, 2022 4:36
4 S23-19 3008 (NO)	HRS	Health Room Restroom - See Map	4	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 25, 2022 4:09
5 S23-22 3008 (TL)	HRS	Staff Lounge - See Map	4	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 25, 2022 4:12
6 W01A-01 3008 (DF) L	HRS	Lower Hallway	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 25, 2022 <del>4:38</del> 4:38
7 W01A-01 3008 (DF) R	HRS	Lower Hallway	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 25, 2022 4:29
8 W01A-01 3008 (DF) B	HRS	Lower Hallway	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 25, 2022 4:40
9 W01A-02 3008 (DF)	HRS	Tech Ed	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 25, 2022 4:42

69831

SITE: HEATHER RIDGE SCHOOL 1445 TANAY AVENUE #4311, FREDERICK, MD 21702  
 NAME: PHILLIP RANKINE

Name	Site	Area-Room number	Area	Category	Sampling Date and Time
10 W01A-03 3008 (DF)	HRS	Gym Boy's Locker	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 25, 2022 4:32
11 W01A-04 3008 (DF)	HRS	Gym Girl's Locker	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 25, 2022 4:30
12 W01A-05 3008 (DF)	HRS	Hallway By Office	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 25, 2022 4:20
13 W01A-05 3008 (DF) B	HRS	Hallway By Office	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 25, 2022 4:22
14 W01A-06 3008 (DF)	HRS	C Pod Hallway	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 25, 2022 4:14
15 W01A-06 3008 (DF) B	HRS	C Pod Hallway	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 25, 2022 4:15
16 W01A-07 3008 (DF)	HRS	D Pod Hallway	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 25, 2022 4:17
17 W01A-07 3008 (DF) B	HRS	D Pod Hallway	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 25, 2022 4:18
18 W01B-01 3008 (DF)	HRS	Gym	4	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	February 25, 2022 4:26

*Phillip Rankine*  
 Rankine  
 Phillip Rankine

(IH)

301 3329094

601831