



Project: Frederick Co Schools

## Analytical Results

Project Number: Lincoln Elementary School  
Client Name: TIDEWATER  
Project Manager: Meneka Rodrigo

Reported:  
07-Apr-22 14:18

### Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K17-01 1004 (IM)	E070252-01	Kitchen	Lead	< 1.0	ug/L	4/6/2022 10:03:33AM	MAP
K31-02 1004 (KS)	E070252-02	Kitchen	Lead	< 1.0	ug/L	4/6/2022 10:14:15AM	MAP
K31-03 1004 (KS)	E070252-03	Kitchen	Lead	< 1.0	ug/L	4/6/2022 10:17:50AM	MAP
S23-015 1004 (NO)	E070252-04	Room 106	Lead	2.3	ug/L	4/6/2022 10:21:25AM	MAP
S23-016 1004 (NO)	E070252-05	Room 106D	Lead	2.0	ug/L	4/6/2022 10:25:00AM	MAP
S23-022 1004 (TL)	E070252-06	Room 112 Lounge	Lead	< 1.0	ug/L	4/6/2022 10:28:36AM	MAP
W01A-01 1004 (DF)	E070252-07	By Parks And Rec Office	Lead	< 1.0	ug/L	4/6/2022 10:39:21AM	MAP
W01A-02 1004 (DF)	E070252-08	By Parks And Rec Office	Lead	< 1.0	ug/L	4/6/2022 10:42:57AM	MAP
W01A-03 1004 (DF)	E070252-09	Cafeteria Hallway	Lead	< 1.0	ug/L	4/6/2022 10:46:33AM	MAP
W01A-04 1004 (DF) B (fE070252-10)		Cafeteria Hallway	Lead	< 1.0	ug/L	4/6/2022 10:50:05AM	MAP
W01A-04 1004 (DF) B (tE070252-11)		Cafeteria Hallway	Lead	< 1.0	ug/L	4/6/2022 10:53:37AM	MAP
W01A-05 1004 (DF) B (fE070252-12)		Entrance By Pre K Hallway	Lead	< 1.0	ug/L	4/6/2022 11:04:17AM	MAP
W01A-05 1004 (DF) B (tE070252-13)		Entrance By Pre K Hallway	Lead	< 1.0	ug/L	4/6/2022 11:07:51AM	MAP
W01A-06 1004 (DF)	E070252-14	Entrance By Pre K Hallway	Lead	< 1.0	ug/L	4/6/2022 11:11:24AM	MAP
W01A-07 1004 (DF)	E070252-15	By Room 219	Lead	< 1.0	ug/L	4/6/2022 11:22:07AM	MAP
W01A-08 1004 (DF)	E070252-16	By Room 219	Lead	< 1.0	ug/L	4/6/2022 11:25:42AM	MAP
W01B-01 1004 (DF)	E070252-17	Room 146	Lead	< 1.0	ug/L	4/6/2022 11:29:17AM	MAP
W01B-02 1004 (DF)	E070252-18	Room 111	Lead	178	ug/L	4/6/2022 4:55:01PM	MAP

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools

## Analytical Results

Project Number: Lincoln Elementary School  
 Client Name: TIDEWATER  
 Project Manager: Meneka Rodrigo

Reported:  
 07-Apr-22 14:18

W01B-03 1004 (DF)	E070252-19	Room 113	Lead	< 1.0	ug/L	4/6/2022	11:32:52AM	MAP
W01B-04 1004 (DF)	E070252-20	Room 114	Lead	< 1.0	ug/L	4/6/2022	11:36:27AM	MAP
W01B-05 1004 (DF)	E070252-21	Room 115	Lead	< 1.0	ug/L	4/6/2022	11:43:33AM	MAP
W01B-06 1004 (DF)	E070252-22	Room 116	Lead	48.9	ug/L	4/6/2022	5:16:30PM	MAP
W01B-07 1004 (DF)	E070252-23	Room 117	Lead	< 1.0	ug/L	4/6/2022	11:54:52AM	MAP
W01B-08 1004 (DF)	E070252-24	Room 118	Lead	< 1.0	ug/L	4/6/2022	12:05:34PM	MAP
W01B-09 1004 (DF)	E070252-25	Room 119	Lead	< 1.0	ug/L	4/6/2022	12:09:08PM	MAP
W01B-10 1004 (DF)	E070252-26	Room 120	Lead	< 1.0	ug/L	4/6/2022	12:12:43PM	MAP
W01B-11 1004 (DF)	E070252-27	Room 128	Lead	128	ug/L	4/6/2022	5:20:05PM	MAP
W01B-12 1004 (DF)	E070252-28	Room 129	Lead	110	ug/L	4/6/2022	5:23:40PM	MAP
W01B-13 1004 (DF)	E070252-29	Room 132	Lead	< 1.0	ug/L	4/6/2022	12:16:17PM	MAP
W01B-14 1004 (DF)	E070252-30	Room 134	Lead	102	ug/L	4/6/2022	5:27:15PM	MAP
W01B-15 1004 (DF)	E070252-31	Room 135	Lead	89.2	ug/L	4/6/2022	5:30:51PM	MAP
W01B-16 1004 (DF)	E070252-32	Room 138	Lead	76.7	ug/L	4/6/2022	5:34:26PM	MAP
W01B-17 1004 (DF)	E070252-33	Room 139	Lead	< 1.0	ug/L	4/6/2022	12:19:52PM	MAP
W01B-18 1004 (DF)	E070252-34	Room 204	Lead	< 1.0	ug/L	4/6/2022	12:30:35PM	MAP
W01B-19 1004 (DF)	E070252-35	Room 209	Lead	< 1.0	ug/L	4/6/2022	12:34:08PM	MAP
W01B-20 1004 (DF)	E070252-36	Room 210	Lead	< 1.0	ug/L	4/6/2022	12:37:41PM	MAP
W01B-21 1004 (DF)	E070252-37	Room 211	Lead	< 1.0	ug/L	4/6/2022	12:48:23PM	MAP
W01B-22 1004 (DF)	E070252-38	Room 212	Lead	< 1.0	ug/L	4/6/2022	5:38:02PM	MAP
W01B-23 1004 (DF)	E070252-39	Room 213	Lead	< 1.0	ug/L	4/6/2022	12:51:56PM	MAP

Stephen Shelley, Laboratory Director

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*



Project: Frederick Co Schools

## Analytical Results

Project Number: Lincoln Elementary School  
 Client Name: TIDEWATER  
 Project Manager: Meneka Rodrigo

Reported:  
 07-Apr-22 14:18

W01B-24 1004 (DF)	E070252-40	Room 214	Lead	< 1.0	ug/L	4/6/2022	12:55:30PM	MAP
W01B-25 1004 (DF)	E070252-41	Room 215	Lead	< 1.0	ug/L	4/6/2022	1:02:38PM	MAP
W01B-26 1004 (DF)	E070252-42	Room 216	Lead	< 1.0	ug/L	4/6/2022	1:13:22PM	MAP
W01B-27 1004 (DF)	E070252-43	Room 223	Lead	< 1.0	ug/L	4/6/2022	1:16:58PM	MAP
W01B-28 1004 (DF)	E070252-44	Room 224	Lead	< 1.0	ug/L	4/6/2022	5:48:46PM	MAP
W01B-29 1004 (DF)	E070252-45	Room 225	Lead	121	ug/L	4/6/2022	5:52:21PM	MAP
W01B-30 1004 (DF)	E070252-46	Room 226	Lead	< 1.0	ug/L	4/6/2022	1:20:31PM	MAP
W01B-31 1004 (DF)	E070252-47	Room 227	Lead	< 1.0	ug/L	4/6/2022	1:31:13PM	MAP
W01B-32 1004 (DF)	E070252-48	Room 231	Lead	< 1.0	ug/L	4/6/2022	1:34:47PM	MAP
W01B-33 1004 (DF)	E070252-49	Room 232	Lead	< 1.0	ug/L	4/6/2022	1:38:21PM	MAP
W01B-34 1004 (DF)	E070252-50	Room 233	Lead	< 1.0	ug/L	4/6/2022	1:41:54PM	MAP
W01B-35 1004 (DF)	E070252-51	Room 235	Lead	< 1.0	ug/L	4/6/2022	1:45:28PM	MAP
W01B-36 1004 (DF)	E070252-52	Room 236	Lead	< 1.0	ug/L	4/6/2022	1:49:02PM	MAP
W01B-37 1004 (DF)	E070252-53	Room 238	Lead	< 1.0	ug/L	4/6/2022	1:52:36PM	MAP
W01B-38 1004 (DF)	E070252-54	Room 221	Lead	< 1.0	ug/L	4/6/2022	1:56:11PM	MAP

Stephen Shelley, Laboratory Director

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*



Project: Frederick Co Schools


## Analytical Results

Project Number: Lincoln Elementary School  
Client Name: TIDEWATER  
Project Manager: Meneka Rodrigo

Reported:  
07-Apr-22 14:18

## Notes and Definitions

DET Analyte DETECTED  
ND Analyte NOT DETECTED at or above the reporting limit  
NR Not Reported  
dry Sample results reported on a dry weight basis  
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

SITE: LINCOLN ELEMENTARY SCHOOL 200 Madison Street, Frederick, MD 21701  
 SAMPLER'S NAME: Phillip Rankine

70252

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1	K17-01 1004 (IM)	LNES	Kitchen	6	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	April 1, 2022 4:09
2	K31-02 1004 (KS)	LNES	Kitchen	6	D2010.60 Plumbing Fixture (Kitchen Sink)	April 1, 2022 4:12
3	K31-03 1004 (KS)	LNES	Kitchen	6	D2010.60 Plumbing Fixture (Kitchen Sink)	April 1, 2022 4:10
4	S23-015 1004 (NO)	LNES	Room 106	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 1, 2022 4:12
5	S23-016 1004 (NO)	LNES	Room 106D	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 1, 2022 4:18
6	S23-022 1004 (TL)	LNES	Room 112 Lounge	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 1, 2022 4:20
7	W01A-01 1004 (DF)	LNES	By Parks And Rec Office	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 1, 2022 3:59
8	W01A-02 1004 (DF)	LNES	By Parks And Rec Office	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 1, 2022 4:07
9	W01A-03 1004 (DF)	LNES	Cafeteria Hallway	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 1, 2022 4:03
10	W01A-04 1004 (DF) B (fountain)	LNES	Cafeteria Hallway	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain) SHE GALE	April 1, 2022 4:05

SITE: LINCOLN ELEMENTARY SCHOOL 200 Madison Street, Frederick, MD 21701  
 SAMPLER'S NAME: Phillip Rankine

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
11	W01A-04 1004 (DF) B (bottle filler)	LNES	Cafeteria Hallway	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 1, 2022 4:06
12	W01A-05 1004 (DF) B (fountain)	LNES	Entrance By Pre K Hallway	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain) <i>Boiler Room</i>	April 1, 2022 4:22
13	W01A-05 1004 (DF) B (bottle filler)	LNES	Entrance By Pre K Hallway	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 1, 2022 4:23
14	W01A-06 1004 (DF)	LNES	Entrance By Pre K Hallway	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 1, 2022 4:21
15	W01A-07 1004 (DF)	LNES	By Room 219	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 1, 2022 4:20
16	W01A-08 1004 (DF)	LNES	By Room 219	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 1, 2022 4:21
17	W01B-01 1004 (DF)	LNES	Room 146	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 1, 2022 4:15
18	W01B-02 1004 (DF)	LNES	Room 111	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain) <i>new - and</i>	April 1, 2022 4:26
19	W01B-03 1004 (DF)	LNES	Room 113	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 1, 2022 4:31
20	W01B-04 1004 (DF)	LNES	Room 114	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 1, 2022 4:32

*PK*

SITE: LINCOLN ELEMENTARY SCHOOL    200 Madison Street, Frederick, MD 21701  
 SAMPLER'S NAME: Phillip Rankine

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
21	W01B-05 1004 (DF)	LNES	Room 115	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 1, 2022 <i>4:55</i>
22	W01B-06 1004 (DF)	LNES	Room 116	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 1, 2022 <i>4:32</i>
23	W01B-07 1004 (DF)	LNES	Room 117	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 1, 2022 <i>4:38</i>
24	W01B-08 1004 (DF)	LNES	Room 118	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 1, 2022 <i>4:30</i>
25	W01B-09 1004 (DF)	LNES	Room 119	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 1, 2022 <i>4:41</i>
26	W01B-10 1004 (DF)	LNES	Room 120	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 1, 2022 <i>4:48</i>
27	W01B-11 1004 (DF)	LNES	Room 128	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain) <i>AS per name.</i>	April 1, 2022 <i>4:45</i>
28	W01B-12 1004 (DF)	LNES	Room 129	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 1, 2022 <i>4:42</i>
29	W01B-13 1004 (DF)	LNES	Room 132	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 1, 2022 <i>4:48</i>
30	W01B-14 1004 (DF)	LNES	Room 134	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 1, 2022 <i>4:54</i>

SITE: LINCOLN ELEMENTARY SCHOOL 200 Madison Street, Frederick, MD 21701  
 SAMPLER'S NAME: Phillip Rankine

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
31	W01B-15 1004 (DF)	LNES	Room 135	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 1, 2022 4:22
32	W01B-16 1004 (DF)	LNES	Room 138	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 1, 2022 4:50
33	W01B-17 1004 (DF)	LNES	Room 139	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 1, 2022 4:55
34	W01B-18 1004 (DF)	LNES	Room 204	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 1, 2022 5:04
35	W01B-19 1004 (DF)	LNES	Room 209	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 1, 2022 5:06
36	W01B-20 1004 (DF)	LNES	Room 210	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 1, 2022 5:09
37	W01B-21 1004 (DF)	LNES	Room 211	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 1, 2022 5:11
38	W01B-22 1004 (DF)	LNES	Room 212 <i>standing drinker</i>	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 1, 2022 5:13
39	W01B-23 1004 (DF)	LNES	Room 213	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 1, 2022 5:15
40	W01B-24 1004 (DF)	LNES	Room 214	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 1, 2022 5:16




SITE: LINCOLN ELEMENTARY SCHOOL 200 Madison Street, Frederick, MD 21701  
 SAMPLER'S NAME: Phillip Rankine

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
41	W01B-25 1004 (DF)	LNES	Room 215	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 1, 2022 5:17
42	W01B-26 1004 (DF)	LNES	Room 216	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 1, 2022 5:18
43	W01B-27 1004 (DF)	LNES	Room 223	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 1, 2022 5:24
44	W01B-28 1004 (DF)	LNES	Room 224	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 1, 2022 5:26
45	W01B-29 1004 (DF)	LNES	Room 225	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 1, 2022 5:29
46	W01B-30 1004 (DF)	LNES	Room 226	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 1, 2022 5:29
47	W01B-31 1004 (DF)	LNES	Room 227	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 1, 2022 5:30
48	W01B-32 1004 (DF)	LNES	Room 231	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 1, 2022 5:34
49	W01B-33 1004 (DF)	LNES	Room 232	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 1, 2022 5:35
50	W01B-34 1004 (DF)	LNES	Room 233	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 1, 2022 5:47

SITE: LINCOLN ELEMENTARY SCHOOL 200 Madison Street, Frederick, MD 21701  
 SAMPLER'S NAME: Phillip Rankine

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
51	W01B-35 1004 (DF)	LNES	Room 235	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 1, 2022 5:35
52	W01B-36 1004 (DF)	LNES	Room 236	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 1, 2022 5:36
53	W01B-37 1004 (DF)	LNES	Room 238	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 1, 2022 5:42
54	W01B-38 1004 (DF)	LNES	Room 221	6	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 1, 2022 5:50

  
 Phillip Rankine

301 332 8084