



Project: Frederick Co Schools

Analytical Results

Project Number: Monocacy Elementary

Client Name: TIDEWATER

Project Manager: Meneka Rodrigo

Reported:

22-Mar-22 12:52

Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K31-02 1029 (KS)	E070086-01	Kitchen	Lead	< 1.0	ug/L	3/19/2022 12:00:51PM	SES
K31-03 1029 (KS)	E070086-02	Kitchen	Lead	1.9	ug/L	3/19/2022 12:04:26PM	SES
S23-15 1029 (NO)	E070086-03	Nurses Office	Lead	< 1.0	ug/L	3/19/2022 12:08:01PM	SES
S23-18 1029 (TL)	E070086-04	Teacher's Lounge/142	Lead	< 1.0	ug/L	3/19/2022 12:11:34PM	SES
Portable 159-09E13X15(E070086-05)	E070086-05	Portable 159-09E13X150T	Lead	< 1.0	ug/L	3/19/2022 12:18:39PM	SES
Portable 159-09E13X15(E070086-06)	E070086-06	Portable 159-09E13X150T	Lead	< 1.0	ug/L	3/19/2022 12:36:28PM	SES
Portable 159-09E13X15(E070086-07)	E070086-07	Portable 159-09E13X150T	Lead	< 1.0	ug/L	3/19/2022 12:40:02PM	SES
Portable 159-09E13X15(E070086-08)	E070086-08	Portable 159-09E13X150T	Lead	< 1.0	ug/L	3/19/2022 12:43:36PM	SES
W01A-01 1029 (DF)	E070086-09	Main Entrance	Lead	< 1.0	ug/L	3/19/2022 12:47:10PM	SES
W01A-01 1029 (DF) B	E070086-10	Main Entrance	Lead	< 1.0	ug/L	3/19/2022 12:50:44PM	SES
W01A-02 1029 (DF)	E070086-11	Main Entrance	Lead	< 1.0	ug/L	3/19/2022 12:54:19PM	SES
W01A-03 1029 (DF)	E070086-12	Next To Room 123-124	Lead	< 1.0	ug/L	3/19/2022 12:57:55PM	SES
W01A-04 1029 (DF)	E070086-13	Next To Room 123-124	Lead	< 1.0	ug/L	3/19/2022 1:01:28PM	SES
W01A-05 1029 (DF)	E070086-14	Next Room 102	Lead	< 1.0	ug/L	3/19/2022 1:05:00PM	SES
W01A-05 1029 (DF) B	E070086-15	Next Room 102	Lead	< 1.0	ug/L	3/19/2022 1:08:33PM	SES
W01A-06 1029 (DF)	E070086-16	Next Room 102	Lead	< 1.0	ug/L	3/19/2022 1:26:22PM	SES
W01A-07 1029 (DF)	E070086-17	Next Room 109	Lead	< 1.0	ug/L	3/19/2022 1:29:56PM	SES
W01A-08 1029 (DF)	E070086-18	Next Room 109	Lead	< 1.0	ug/L	3/19/2022 1:33:30PM	SES

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.




Project: Frederick Co Schools

Analytical Results

Project Number: Monocacy Elementary
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
22-Mar-22 12:52

W01A-09 1029 (DF)	E070086-19	Gym	Lead	< 1.0	ug/L	3/19/2022	1:37:04PM	SES
-------------------	------------	-----	------	-------	------	-----------	-----------	-----



Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools


Analytical Results

Project Number: Monocacy Elementary
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
22-Mar-22 12:52

Notes and Definitions

DET Analyte DETECTED
ND Analyte NOT DETECTED at or above the reporting limit
NR Not Reported
dry Sample results reported on a dry weight basis
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

SITE: MONOCACY ELEMENTARY SCHOOL 7421 Hayward Road, Frederick, MD 21702
 SAMPLER'S NAME: Christopher Wilcome

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1	K31-02 1029 (KS)	MOES	Kitchen	4	D2010.60 Plumbing Fixture (Kitchen Sink)	March 18, 2022 3:41
2	K31-03 1029 (KS)	MOES	Kitchen	4	D2010.60 Plumbing Fixture (Kitchen Sink)	March 18, 2022 3:41
3	S23-15 1029 (NO)	MOES	Nurses Office	4	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 18, 2022 3:48
4	S23-18 1029 (TL)	MOES	Teacher's Lounge/142	4	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 18, 2022 3:42
5	Portable 159-09E13X150T W01A-01 (DF) L	MOES	Portable 159-09E13X150T	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 18, 2022 4:02
6	Portable 159-09E13X150T W01A-01 (DF) R	MOES	Portable 159-09E13X150T	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 18, 2022 4:02
7	Portable 159-09E13X150T W01A-02 (DF)	MOES	Portable 159-09E13X150T	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 18, 2022 4:00
8	Portable 159-09E13X150T W01A-02 (DF) B	MOES	Portable 159-09E13X150T	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 18, 2022 4:00
9	W01A-01 1029 (DF)	MOES	Main Entrance	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 18, 2022 3:49
10	W01A-01 1029 (DF) B	MOES	Main Entrance	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 18, 2022 3:47
11	W01A-02 1029 (DF)	MOES	Main Entrance	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 18, 2022 3:46
12	W01A-03 1029 (DF)	MOES	Next To Room 123-124	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 18, 2022 3:52

20086

2084

SITE: MONOCACY ELEMENTARY SCHOOL 7421 Hayward Road, Frederick, MD 21702
SAMPLER'S NAME: Christopher Wilcome

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
13	W01A-04 1029 (DF)	MOES	Next To Room 123-124	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 18, 2022 3:51
14	W01A-05 1029 (DF)	MOES	Next Room 102	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 18, 2022 3:55
15	W01A-05 1029 (DF) B	MOES	Next Room 102	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 18, 2022 3:55
16	W01A-06 1029 (DF)	MOES	Next Room 102	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 18, 2022 3:54
17	W01A-07 1029 (DF)	MOES	Next Room 109	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 18, 2022 3:57
18	W01A-08 1029 (DF)	MOES	Next Room 109	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 18, 2022 3:57
19	W01A-09 1029 (DF)	MOES	Gym	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 18, 2022 3:48