



Project: Frederick Co Schools

## Analytical Results

Project Number: Middletown Primary School  
Client Name: TIDEWATER  
Project Manager: Meneka Rodrigo

Reported:  
11-Apr-22 10:49

### Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K17-01 1034 (IM)	E070297-01	Kitchen	Lead	< 1.0	ug/L	4/8/2022 3:16:04PM	RAS
K31-03 1034 (KS)	E070297-02	Main Kitchen	Lead	4.2	ug/L	4/8/2022 3:19:39PM	RAS
K31-04 1034 (KS)	E070297-03	Main Kitchen	Lead	3.1	ug/L	4/8/2022 3:23:13PM	RAS
S23-43 1034 (TL)	E070297-04	Room 174 Faculty Room	Lead	8.4	ug/L	4/8/2022 3:26:48PM	RAS
S23-51 1034 (NO)	E070297-05	Room 106 Health Room	Lead	7.8	ug/L	4/8/2022 3:33:59PM	RAS
W01A-01 1034 (DF)	E070297-06	Park & Rec Lobby	Lead	< 1.0	ug/L	4/8/2022 3:51:48PM	RAS
W01A-01 1034 (DF) B	E070297-07	Park & Rec Lobby	Lead	< 1.0	ug/L	4/8/2022 3:55:21PM	RAS
W01A-02 1034 (DF) L	E070297-08	Room 178	Lead	< 1.0	ug/L	4/8/2022 3:58:55PM	RAS
W01A-02 1034 (DF) R	E070297-09	Room 178	Lead	< 1.0	ug/L	4/8/2022 4:02:29PM	RAS
W01A-03 1034 (DF)	E070297-10	Hallway By Room 166	Lead	< 1.0	ug/L	4/8/2022 4:06:03PM	RAS
W01A-04 1034 (DF)	E070297-11	Hallway By Room 145	Lead	< 1.0	ug/L	4/8/2022 4:09:38PM	RAS
W01A-05 1034 (DF)	E070297-12	Hallway By Room 113	Lead	1.2	ug/L	4/8/2022 4:13:12PM	RAS
W01A-05 1034 (DF) B	E070297-13	Hallway By Room 113	Lead	1.3	ug/L	4/8/2022 4:16:47PM	RAS
W01A-06 1034 (DF)	E070297-14	Cafeteria	Lead	1.1	ug/L	4/8/2022 4:20:23PM	RAS

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools


## Analytical Results

Project Number: Middletown Primary School  
Client Name: TIDEWATER  
Project Manager: Meneka Rodrigo

Reported:  
11-Apr-22 10:49

## Notes and Definitions

DET Analyte DETECTED  
ND Analyte NOT DETECTED at or above the reporting limit  
NR Not Reported  
dry Sample results reported on a dry weight basis  
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

SITE: MIDDLETOWN PRIMARY SCHOOL      403 Franklin Street, Middletown, MD 21769  
 SAMPLER'S NAME: CHRISTOPHER WILLCOME

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1	K17-01 1034 (IM)	MPS	Kitchen	2	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	April 7, 2022 4:18
2	K31-03 1034 (KS)	MPS	Main Kitchen	2	D2010.60 Plumbing Fixture (Kitchen Sink)	April 7, 2022 4:16
3	K31-04 1034 (KS)	MPS	Main Kitchen	2	D2010.60 Plumbing Fixture (Kitchen Sink)	April 7, 2022 4:18
4	S23-43 1034 (TL)	MPS	Room 174 Faculty Room	2	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 7, 2022 4:29
5	S23-51 1034 (NO)	MPS	Room 106 Health Room	2	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 7, 2022 4:35
6	W01A-01 1034 (DF)	MPS	Park & Rec Lobby	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 7, 2022 4:21
7	W01A-01 1034 (DF) B	MPS	Park & Rec Lobby	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 7, 2022 4:21
8	W01A-02 1034 (DF) L	MPS	Room 178	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 7, 2022 4:27
9	W01A-02 1034 (DF) R	MPS	Room 178	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 7, 2022 4:27
10	W01A-03 1034 (DF)	MPS	Hallway By Room 166	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 7, 2022 4:32

2022

70297

SITE: MIDDLETOWN PRIMARY SCHOOL 403 Franklin Street, Middletown, MD 21769  
SAMPLER'S NAME: CHRISTOPHER WILCOMBE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
11	W01A-04 1034 (DF)	MPS	Hallway By Room 145	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 7, 2022 4:38
12	W01A-05 1034 (DF)	MPS	Hallway By Room 113	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 7, 2022 4:39
13	W01A-05 1034 (DF) B	MPS	Hallway By Room 113	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 7, 2022 4:41
14	W01A-06 1034 (DF)	MPS	Cafeteria	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 7, 2022 4:43

**Client:** Frederick County Public Schools  
ATTN: Accounts Payable 191 South East St  
Frederick, MD 21701

**Project:** Middletown Primary School  
April 2022

**Site:** Middletown Primary School  
403 Franklin Street  
Middletown, MD 21769

**Work order: FWD0289**

Received at lab: 04/12/22 11:01  
Date Reported: 04/13/22 16:19  
Collected by: Marc Angleberger, ID: 0659MA  
Treatment: N/A

**Source: S23-43-1034 TL**

(Drinking Water)(Grab - Flushed)

Collected: 4/12/2022 10:29:00AM

*Data Analyzed by: Fredericktowne Labs:*

Lab ID	Parameter	Result	Units	MRL	Prepared	Analyzed	Analyst	Qual	Method
FWD0289-01	Lead	<5	ppb	5	04/13/22 09:32	04/13/22 11:10	KMW		SM3113-B


**Source: S23-51-1034 NO**

(Drinking Water)(Grab - Flushed)

Collected: 4/12/2022 10:33:00AM

*Data Analyzed by: Fredericktowne Labs:*

Lab ID	Parameter	Result	Units	MRL	Prepared	Analyzed	Analyst	Qual	Method
FWD0289-02	Lead	<5	ppb	5	04/13/22 09:32	04/13/22 11:28	KMW		SM3113-B

  
Sara E. Randall, President

