



Project: Frederick Co Schools

## Analytical Results

Project Number: New Market Middle School

Client Name: TIDEWATER

Project Manager: Meneka Rodrigo

Reported:

03-May-22 10:49

### Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K17-01 2064 (IM)	E070490-01	Kitchen	Lead	< 1.0	ug/L	5/1/2022 3:15:10PM	SES
K31-02 2064 (KS)	E070490-02	Kitchen	Lead	6.1	ug/L	5/1/2022 3:18:46PM	SES
K31-04 2064 (KS)	E070490-03	Kitchen	Lead	5.1	ug/L	5/1/2022 3:22:19PM	SES
S23-014 2064 (HE)	E070490-04	Home Economics	Lead	4.2	ug/L	5/1/2022 3:25:52PM	SES
S23-015 2064 (HE)	E070490-05	Home Economics	Lead	4.3	ug/L	5/1/2022 3:29:25PM	SES
S23-016 2064 (HE)	E070490-06	Home Economics	Lead	6.5	ug/L	5/1/2022 3:47:15PM	SES
S23-017 2064 (HE)	E070490-07	Home Economics	Lead	4.6	ug/L	5/1/2022 3:50:48PM	SES
S23-018 2064 (HE)	E070490-08	Home Economics	Lead	38.6	ug/L	5/1/2022 3:54:23PM	SES
S23-019 2064 (HE)	E070490-09	Home Economics	Lead	5.3	ug/L	5/1/2022 3:57:57PM	SES
S23-020 2064 (HE)	E070490-10	Home Economics	Lead	7.2	ug/L	5/1/2022 4:01:32PM	SES
S23-033 2064 (NO)	E070490-11	Health Room	Lead	< 1.0	ug/L	5/1/2022 4:05:07PM	SES
S23-038 2064 (TL)	E070490-12	Staff Lounge	Lead	3.7	ug/L	5/1/2022 4:08:42PM	SES
W01A-01 2064 (DF)	E070490-13	Rear Entrance	Lead	5.1	ug/L	5/1/2022 4:12:16PM	SES
W01A-02 2064 (DF)	E070490-14	Outside Room 9	Lead	< 1.0	ug/L	5/1/2022 4:15:49PM	SES
W01A-03 2064 (DF)	E070490-15	Cafeteria	Lead	1.6	ug/L	5/1/2022 4:30:05PM	SES
W01A-03 2064 (DF) B	E070490-16	Cafeteria	Lead	1.9	ug/L	5/1/2022 4:40:46PM	SES
W01A-04 2064 (DF)	E070490-17	Cafeteria	Lead	1.7	ug/L	5/1/2022 4:44:20PM	SES
W01A-05 2064 (DF)	E070490-18	Cafeteria	Lead	< 1.0	ug/L	5/1/2022 4:47:55PM	SES

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools

## Analytical Results

Project Number: New Market Middle School  
 Client Name: TIDEWATER  
 Project Manager: Meneka Rodrigo

Reported:  
 03-May-22 10:49

W01A-06 2064 (DF)	E070490-19	By Elevator	Lead	1.6	ug/L	5/1/2022	4:51:30PM	SES
W01A-06 2064 (DF) B	E070490-20	By Elevator	Lead	1.8	ug/L	5/1/2022	4:55:05PM	SES
W01A-07 2064 (DF)	E070490-21	Boy's Locker Room	Lead	2.0	ug/L	5/1/2022	4:58:41PM	SES
W01A-08 2064 (DF)	E070490-22	Girl's Locker Room	Lead	1.7	ug/L	5/1/2022	5:02:15PM	SES
W01A-09 2064 (DF)	E070490-23	Hallway By Guidance	Lead	2.4	ug/L	5/1/2022	5:12:58PM	SES
W01A-09 2064 (DF) B	E070490-24	Hallway By Guidance	Lead	2.5	ug/L	5/1/2022	5:16:32PM	SES
W01A-10 2064 (DF)	E070490-25	Main Entrance Lobby	Lead	9.1	ug/L	5/1/2022	5:20:06PM	SES
W01A-11 2064 (DF)	E070490-26	Room 10	Lead	3.2	ug/L	5/1/2022	5:30:48PM	SES
W01A-12 2064 (DF)	E070490-27	Room 20	Lead	3.0	ug/L	5/1/2022	5:34:22PM	SES
W01A-13 2064 (DF)	E070490-28	Hallway By Room 30	Lead	2.7	ug/L	5/1/2022	5:37:57PM	SES
W01A-13 2064 (DF) B	E070490-29	Hallway By Room 30	Lead	2.8	ug/L	5/1/2022	5:41:32PM	SES
W01A-14 2064 (DF)	E070490-30	Room 32	Lead	6.8	ug/L	5/1/2022	5:45:07PM	SES
W01A-15 2064 (DF)	E070490-31	East Exit B	Lead	1.0	ug/L	5/1/2022	5:55:52PM	SES
W01A-16 2064 (DF)	E070490-32	Room 34	Lead	1.1	ug/L	5/1/2022	5:59:26PM	SES
W01A-17 2064 (DF)	E070490-33	Room 40	Lead	1.6	ug/L	5/1/2022	6:03:00PM	SES
W01A-18 2064 (DF)	E070490-34	East Exit A	Lead	5.4	ug/L	5/1/2022	6:06:34PM	SES
W01A-18 2064 (DF) B	E070490-35	East Exit A	Lead	5.4	ug/L	5/1/2022	6:13:43PM	SES
W01A-19 2064 (DF)	E070490-36	Room 50	Lead	3.0	ug/L	5/1/2022	6:24:26PM	SES
W01A-19 2064 (DF) B	E070490-37	Room 50	Lead	3.4	ug/L	5/1/2022	6:28:00PM	SES
W01A-20 2064 (DF)	E070490-38	Room 51	Lead	4.5	ug/L	5/1/2022	6:38:45PM	SES
W01A-20 2064 (DF) B	E070490-39	Room 51	Lead	4.6	ug/L	5/1/2022	6:42:20PM	SES

Stephen Shelley, Laboratory Director

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*



Project: Frederick Co Schools

## Analytical Results

Project Number: New Market Middle School

Client Name: TIDEWATER

Project Manager: Meneka Rodrigo

Reported:

03-May-22 10:49

W01A-21 2064 (DF)	E070490-40	Room 60	Lead	11.5	ug/L	5/1/2022	6:45:56PM	SES
W01A-21 2064 (DF) B	E070490-41	Room 60	Lead	11.8	ug/L	5/1/2022	6:49:31PM	SES
W01A-22 2064 (DF)	E070490-42	Media	Lead	5.8	ug/L	5/1/2022	6:53:05PM	SES
W01A-22 2064 (DF) B	E070490-43	Media	Lead	6.0	ug/L	5/1/2022	6:56:40PM	SES
W01A-23 2064 (DF)	E070490-44	Hallway By Media	Lead	< 1.0	ug/L	5/1/2022	7:00:15PM	SES
W01A-24 2064 (DF)	E070490-45	Room 70	Lead	1.8	ug/L	5/1/2022	7:03:52PM	SES
W01A-25 2064 (DF)	E070490-46	Gym	Lead	4.1	ug/L	5/1/2022	7:21:46PM	SES

Stephen Shelley, Laboratory Director

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*



Project: Frederick Co Schools


## Analytical Results

Project Number: New Market Middle School  
Client Name: TIDEWATER  
Project Manager: Meneka Rodrigo

Reported:  
03-May-22 10:49

## Notes and Definitions

DET Analyte DETECTED  
ND Analyte NOT DETECTED at or above the reporting limit  
NR Not Reported  
dry Sample results reported on a dry weight basis  
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

SITE: NEW MARKET MIDDLE SCHOOL 125 W. MAIN STREET, NEW MARKET, MD 21774  
 SAMPLER'S NAME: CHRISTOPHER WILCOMBE

70490

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1	K17-01 2064 (IM)	NMMS	Kitchen	8	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	April 29, 2022 5:07
2	K31-02 2064 (KS)	NMMS	Kitchen	8	D2010.60 Plumbing Fixture (Kitchen Sink)	April 29, 2022 5:01
3	K31-04 2064 (KS)	NMMS	Kitchen	8	D2010.60 Plumbing Fixture (Kitchen Sink)	April 29, 2022 5:03
4	S23-014 2064 (HE)	NMMS	Home Economics	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 29, 2022 4:29
5	S23-015 2064 (HE)	NMMS	Home Economics	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 29, 2022 4:30
6	S23-016 2064 (HE)	NMMS	Home Economics	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 29, 2022 4:31
7	S23-017 2064 (HE)	NMMS	Home Economics	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 29, 2022 4:32
8	S23-018 2064 (HE)	NMMS	Home Economics	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 29, 2022 4:33
9	S23-019 2064 (HE)	NMMS	Home Economics	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 29, 2022 4:33
10	S23-020 2064 (HE)	NMMS	Home Economics	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 29, 2022 4:35

SITE: NEW MARKET MIDDLE SCHOOL 125 W. MAIN STREET, NEW MARKET, MD 21774  
 SAMPLER'S NAME: CHRISTOPHER WILCOMBE

20180

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
11	S23-033 2064 (NO)	NMMS	Health Room	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 29, 2022 3:57
12	S23-038 2064 (TL)	NMMS	Staff Lounge	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 29, 2022 4:05
13	W01A-01 2064 (DF)	NMMS	Rear Entrance	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 5:00
14	W01A-02 2064 (DF)	NMMS	Outside Room 9	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:48
15	W01A-03 2064 (DF)	NMMS	Cafeteria	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:54
16	W01A-03 2064 (DF) B	NMMS	Cafeteria	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:54
17	W01A-04 2064 (DF)	NMMS	Cafeteria	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:57
18	W01A-05 2064 (DF)	NMMS	Cafeteria	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:56
19	W01A-06 2064 (DF)	NMMS	By Elevator	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:47
20	W01A-06 2064 (DF) B	NMMS	By Elevator	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:47

SITE: NEW MARKET MIDDLE SCHOOL 125 W. MAIN STREET, NEW MARKET, MD 21774  
 SAMPLERS NAME: CHRISTOPHER WILCOMBE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
21	W01A-07 2064 (DF)	NMMS	Boy's Locker Room	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:49
22	W01A-08 2064 (DF)	NMMS	Girl's Locker Room	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:52
23	W01A-09 2064 (DF)	NMMS	Hallway By Guidance	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:02
24	W01A-09 2064 (DF) B	NMMS	Hallway By Guidance	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:03
25	W01A-10 2064 (DF)	NMMS	Main Entrance Lobby	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:11
26	W01A-11 2064 (DF)	NMMS	Room 10	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:00
27	W01A-12 2064 (DF)	NMMS	Room 20	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:39
28	W01A-13 2064 (DF)	NMMS	Hallway By Room 30	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:23
29	W01A-13 2064 (DF) B	NMMS	Hallway By Room 30	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:24
30	W01A-14 2064 (DF)	NMMS	Room 32	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:37

20490

SITE: NEW MARKET MIDDLE SCHOOL 125 W. MAIN STREET, NEW MARKET, MD 21774  
 SAMPLER'S NAME: CHRISTOPHER WILCOMBE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
31	W01A-15 2064 (DF)	NMMS	East Exit B	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:26
32	W01A-16 2064 (DF)	NMMS	Room 34	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:27
33	W01A-17 2064 (DF)	NMMS	Room 40	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:21
34	W01A-18 2064 (DF)	NMMS	East Exit A	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:18
35	W01A-18 2064 (DF) B	NMMS	East Exit A	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:18
36	W01A-19 2064 (DF)	NMMS	Room 50	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:16
37	W01A-19 2064 (DF) B	NMMS	Room 50	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:16
38	W01A-20 2064 (DF)	NMMS	Room 51	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:14
39	W01A-20 2064 (DF) B	NMMS	Room 51	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:14
40	W01A-21 2064 (DF)	NMMS	Room 60	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022 4:10

2022



SITE: NEW MARKET MIDDLE SCHOOL 125 W. MAIN STREET, NEW MARKET, MD 21774  
 SAMPLER'S NAME: CHRISTOPHER WILCOMBE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
41	W01A-21 2064 (DF) B	NMMS	Room 60	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022  4:10
42	W01A-22 2064 (DF)	NMMS	Media	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	4:41 April 29, 2022  4:41
43	W01A-22 2064 (DF) B	NMMS	Media	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	4:41 April 29, 2022  4:42
44	W01A-23 2064 (DF)	NMMS	Hallway By Media	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022  4:42
45	W01A-24 2064 (DF)	NMMS	Room 70	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022  4:08
46	W01A-25 2064 (DF)	NMMS	Gym	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 29, 2022  4:50

70490