



Project: Frederick Co Schools

Analytical Results

Project Number: Whittier Elementary
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
18-Mar-22 12:48

Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K17-01 1021 (IM)	E070066-01	Kitchen	Lead	< 1.0	ug/L	3/17/2022 8:28:59PM	MAP
K17-03 1021 (IM)	E070066-02	Staff Lounge	Lead	1.3	ug/L	3/17/2022 8:32:32PM	MAP
K31-01 1021 (KS)	E070066-03	Kitchen	Lead	1.1	ug/L	3/17/2022 8:36:05PM	MAP
S23-19 1021 (NO)	E070066-04	Health Room	Lead	< 1.0	ug/L	3/17/2022 8:46:46PM	MAP
S23-26 1021 (TL)	E070066-05	Staff Lounge	Lead	< 1.0	ug/L	3/17/2022 8:50:21PM	MAP
W01A-01 1021 (DF)	E070066-06	1st Floor Outside Office	Lead	< 1.0	ug/L	3/17/2022 8:53:55PM	MAP
W01A-01 1021 (DF) B	E070066-07	1st Floor Outside Office	Lead	< 1.0	ug/L	3/17/2022 8:57:30PM	MAP
W01A-02 1021 (DF)	E070066-08	1st Floor Outside Office	Lead	< 1.0	ug/L	3/17/2022 9:01:06PM	MAP
W01A-02 1021 (DF) B	E070066-09	1st Floor Outside Office	Lead	< 1.0	ug/L	3/17/2022 9:11:50PM	MAP
W01A-03 1021 (DF)	E070066-10	In Cafe	Lead	< 1.0	ug/L	3/17/2022 9:15:24PM	MAP
W01A-03 1021 (DF) B	E070066-11	In Cafe	Lead	< 1.0	ug/L	3/17/2022 9:18:58PM	MAP
W01A-04 1021 (DF)	E070066-12	In Cafe	Lead	< 1.0	ug/L	3/17/2022 9:29:40PM	MAP
W01A-05 1021 (DF)	E070066-13	2nd Floor By Room 211	Lead	< 1.0	ug/L	3/17/2022 9:33:14PM	MAP
W01A-05 1021 (DF) B	E070066-14	2nd Floor By Room 211	Lead	< 1.0	ug/L	3/17/2022 9:36:48PM	MAP
W01A-06 1021 (DF)	E070066-15	2nd Floor By Room 211	Lead	< 1.0	ug/L	3/17/2022 9:40:22PM	MAP
W01A-07 1021 (DF)	E070066-16	Gym	Lead	< 1.0	ug/L	3/17/2022 9:43:57PM	MAP
W01A-08 1021 (DF) L	E070066-17	By Room 15	Lead	< 1.0	ug/L	3/17/2022 9:54:41PM	MAP
W01A-08 1021 (DF) R	E070066-18	By Room 15	Lead	< 1.0	ug/L	3/17/2022 9:58:16PM	MAP

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools

Analytical Results

Project Number: Whittier Elementary

Client Name: TIDEWATER

Project Manager: Meneka Rodrigo

Reported:

18-Mar-22 12:48

W01A-09 1021 (DF) L E070066-19 By Room 107	Lead	< 1.0	ug/L	3/17/2022 10:01:52PM	MAP
W01A-09 1021 (DF) R E070066-20 By Room 107	Lead	< 1.0	ug/L	3/17/2022 10:05:26PM	MAP

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools


Analytical Results

Project Number: Whittier Elementary
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
18-Mar-22 12:48

Notes and Definitions

DET Analyte DETECTED
ND Analyte NOT DETECTED at or above the reporting limit
NR Not Reported
dry Sample results reported on a dry weight basis
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

SITE: WHITTIER ELEMENTARY SCHOOL 2400 Whittier Drive, Frederick, MD 21702
 SAMPLER'S NAME: PHILLIP RANKING

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1	K17-01 1021 (IM)	WHES	Kitchen	4	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	March 16, 2022 6:17
2	K17-03 1021 (IM)	WHES	Staff Lounge	4	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	March 16, 2022 6:24
3	K31-01 1021 (KS)	WHES	Kitchen	4	D2010.60 Plumbing Fixture (Kitchen Sink)	March 16, 2022 6:15
4	S23-19 1021 (NO)	WHES	Health Room	4	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 16, 2022 6:24
5	S23-26 1021 (TL)	WHES	Staff Lounge	4	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 16, 2022 6:25
6	W01A-01 1021 (DF)	WHES	1st Floor Outside Office	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 16, 2022 6:11
7	W01A-01 1021 (DF) B	WHES	1st Floor Outside Office	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 16, 2022 6:10
8	W01A-02 1021 (DF)	WHES	1st Floor Outside Office	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 16, 2022 6:13
9	W01A-02 1021 (DF) B	WHES	1st Floor Outside Office	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 16, 2022 6:12
10	W01A-03 1021 (DF)	WHES	In Cafe	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 16, 2022 6:19

SITE: WHITTIER ELEMENTARY SCHOOL 2400 Whittier Drive, Frederick, MD 21702
 SAMPLER'S NAME: PHILLIP RANKING

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
11	W01A-03 1021 (DF) B	WHES	In Cafe	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 16, 2022 6:20
12	W01A-04 1021 (DF)	WHES	In Cafe	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 16, 2022 6:22
13	W01A-05 1021 (DF)	WHES	2nd Floor By Room 211	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain) <i>Boyle Rilla</i>	March 16, 2022 6:42
14	W01A-05 1021 (DF) B	WHES	2nd Floor By Room 211	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 16, 2022 6:45
15	W01A-06 1021 (DF)	WHES	2nd Floor By Room 211	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 16, 2022 6:40
16	W01A-07 1021 (DF)	WHES	Gym	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 16, 2022 6:50
17	W01A-08 1021 (DF) L	WHES	By Room 15	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 16, 2022 6:22
18	W01A-08 1021 (DF) R	WHES	By Room 15	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 16, 2022 6:28
19	W01A-09 1021 (DF) L	WHES	By Room 107	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 16, 2022 6:32
20	W01A-09 1021 (DF) R	WHES	By Room 107	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 16, 2022 6:34

Phillip Ranking
 3/16/22 1518