



Project: Frederick Co Schools

## Analytical Results

Project Number: Walkersville High  
Client Name: TIDEWATER  
Project Manager: Meneka Rodrigo

Reported:  
07-Mar-22 15:52

### Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K17-03 3054 (IM)	E069896-01	Athletic Laundry Room 116	Lead	< 1.0	ug/L	3/4/2022 12:11:14PM	SES
K17-04 3054 (IM)	E069896-02	Cooler room by 116	Lead	< 1.0	ug/L	3/4/2022 12:21:57PM	SES
K31-01 3054 (KS)	E069896-03	Kitchen	Lead	40.5	ug/L	3/4/2022 12:25:30PM	SES
K31-02 3054 (KS)	E069896-04	Kitchen	Lead	140	ug/L	3/4/2022 12:36:12PM	SES
K31-03 3054 (KS)	E069896-05	Kitchen	Lead	3.7	ug/L	3/4/2022 12:39:46PM	SES
K31-04 3054 (KS)	E069896-06	Kitchen	Lead	43.1	ug/L	3/4/2022 12:43:21PM	SES
S23-033 3054 (HE)	E069896-07	Classroom 177	Lead	2.5	ug/L	3/4/2022 12:46:56PM	SES
S23-034 3054 (HE)	E069896-08	Classroom 179	Lead	15.2	ug/L	3/4/2022 12:50:31PM	SES
S23-035 3054 (HE)	E069896-09	Classroom 179	Lead	10.0	ug/L	3/4/2022 12:54:05PM	SES
S23-036 3054 (HE)	E069896-10	Classroom 176	Lead	10.6	ug/L	3/4/2022 1:04:47PM	SES
S23-138 3054 (TL)	E069896-11	Teachers Lounge 142	Lead	< 1.0	ug/L	3/4/2022 1:11:54PM	SES
S23-177 3054 (TL)	E069896-12	Teachers Lounge 104	Lead	1.6	ug/L	3/4/2022 1:22:36PM	SES
S23-179 3054 (NO)	E069896-13	Health Room 110	Lead	2.8	ug/L	3/4/2022 1:26:10PM	SES
S23-190 3054 (OT)	E069896-14	Music Break Room 168	Lead	9.4	ug/L	3/4/2022 1:29:45PM	SES
W01A-01 3054 (DF)	E069896-15	Boy's Locker Room	Lead	1.2	ug/L	3/4/2022 1:33:20PM	SES
W01A-02 3054 (DF)	E069896-16	Women's Locker Room	Lead	3.5	ug/L	3/4/2022 1:36:55PM	SES
W01A-03 3054 (DF)	E069896-17	By Athletic Directors Office	Lead	< 1.0	ug/L	3/4/2022 1:47:40PM	SES
W01A-04 3054 (DF)	E069896-18	By Athletic Directors Office	Lead	< 1.0	ug/L	3/4/2022 1:51:14PM	SES

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools

## Analytical Results

Project Number: Walkersville High  
Client Name: TIDEWATER  
Project Manager: Meneka Rodrigo

Reported:  
07-Mar-22 15:52

W01A-05 3054 (DF) L-RE069896-19	Cafeteria	Lead	< 1.0	ug/L	3/4/2022	1:54:48PM	SES
W01A-05 3054 (DF) L-RE069896-20	Cafeteria	Lead	< 1.0	ug/L	3/4/2022	1:58:22PM	SES
W01A-05 3054 (DF) L-RE069896-21	Cafeteria	Lead	< 1.0	ug/L	3/4/2022	2:01:56PM	SES
W01A-06 3054 (DF) L-RE069896-22	Cafeteria	Lead	< 1.0	ug/L	3/4/2022	2:12:38PM	SES
W01A-06 3054 (DF) L-RE069896-23	Cafeteria	Lead	< 1.0	ug/L	3/4/2022	2:16:12PM	SES
W01A-07 3054 (DF) E069896-24	Hallway by Wrestling Room	Lead	1.3	ug/L	3/4/2022	2:19:46PM	SES
W01A-08 3054 (DF) B (fE069896-25	Hallway by Wrestling Room	Lead	1.1	ug/L	3/4/2022	2:30:30PM	SES
W01A-08 3054 (DF) B (tE069896-26	Hallway by Wrestling Room	Lead	1.2	ug/L	3/4/2022	2:34:06PM	SES
W01A-09 3054 (DF) B (fE069896-27	Vo-Ag Shop	Lead	< 1.0	ug/L	3/4/2022	2:37:41PM	SES
W01A-09 3054 (DF) B (tE069896-28	Vo-Ag Shop	Lead	< 1.0	ug/L	3/4/2022	2:41:15PM	SES
W01A-10 3054 (DF) E069896-29	By Scirence Prep	Lead	4.9	ug/L	3/4/2022	2:44:50PM	SES
W01A-11 3054 (DF) B (fE069896-30	By Scirence Prep	Lead	< 1.0	ug/L	3/4/2022	2:48:24PM	SES
W01A-11 3054 (DF) B (bE069896-31	By Scirence Prep	Lead	1.0	ug/L	3/4/2022	2:55:32PM	SES
W01A-12 3054 (DF) E069896-32	Math Hallway	Lead	< 1.0	ug/L	3/4/2022	3:13:24PM	SES
W01A-13 3054 (DF) B (fE069896-33	Math Hallway	Lead	< 1.0	ug/L	3/4/2022	3:16:59PM	SES
W01A-13 3054 (DF) B (tE069896-34	Math Hallway	Lead	< 1.0	ug/L	3/4/2022	3:20:34PM	SES
W01A-14 3054 (DF) B (fE069896-35	Room 160	Lead	1.8	ug/L	3/4/2022	3:24:09PM	SES
W01A-14 3054 (DF) B (tE069896-36	Room 160	Lead	1.6	ug/L	3/4/2022	3:27:45PM	SES
W01A-15 3054 (DF) E069896-37	Room 164	Lead	5.4	ug/L	3/4/2022	3:31:19PM	SES
W01A-16 3054 (DF) E069896-38	Hallway By Auditorium	Lead	3.1	ug/L	3/4/2022	3:34:54PM	SES
W01A-17 3054 (DF) E069896-39	Hall by Faculty R.R.	Lead	8.8	ug/L	3/4/2022	3:39:00PM	SES

Stephen Shelley, Laboratory Director

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*



Project: Frederick Co Schools

## Analytical Results

Project Number: Walkersville High  
Client Name: TIDEWATER  
Project Manager: Meneka Rodrigo

Reported:  
07-Mar-22 15:52

W01A-18 3054 (DF) B (fE069896-40	Room 177	Lead	2.3	ug/L	3/4/2022	3:42:00PM	SES
W01A-18 3054 (DF) B (tE069896-41	Room 177	Lead	2.6	ug/L	3/4/2022	3:46:00PM	SES
W01A-19 3054 (DF)	E069896-42 Outside Music Room	Lead	5.4	ug/L	3/4/2022	4:04:00PM	SES
W01A-20 3054 (DF)	E069896-43 Weight Room	Lead	< 1.0	ug/L	3/4/2022	4:07:00PM	SES
W01A-21 3054 (DF) B (fE069896-44	Weight Room	Lead	< 1.0	ug/L	3/4/2022	4:11:00PM	SES
W01A-21 3054 (DF) B (tE069896-45	Weight Room	Lead	< 1.0	ug/L	3/4/2022	4:15:00PM	SES
W01B-01 3054 (DF)	E069896-46 Gym	Lead	7.5	ug/L	3/4/2022	4:18:00PM	SES
W01B-02 3054 (DF)	E069896-47 Gym	Lead	4.3	ug/L	3/4/2022	4:22:00PM	SES
W01B-03 3054 (DF)	E069896-48 Pool Area	Lead	7.0	ug/L	3/4/2022	4:25:00PM	SES
W01B-04 3054 (DF)	E069896-49 Pool Area	Lead	28.3	ug/L	3/4/2022	4:29:00PM	SES
W11-28 3054 (OT)	E069896-50 Storage room next to 116	Lead	2.8	ug/L	3/4/2022	4:40:00PM	SES

Stephen Shelley, Laboratory Director

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*



Project: Frederick Co Schools


## Analytical Results

Project Number: Walkersville High  
Client Name: TIDEWATER  
Project Manager: Meneka Rodrigo

Reported:  
07-Mar-22 15:52

## Notes and Definitions

DET Analyte DETECTED  
ND Analyte NOT DETECTED at or above the reporting limit  
NR Not Reported  
dry Sample results reported on a dry weight basis  
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

SITE: WALKERSVILLE HIGH SCHOOL 81 WEST FREDERICK STREET, WALKERSVILLE, MD 21793  
 SAMPLER'S NAME: DUREKA ALUWHARE

60896

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1	K17-03 3054 (IM) Test Point	WHS	Athletic Laundry Room 116	5	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	March 3, 2022 3:55
2	K17-04 3054 (IM) Test Point	WHS	Cooler room by 116	5	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	March 3, 2022 3:59
3	K31-01 3054 (KS) Test Point	WHS	Kitchen	5	D2010.60 Plumbing Fixture (Kitchen Sink)	March 3, 2022 4:06
4	K31-02 3054 (KS) Test Point	WHS	Kitchen	5	D2010.60 Plumbing Fixture (Kitchen Sink)	March 3, 2022 4:06
5	K31-03 3054 (KS) Test Point	WHS	Kitchen	5	D2010.60 Plumbing Fixture (Kitchen Sink)	March 3, 2022 4:08
6	K31-04 3054 (KS) Test Point	WHS	Kitchen	5	D2010.60 Plumbing Fixture (Kitchen Sink)	March 3, 2022 4:08
7	S23-033 3054 (HE) Test Point	WHS	Classroom 177	5	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 3, 2022 4:15
8	S23-034 3054 (HE) Test Point	WHS	Classroom 179	5	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 3, 2022 4:16
9	S23-035 3054 (HE) Test Point	WHS	Classroom 179	5	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 3, 2022 4:17
10	S23-036 3054 (HE) Test Point	WHS	Classroom 176	5	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 3, 2022 4:21
11	S23-138 3054 (TL) Test Point	WHS	Teachers Lounge 142	5	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 3, 2022 4:24

**SITE: WALKERSVILLE HIGH SCHOOL 81 WEST FREDERICK STREET, WALKERSVILLE, MD 21793**  
**SAMPLER'S NAME: DUREKA ALUWHARE**

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
12	S23-177 3054 (TL) Test Point	WHS	Teachers Lounge 104	5	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 3, 2022 4:22
13	S23-179 3054 (NO) Test Point	WHS	Health Room 110	5	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 3, 2022 4:30
14	S23-190 3054 (OT) Test Point	WHS	Music Break Room 168	5	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 3, 2022 4:31
15	W01A-01 3054 (DF) Test Point	WHS	Boys Locker Room	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 3, 2022 4:38
16	W01A-02 3054 (DF) Test Point	WHS	Women's Locker Room	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 3, 2022 4:38
17	W01A-03 3054 (DF) Test Point	WHS	By Athletic Directors Office	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 3, 2022 4:40
18	W01A-04 3054 (DF) Test Point	WHS	By Athletic Directors Office	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 3, 2022 4:41
19	W01A-05 3054 (DF) Test Point L-R-B (left)	WHS	Cafeteria	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 3, 2022 4:45
20	W01A-05 3054 (DF) Test Point L-R-B (right)	WHS	Cafeteria	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 3, 2022 4:46
21	W01A-05 3054 (DF) Test Point L-R-B (bottle filler)	WHS	Cafeteria	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 3, 2022 4:46
22	W01A-06 3054 (DF) Test Point L-R (left)	WHS	Cafeteria	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 3, 2022 4:56

SITE: WALKERSVILLE HIGH SCHOOL 81 WEST FREDERICK STREET, WALKERSVILLE, MD 21793  
 SAMPLER'S NAME: DUREKA ALUWHARE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
23	W01A-06 3054 (DF) Test Point L-R (right)	WHS	Cafeteria	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 3, 2022 4:50
24	W01A-07 3054 (DF) Test Point	WHS	Hallway by Wrestling Room	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 3, 2022 4:55
25	W01A-08 3054 (DF) Test Point B (fountain)	WHS	Hallway by Wrestling Room	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 3, 2022 4:56
26	W01A-08 3054 (DF) Test Point B (bottle filler)	WHS	Hallway by Wrestling Room	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 3, 2022 4:56
27	W01A-09 3054 (DF) Test Point B (fountain)	WHS	Vo-Ag Shop	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 3, 2022 5:01
28	W01A-09 3054 (DF) Test Point B (bottle filler)	WHS	Vo-Ag Shop	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 3, 2022 5:01
29	W01A-10 3054 (DF) Test Point	WHS	By Science Prep	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 3, 2022 5:07
30	W01A-11 3054 (DF) Test Point B (fountain)	WHS	By Science Prep	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 3, 2022 5:08
31	W01A-11 3054 (DF) Test Point B (bottle filler)	WHS	By Science Prep	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 3, 2022 5:09
32	W01A-12 3054 (DF) Test Point	WHS	Math Hallway	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 3, 2022 5:17
33	W01A-13 3054 (DF) Test Point B (fountain)	WHS	Math Hallway	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 3, 2022 5:17

SITE: WALKERSVILLE HIGH SCHOOL 81 WEST FREDERICK STREET, WALKERSVILLE, MD 21793  
 SAMPLER'S NAME: DUREKA ALUWHARE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
34	W01A-13 3054 (DF) Test Point B (bottle filler)	WHS	Math Hallway	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 3, 2022 5:11
35	W01A-14 3054 (DF) Test Point B (fountain)	WHS	Room 160	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 3, 2022 5:12
36	W01A-14 3054 (DF) Test Point B (bottle filler)	WHS	Room 160	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 3, 2022 5:12
37	W01A-15 3054 (DF) Test Point	WHS	Room 164	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 3, 2022 5:20
38	W01A-16 3054 (DF) Test Point	WHS	Hallway By Auditorium	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 3, 2022 5:22
39	W01A-17 3054 (DF) Test Point	WHS	Hall by Faculty R.R.	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 3, 2022 5:22
40	W01A-18 3054 (DF) Test Point B (fountain)	WHS	Room 177	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 3, 2022 5:21
41	W01A-18 3054 (DF) Test Point B (bottle filler)	WHS	Room 177	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 3, 2022 5:25
42	W01A-19 3054 (DF) Test Point	WHS	Outside Music Room	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 3, 2022 5:25
43	W01A-20 3054 (DF) Test Point	WHS	Weight Room	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 3, 2022 5:28
44	W01A-21 3054 (DF) Test Point B (fountain)	WHS	Weight Room	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 3, 2022 5:28



**SITE: WALKERSVILLE HIGH SCHOOL 81 WEST FREDERICK STREET, WALKERSVILLE, MD 21793**  
**SAMPLER'S NAME: DUREKA ALUWHARE**

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
45	W01A-21 3054 (DF) Test Point B (bottle filler)	WHS	Weight Room	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 3, 2022 5:36
46	W01B-01 3054 (DF) Test Point	WHS	Gym	5	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	March 3, 2022 5:34
47	W01B-02 3054 (DF) Test Point	WHS	Gym	5	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	March 3, 2022 5:34
48	W01B-03 3054 (DF) Test Point	WHS	Pool Area	5	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	March 3, 2022 5:39
49	W01B-04 3054 (DF) Test Point	WHS	Pool Area	5	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	March 3, 2022 5:40
50	W11-28 3054 (OT) Test Point	WHS	Storage room next to 116	5	D2010.60 Plumbing Fixture (Hose Bib)	March 3, 2022 5:40

**Client:** Frederick County Public Schools  
ATTN: Accounts Payable 191 South East Stree  
Frederick, MD 21701-

**Project:** Walkersville High School  
WHS Flush

**Site:** Walkersville High School  
81 West Frederick St.  
Walkersville, MD 21793

**Work order: FWC0474**

Revised: 04/01/2022 - Revised Source Name

Received at lab: 03/14/22 10:39  
Date Reported: 04/01/22 12:18  
Collected by: Marc Angleberger, ID: 0659MA  
Treatment: N/A

**Source: K-31-01-3054-KS**

(Drinking Water)(Grab - Flushed)

Collected: 3/12/2022 7:54:00AM

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	Prepared	Analyzed	Analyst	Qual	Method
FWC0474-01	Lead	<0.005	mg/L	0.005	03/24/22 15:17	03/24/22 17:19	KMW		SM3113-B

**Source: K-31-02-3054-KS**

(Drinking Water)(Grab - Flushed)

Collected: 3/12/2022 7:55:00AM

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	Prepared	Analyzed	Analyst	Qual	Method
FWC0474-02	Lead	0.023	mg/L	0.005	03/24/22 11:39	03/24/22 13:48	KMW		SM3113-B

**Source: K-31-03-3054-KS**

(Drinking Water)(Grab - Flushed)

Collected: 3/12/2022 7:56:00AM

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	Prepared	Analyzed	Analyst	Qual	Method
FWC0474-03	Lead	NS	mg/L	0.005	03/25/22 14:27	03/25/22 14:27	KH	NOTE	SM3113-B

**Source: K-31-04-3054-KS**

(Drinking Water)(Grab - Flushed)

Collected: 3/12/2022 7:57:00AM

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	Prepared	Analyzed	Analyst	Qual	Method
FWC0474-04	Lead	<0.005	mg/L	0.005	03/24/22 11:39	03/24/22 13:57	KMW		SM3113-B

**Source: W01B-02-3054-DF**

(Drinking Water)(Grab - Flushed)

Collected: 3/12/2022 7:45:00AM

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	Prepared	Analyzed	Analyst	Qual	Method
FWC0474-05	Lead	<0.005	mg/L	0.005	03/24/22 11:39	03/24/22 14:12	KMW		SM3113-B

*Sara E. Randall*  
Sara E. Randall, President

**Client:** Frederick County Public Schools  
ATTN: Accounts Payable 191 South East Stree  
Frederick, MD 21701-

**Project:** Walkersville High School  
WHS Flush

**Site:** Walkersville High School  
81 West Frederick St.  
Walkersville, MD 21793

**Work order: FWC0474**

Revised: 04/01/2022 - Revised Source Name

Received at lab: 03/14/22 10:39  
Date Reported: 04/01/22 12:18  
Collected by: Marc Angleberger, ID: 0659MA  
Treatment: N/A

**Source: W01B-04-3054-DF**

(Drinking Water)(Grab - Flushed)

Collected: 3/12/2022 8:08:00AM

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	Prepared	Analyzed	Analyst	Qual	Method
FWC0474-06	Lead	NS	mg/L	0.005	03/25/22 14:28	03/25/22 14:28	KH	NOTE	SM3113-B

**Source: W01B-03-3054-DF**

(Drinking Water)(Grab - Flushed)

Collected: 3/12/2022 8:10:00AM

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	Prepared	Analyzed	Analyst	Qual	Method
FWC0474-07	Lead	<0.005	mg/L	0.005	03/24/22 15:17	03/24/22 17:01	KMW		SM3113-B

**Source: S23-190-3054-OT**

(Drinking Water)(Grab - Flushed)

Collected: 3/12/2022 8:11:00AM

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	Prepared	Analyzed	Analyst	Qual	Method
FWC0474-08	Lead	<0.005	mg/L	0.005	03/24/22 15:17	03/24/22 16:03	KMW		SM3113-B

**Source: W01A-19-3054-DF**

(Drinking Water)(Grab - Flushed)

Collected: 3/12/2022 8:19:00AM

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	Prepared	Analyzed	Analyst	Qual	Method
FWC0474-09	Lead	NS	mg/L	0.005	03/25/22 14:28	03/25/22 14:28	KH	NOTE	SM3113-B

**Source: S23-035-3054-HE**

(Drinking Water)(Grab - Flushed)

Collected: 3/12/2022 8:19:00AM

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	Prepared	Analyzed	Analyst	Qual	Method
FWC0474-10	Lead	<0.005	mg/L	0.005	03/24/22 15:17	03/24/22 16:12	KMW		SM3113-B

*Sara E. Randall*  
Sara E. Randall, President

**Client:** Frederick County Public Schools  
ATTN: Accounts Payable 191 South East Stree  
Frederick, MD 21701-

**Project:** Walkersville High School  
WHS Flush

**Site:** Walkersville High School  
81 West Frederick St.  
Walkersville, MD 21793

**Work order: FWC0474**

Revised: 04/01/2022 - Revised Source Name

Received at lab: 03/14/22 10:39  
Date Reported: 04/01/22 12:18  
Collected by: Marc Angleberger, ID: 0659MA  
Treatment: N/A

**Source: S23-034-3054-HE**  
(Drinking Water)(Grab - Flushed)

Collected: 3/12/2022 8:21:00AM

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	Prepared	Analyzed	Analyst	Qual	Method
FWC0474-11	Lead	<0.005	mg/L	0.005	03/24/22 15:17	03/24/22 16:21	KMW		SM3113-B

**Source: S23-036-3054-HE**  
(Drinking Water)(Grab - Flushed)

Collected: 3/12/2022 8:22:00AM

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	Prepared	Analyzed	Analyst	Qual	Method
FWC0474-12	Lead	<0.005	mg/L	0.005	03/24/22 15:17	03/24/22 16:30	KMW		SM3113-B

**Source: W01A-17-3054-DF**  
(Drinking Water)(Grab - Flushed)

Collected: 3/12/2022 8:23:00AM

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	Prepared	Analyzed	Analyst	Qual	Method
FWC0474-13	Lead	<0.005	mg/L	0.005	03/24/22 15:17	03/24/22 16:38	KMW		SM3113-B

**Source: W01A-10-3054-DF**  
(Drinking Water)(Grab - Flushed)

Collected: 3/12/2022 8:28:00AM

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	Prepared	Analyzed	Analyst	Qual	Method
FWC0474-14	Lead	<0.005	mg/L	0.005	03/24/22 15:17	03/24/22 16:47	KMW		SM3113-B

**Source: W01A-15-3054-DF**  
(Drinking Water)(Grab - Flushed)

Collected: 3/12/2022 8:25:00AM

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	Prepared	Analyzed	Analyst	Qual	Method
FWC0474-15	Lead	<0.005	mg/L	0.005	03/24/22 15:17	03/24/22 17:10	KMW		SM3113-B

*Sara E. Randall*  
Sara E. Randall, President

Fredericktowne Labs, Inc. is a State Certified Water Quality Laboratory  
Maryland Cert. No. 116 Virginia Cert. No. 00444  
West Virginia Cert. 415 MDOT WBE Cert. No.: 91-158



# CHAIN OF CUSTODY

FREDERICKTOWNE LABS, INC.  
3020 VENTRIE CT., PO BOX 245, MYERSVILLE, MD 21773  
301-293-3340 OR FAX 301-293-2366

FTL Acct. No.: <b>344-</b> <i>FWCO2H 0474</i>					Collected By: (Please Print) <i>MARC Angleberger</i> <i>MA-0659</i>					Analyses To Be Performed										
Compliance Sample (regulated): Yes <input type="checkbox"/> No <input type="checkbox"/>					Affiliation: <b>Frederick County Public Schools</b>					<i>Lead</i>										
Project: <i>Walkersville High School</i> <i>81 West Frederick St. Walkersville, MD 21793</i>																				
Lab ID	Field Sample ID	Site Description	Collection Date		Collection Time		Matrix <i>(DWI)</i> WW	pH	Res. Cl	DO	Temp	<i>(Grab)</i> Comp	Rec'd Temp (at lab)	Preservation						
			Start	End	Start	End														
	<i>Flush</i>	<i>523-035-3054-HE</i>	<i>3-12-22</i>		<i>8:21 AM</i>		<input checked="" type="checkbox"/>					<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>						
	<i>"</i>	<i>523-034-3054-HE</i>	<i>"</i>		<i>8:22 AM</i>		<input checked="" type="checkbox"/>					<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>						
	<i>"</i>	<i>523-035-3054-HE</i>	<i>"</i>		<i>8:23 AM</i>		<input checked="" type="checkbox"/>					<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>						
	<i>"</i>	<i>WD1A-10-3054-DF</i>	<i>"</i>		<i>8:28 AM</i>		<input checked="" type="checkbox"/>					<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>						
	<i>"</i>	<i>WD1A-17-3054-DF</i>	<i>"</i>		<i>8:25 AM</i>		<input checked="" type="checkbox"/>					<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>						
Relinquished By:			Date/Time		Received By:			Date/Time		Treatment Devices Present: Yes <input type="checkbox"/> No <input type="checkbox"/>										
<i>(Print): MARC R Angleberger</i>			<i>3-14-22</i>		<i>(Print): Ellen Mellott</i>			<i>3/14/22</i>		Describe Treatment Device(s):										
<i>(Signature): Marc R. Angleberger</i>			<i>10:39 AM</i>		<i>(Signature): Ellen Mellott</i>			<i>10:39</i>												
Relinquished By:			Date/Time		Received By:			Date/Time		Lead & Copper Samples - Water Last Used:										
<i>(Print):</i>					<i>(Print):</i>					Date: _____ Time: _____										
<i>(Signature):</i>					<i>(Signature):</i>					Method of Shipment: Iced: Yes <input type="checkbox"/> No <input type="checkbox"/>										
Relinquished By:			Date/Time		Received By:			Date/Time		Condition of Sample(s) upon Receipt:										
<i>(Print):</i>					<i>(Print):</i>															
<i>(Signature):</i>					<i>(Signature):</i>															