



Project: Frederick Co Schools

Analytical Results

Project Number: Windsor Knoll MS
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
17-Jan-22 11:45

Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K17-01 2076 (IM)	E069431-01	Kitchen	Lead	< 1.0	ug/L	1/15/2022 2:26:31PM	SES
K31-01 2076 (KS)	E069431-02	Kitchen	Lead	3.1	ug/L	1/15/2022 2:30:21PM	SES
K31-02 2076 (KS)	E069431-03	Kitchen	Lead	4.2	ug/L	1/15/2022 2:34:11PM	SES
S23-29 2076 (NO)	E069431-04	Room 20	Lead	1.1	ug/L	1/15/2022 2:38:01PM	SES
S23-36 2076 (HE)	E069431-05	Room 109	Lead	2.7	ug/L	1/15/2022 2:41:49PM	SES
S23-37 2076 (HE)	E069431-06	Room 109	Lead	3.3	ug/L	1/15/2022 2:45:37PM	SES
S23-38 2076 (HE)	E069431-07	Room 109	Lead	2.5	ug/L	1/15/2022 2:49:25PM	SES
S23-39 2076 (HE)	E069431-08	Room 109	Lead	1.1	ug/L	1/15/2022 3:08:29PM	SES
S23-40 2076 (HE)	E069431-09	Room 109	Lead	2.9	ug/L	1/15/2022 3:12:18PM	SES
S23-41 2076 (HE)	E069431-10	Room 109	Lead	2.5	ug/L	1/15/2022 3:16:07PM	SES
S23-42 2076 (HE)	E069431-11	Room 29, by Home-Ec	Lead	1.6	ug/L	1/15/2022 3:19:57PM	SES
S23-57 2076 (TL)	E069431-12	Room 116	Lead	4.4	ug/L	1/15/2022 3:23:46PM	SES
W01A-01 2076 (DF)	E069431-13	Kitchen Hallway-Loading	Lead	< 1.0	ug/L	1/15/2022 3:27:36PM	SES
W01A-02 2076 (DF)	E069431-14	Girl's Locker Room	Lead	< 1.0	ug/L	1/15/2022 3:31:27PM	SES
W01A-03 2076 (DF)	E069431-15	Girl's Locker Room	Lead	< 1.0	ug/L	1/15/2022 3:35:15PM	SES
W01A-04 2076 (DF)	E069431-16	Boy's Locker Room	Lead	< 1.0	ug/L	1/15/2022 3:46:43PM	SES
W01A-05 2076 (DF)	E069431-17	Boy's Locker Room	Lead	< 1.0	ug/L	1/15/2022 3:54:20PM	SES
W01A-06 2076 (DF) B	(E069431-18)	Hallway Lobby West	Lead	< 1.0	ug/L	1/15/2022 4:05:46PM	SES

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools

Analytical Results

Project Number: Windsor Knoll MS

Client Name: TIDEWATER

Project Manager: Meneka Rodrigo

Reported:

17-Jan-22 11:45

W01A-06 2076 (DF) B (E069431-19	Hallway Lobby West	Lead	< 1.0	ug/L	1/15/2022	4:09:36PM	SES
W01A-07 2076 (DF) E069431-20	Hallway Lobby West	Lead	< 1.0	ug/L	1/15/2022	4:13:26PM	SES
W01A-08 2076 (DF) B (E069431-21	Hallway By Room 29	Lead	< 1.0	ug/L	1/15/2022	4:17:16PM	SES
W01A-08 2076 (DF) B (E069431-22	Hallway By Room 29	Lead	< 1.0	ug/L	1/15/2022	4:21:06PM	SES
W01A-09 2076 (DF) E069431-23	Hallway By Room 29	Lead	< 1.0	ug/L	1/15/2022	4:32:35PM	SES
W01A-10 2076 (DF) E069431-24	Hallway Music	Lead	< 1.0	ug/L	1/15/2022	4:36:24PM	SES
W01A-11 2076 (DF) E069431-25	Hallway Music	Lead	< 1.0	ug/L	1/15/2022	4:40:13PM	SES
W01A-12 2076 (DF) E069431-26	Hallway 2nd Floor East	Lead	< 1.0	ug/L	1/15/2022	4:44:02PM	SES
W01A-13 2076 (DF) B (E069431-27	Hallway 2nd Floor East	Lead	< 1.0	ug/L	1/15/2022	4:47:51PM	SES
W01A-13 2076 (DF) B (E069431-28	Hallway 2nd Floor East	Lead	< 1.0	ug/L	1/15/2022	4:59:19PM	SES
W01A-14 2076 (DF) E069431-29	Hallway 2nd Floor West	Lead	< 1.0	ug/L	1/15/2022	5:03:08PM	SES
W01A-15 2076 (DF) E069431-30	Hallway 2nd Floor West	Lead	4.9	ug/L	1/15/2022	5:06:58PM	SES
W01B-01 2076 (DF) E069431-31	Aux Gym	Lead	< 1.0	ug/L	1/15/2022	5:18:00PM	SES

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools


Analytical Results

Project Number: Windsor Knoll MS
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
17-Jan-22 11:45

Notes and Definitions

DET Analyte DETECTED
ND Analyte NOT DETECTED at or above the reporting limit
NR Not Reported
dry Sample results reported on a dry weight basis
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

SITE: WINDSOR KNOLLS MIDDLE SCHOOL, 11150 WINDSOR ROAD, JAMSVILLE, MD 21754
 SAMPLER'S NAME: UDAYANGA DIAS

Name	Site	Area-Room number	Area	Category	Sampling Date and Time
K17-01 2076 (IM)	WKMS	Kitchen	7	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	January 14, 2022 , 0400
K31-01 2076 (KS)	WKMS	Kitchen	7	D2010.60 Plumbing Fixture (Kitchen Sink)	January 14, 2022 , 0403
K31-02 2076 (KS)	WKMS	Kitchen	7	D2010.60 Plumbing Fixture (Kitchen Sink)	January 14, 2022 , 0412
S23-29 2076 (NO)	WKMS	Room 20	7	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	January 14, 2022 , 0458
S23-36 2076 (HE)	WKMS	Room 109	7	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	January 14, 2022 , 0440
S23-37 2076 (HE)	WKMS	Room 109	7	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	January 14, 2022 , 0441
S23-38 2076 (HE)	WKMS	Room 109	7	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	January 14, 2022 , 0442
S23-39 2076 (HE)	WKMS	Room 109	7	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	January 14, 2022 , 0443
S23-40 2076 (HE)	WKMS	Room 109	7	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	January 14, 2022 , 0444
S23-41 2076 (HE)	WKMS	Room 109	7	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	January 14, 2022 , 0445
S23-42 2076 (HE)	WKMS	Room 29, by Home-Ec	7	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	January 14, 2022 , 0438
S23-57 2076 (TL)	WKMS	Room 116	7	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	January 14, 2022 , 0453
W01A-01 2076 (DF)	WKMS	Kitchen Hallway-Loading	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	January 14, 2022 , 0414

6943

SITE: WINDSOR KNOLLS MIDDLE SCHOOL, 11150 WINDSOR ROAD, JAMSVILLE, MD 21754
SAMPLER'S NAME: UDAYANCA DIAS

Name	Site	Area-Room number	Area	Category	Sampling Date and Time
W01A-02 2076 (DF)	WKMS	Girl's Locker Room	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	January 14, 2022 , 0418
W01A-03 2076 (DF)	WKMS	Girl's Locker Room	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	January 14, 2022 , 0419
W01A-04 2076 (DF)	WKMS	Boy's Locker Room	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	January 14, 2022 , 0423
W01A-05 2076 (DF)	WKMS	Boy's Locker Room	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	January 14, 2022 , 0424
W01A-06 2076 (DF) B (fountain)	WKMS	Hallway Lobby West	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	January 14, 2022 , 0427
W01A-06 2076 (DF) B (bottle filler)	WKMS	Hallway Lobby West	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	January 14, 2022 , 0428
W01A-07 2076 (DF)	WKMS	Hallway Lobby West	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	January 14, 2022 , 0429
W01A-08 2076 (DF) B (fountain)	WKMS	Hallway By Room 29	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	January 14, 2022 , 0435
W01A-08 2076 (DF) B (bottle filler)	WKMS	Hallway By Room 29	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	January 14, 2022 , 0436
W01A-09 2076 (DF)	WKMS	Hallway By Room 29	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	January 14, 2022 , 0437
W01A-10 2076 (DF)	WKMS	Hallway Music	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	January 14, 2022 , 0432
W01A-11 2076 (DF)	WKMS	Hallway Music	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	January 14, 2022 , 0433
W01A-12 2076 (DF)	WKMS	Hallway 2nd Floor East	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	January 14, 2022 , 0503

69431

SITE: WINDSOR KNOLLS MIDDLE SCHOOL, 11150 WINDSOR ROAD, JAMSVILLE, MD 21754
SAMPLER'S NAME: UDAYANGA DIAS

Name	Site	Area-Room number	Area	Category	Sampling Date and Time
W01A-13 2076 (DF) B (fountain)	WKMS	Hallway 2nd Floor East	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	January 14, 2022, 0501
W01A-13 2076 (DF) B (bottle filler)	WKMS	Hallway 2nd Floor East	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	January 14, 2022, 0502
W01A-14 2076 (DF)	WKMS	Hallway 2nd Floor West	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	January 14, 2022, 0511
W01A-15 2076 (DF)	WKMS	Hallway 2nd Floor West	7	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	January 14, 2022, 0512
W01B-01 2076 (DF)	WKMS	Aux Gym	7	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	January 14, 2022, 0421

69431

VS
 1/14/22
 81-