



Project: Frederick Co Schools

Analytical Results

Project Number: Ballenger Creek Elementary School
 Client Name: TIDEWATER
 Project Manager: Meneka Rodrigo

Reported:
 24-Mar-22 14:07

Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K17-01 1028 (IM)	E070115-01	Kitchen/Dishroom	Lead	< 1.0	ug/L	3/23/2022 10:23:20AM	MAP
K31-05 1028 (KS)	E070115-02	Kitchen	Lead	< 1.0	ug/L	3/23/2022 10:26:54AM	MAP
S23-45 1028 (TL)	E070115-03	Teacher Lounge	Lead	< 1.0	ug/L	3/23/2022 10:37:38AM	MAP
S23-86 1028 (NO)	E070115-04	Health Room	Lead	< 1.0	ug/L	3/23/2022 10:41:13AM	MAP
W01A-01 1028 (DF)	E070115-05	Hallway at Gym	Lead	< 1.0	ug/L	3/23/2022 10:44:49AM	MAP
W01A-02 1028 (DF) B (E070115-06)	E070115-06	Hallway At Office	Lead	< 1.0	ug/L	3/23/2022 10:55:33AM	MAP
W01A-02 1028 (DF) B (E070115-07)	E070115-07	Hallway At Office	Lead	< 1.0	ug/L	3/23/2022 10:59:09AM	MAP
W01A-03 1028 (DF) L-FE070115-08	E070115-08	Hallway At Office	Lead	< 1.0	ug/L	3/23/2022 11:02:46AM	MAP
W01A-03 1028 (DF) L-FE070115-09	E070115-09	Hallway At Office	Lead	< 1.0	ug/L	3/23/2022 11:06:18AM	MAP
W01A-04 1028 (DF)	E070115-10	Hallway By Room 108	Lead	< 1.0	ug/L	3/23/2022 11:09:50AM	MAP
W01A-05 1028 (DF)	E070115-11	Hallway By Room 206	Lead	< 1.0	ug/L	3/23/2022 11:13:23AM	MAP
W01A-06 1028 (DF) B (E070115-12)	E070115-12	Hallway By Room 306	Lead	< 1.0	ug/L	3/23/2022 11:24:03AM	MAP
W01A-06 1028 (DF) B (E070115-13)	E070115-13	Hallway By Room 306	Lead	< 1.0	ug/L	3/23/2022 11:27:37AM	MAP

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools


Analytical Results

Project Number: Ballenger Creek Elementary School
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
24-Mar-22 14:07

Notes and Definitions

DET Analyte DETECTED
ND Analyte NOT DETECTED at or above the reporting limit
NR Not Reported
dry Sample results reported on a dry weight basis
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

SITE: BALLENGER CREEK ELEMENTARY SCHOOL 5250 Kingsbrook Drive, Frederick, MD 21703
Name: Dureka Aluwihare

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1	K17-01 1028 (IM)	BCES	Kitchen/Dishroom	6	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	March 22, 2022 S:02
2	K31-05 1028 (KS)	BCES	Kitchen	6	D2010.60 Plumbing Fixture (Kitchen Sink)	March 22, 2022 S:03
3	S23-45 1028 (TL)	BCES	Teacher Lounge	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 22, 2022 S:10
4	S23-86 1028 (NO)	BCES	Health Room	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 22, 2022 S:13
5	W01A-01 1028 (DF)	BCES	Hallway at Gym	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 22, 2022 S:20
6	W01A-02 1028 (DF) B (fountain)	BCES	Hallway At Office	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 22, 2022 S:22
7	W01A-02 1028 (DF) B (bottle filler)	BCES	Hallway At Office	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 22, 2022 S:25
8	W01A-03 1028 (DF) L-R (left)	BCES	Hallway At Office	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 22, 2022 S:26
9	W01A-03 1028 (DF) L-R (right)	BCES	Hallway At Office	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 22, 2022 S:27

20115

SITE: BALLENGER CREEK ELEMENTARY SCHOOL 5250 Kingsbrook Drive, Frederick, MD 21703
 Name: Dureka Aluwihare

2015

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
10	W01A-04 1028 (DF)	BCES	Hallway By Room 108	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 22, 2022 5:27
11	W01A-05 1028 (DF)	BCES	Hallway By Room 206	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 22, 2022 5:32
12	W01A-06 1028 (DF) B (fountain)	BCES	Hallway By Room 306	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 22, 2022 5:38
13	W01A-06 1028 (DF) B (bottle filler)	BCES	Hallway By Room 306	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 22, 2022 5:39