



Project: Frederick Co Schools

Analytical Results

Project Number: Brunswick High School
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
04-May-22 16:26

Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K17-01 3066 (IM)	E070480-01	Kitchen	Lead	< 1.0	ug/L	4/29/2022 11:31:47AM	RAS
K17-05 3066 (IM)	E070480-02	Athletic Laundry Room	Lead	< 1.0	ug/L	4/29/2022 11:35:22AM	RAS
K31-01 3066 (KS) L	E070480-04	Kitchen	Lead	< 1.0	ug/L	4/29/2022 11:38:57AM	RAS
K31-01 3066 (KS) R	E070480-05	Kitchen	Lead	< 1.0	ug/L	4/29/2022 11:42:32AM	RAS
S23-005 3066 (OT)	E070480-06	Room 100/ Learning for Life	Lead	< 1.0	ug/L	4/29/2022 11:46:08AM	RAS
S23-015 3066 (HE)	E070480-07	Room 104 Home Economics	Lead	2.8	ug/L	4/29/2022 11:56:52AM	RAS
S23-016 3066 (HE)	E070480-08	Room 104 Home Economics	Lead	4.4	ug/L	4/29/2022 12:00:29PM	RAS
S23-018 3066 (HE)	E070480-10	Room 104 Home Economics	Lead	1.9	ug/L	4/29/2022 12:04:05PM	RAS
S23-019 3066 (HE)	E070480-11	Room 104 Home Economics	Lead	1.6	ug/L	4/29/2022 12:07:37PM	RAS
S23-020 3066 (HE)	E070480-12	Room 104 Home Economics	Lead	1.3	ug/L	4/29/2022 12:11:10PM	RAS
S23-033 3066 (TL)	E070480-13	Room 112D Faculty Lounge	Lead	1.1	ug/L	4/29/2022 12:21:49PM	RAS
S23-042 3066 (NO)	E070480-14	Health Room	Lead	< 1.0	ug/L	4/29/2022 12:25:23PM	RAS
W01A-01 3066 (DF) L	E070480-16	Aud Lobby Hi Lo	Lead	< 1.0	ug/L	4/29/2022 12:28:57PM	RAS
W01A-01 3066 (DF) R	E070480-17	Aud Lobby Hi Lo	Lead	< 1.0	ug/L	4/29/2022 12:39:40PM	RAS
W01A-02 3066 (DF)	E070480-18	New Gym Lobby Bottle Filler Bottom	Lead	< 1.0	ug/L	4/29/2022 12:43:15PM	RAS
W01A-02 3066 (DF) B	E070480-19	New Gym Lobby Bottle Filler Bottom	Lead	< 1.0	ug/L	4/29/2022 12:46:50PM	RAS
W01A-03 3066 (DF)	E070480-20	New Gym Lobby	Lead	< 1.0	ug/L	4/29/2022 12:50:25PM	RAS
W01A-04 3066 (DF)	E070480-21	Hallway Boy's Restroom by Locker Rd	Lead	< 1.0	ug/L	4/29/2022 12:54:00PM	RAS

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools

Analytical Results

Project Number: Brunswick High School

Client Name: TIDEWATER

Project Manager: Meneka Rodrigo

Reported:

04-May-22 16:26

W01A-05 3066 (DF)	E070480-22	New Gym Visitor Locker Room	Lead	< 1.0	ug/L	4/29/2022	1:01:06PM	RAS
W01A-07 3066 (DF)	E070480-25	2nd Floor RM 213	Lead	< 1.0	ug/L	4/29/2022	1:26:01PM	RAS
W01A-07 3066 (DF) B	E070480-26	2nd Floor RM 213	Lead	< 1.0	ug/L	4/29/2022	1:29:35PM	RAS
W01A-08 3066 (DF)	E070480-27	AT Rm 606	Lead	< 1.0	ug/L	4/29/2022	1:33:10PM	RAS
W01A-08 3066 (DF) B	E070480-28	AT Rm 606	Lead	< 1.0	ug/L	4/29/2022	1:36:45PM	RAS
W01A-09 3066 (DF) B	E070480-29	Aux Gym Right Side/Girls Locker Room	Lead	< 1.0	ug/L	4/29/2022	1:40:20PM	RAS
W01A-09 3066 (DF) B	E070480-30	Aux Gym Right Side/Girls Locker Room	Lead	1.1	ug/L	4/29/2022	1:43:55PM	RAS
W01A-10 3066 (DF) B	E070480-31	Aux Gym Left Side/Boys Locker Room	Lead	< 1.0	ug/L	4/29/2022	1:47:28PM	RAS
W01A-10 3066 (DF) B	E070480-32	Aux Gym Left Side/Boys Locker Room	Lead	< 1.0	ug/L	4/29/2022	1:51:01PM	RAS
W01A-11 3066 (DF) B	E070480-34	Upstairs @ RM 200	Lead	< 1.0	ug/L	4/29/2022	1:54:34PM	RAS
W01B-01 3066 (DF)	E070480-35	Hall @ Café	Lead	< 1.0	ug/L	4/29/2022	2:05:16PM	RAS
W01B-05 3066 (DF)	E070480-36	Hallway at Rm 604	Lead	1.8	ug/L	4/29/2022	2:15:57PM	RAS
W01B-08 3066 (DF)	E070480-37	Hall outside Gym Lobby	Lead	1.9	ug/L	4/29/2022	2:19:31PM	RAS
W01B-13 3066 (DF)	E070480-38	In Rear Stairwell, 1st Floor	Lead	1.6	ug/L	4/29/2022	2:23:05PM	RAS
S23-017 3066 (HE)	E070505-01	Room 104 Home Economics	Lead	3.0	ug/L	5/1/2022	7:25:21PM	SES
S23-062 3066 (OT)	E070505-02	Maintenance Office	Lead	< 1.0	ug/L	5/1/2022	7:28:56PM	SES
W01A-01 3066 (DF) R	E070505-03	Aud Lobby Hi Lo	Lead	< 1.0	ug/L	5/1/2022	7:32:31PM	SES
W01A-06 3066 (DF)	E070505-04	Main Hall at Main Office	Lead	< 1.0	ug/L	5/1/2022	7:36:07PM	SES
W01A-06 3066 (DF) B	E070505-05	Main Hall at Main Office	Lead	< 1.0	ug/L	5/1/2022	7:39:42PM	SES
W01A-11 3066 (DF)	E070505-06	Upstairs @ RM 200	Lead	< 1.0	ug/L	5/1/2022	7:43:16PM	SES
W01B-14 3066 (DF)	E070505-07	In Rear Stairwell, 1st Floor	Lead	< 1.0	ug/L	5/1/2022	7:46:51PM	SES

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools


Analytical Results

Project Number: Brunswick High School
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
04-May-22 16:26

Notes and Definitions

DET Analyte DETECTED
ND Analyte NOT DETECTED at or above the reporting limit
NR Not Reported
dry Sample results reported on a dry weight basis
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

SITE: BRUNSWICK HIGH SCHOOL 101 CUMMINGS DRIVE, BRUNSWICK, MD 21716
 SAMPLER'S NAME: CHRISTOPHER WILCOMBE

70480

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1	K17-01 3066 (IM)	BHS	Kitchen	2	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	April 28, 2022 4:39
2	K17-05 3066 (IM)	BHS	Athletic Laundry Room	2	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	April 28, 2022 4:26
3	K17-06 3066 (IM)	BHS	Room 100/ Learning for Life Laundry Room	2	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	April 28, 2022 N/A
4	K31-01 3066 (KS) L	BHS	Kitchen	2	D2010.60 Plumbing Fixture (Kitchen Sink)	April 28, 2022 Out of order 4:40
5	K31-01 3066 (KS) R	BHS	Kitchen	2	D2010.60 Plumbing Fixture (Kitchen Sink)	April 28, 2022 4:40
6	S23-005 3066 (OT)	BHS	Room 100/ Learning for Life	2	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 28, 2022 3:58
7	S23-015 3066 (HE)	BHS	Room 104 Home Economics	2	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 28, 2022 4:02
8	S23-016 3066 (HE)	BHS	Room 104 Home Economics	2	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 28, 2022 4:02
9	S23-017 3066 (HE)	BHS	Room 104 Home Economics	2	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 28, 2022 4:01
10	S23-018 3066 (HE)	BHS	Room 104 Home Economics	2	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 28, 2022 4:05

SITE: BRUNSWICK HIGH SCHOOL 101 CUMMINGS DRIVE, BRUNSWICK, MD 21716
SAMPLER'S NAME: CHRISTOPHER WILCOMBE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
11	S23-019 3066 (HE)	BHS	Room 104 Home Economics	2	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 28, 2022 4:01
12	S23-020 3066 (HE)	BHS	Room 104 Home Economics	2	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 28, 2022 4:01
13	S23-033 3066 (TL)	BHS	Room 112D Faculty Lounge	2	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 28, 2022 4:54
14	S23-042 3066 (NO)	BHS	Health Room	2	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 28, 2022 4:23
15	S23-062 3066 (OT)	BHS	Maintenance Office	2	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 28, 2022 N/A <i>Can not get too</i>
16	W01A-01 3066 (DF) L	BHS	Aud Lobby HI Lo	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 28, 2022 4:43
17	W01A-01 3066 (DF) R	BHS	Aud Lobby HI Lo	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 28, 2022 4:43
18	W01A-02 3066 (DF)	BHS	New Gym Lobby Bottle Filler Bottom	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 28, 2022 4:20
19	W01A-02 3066 (DF) B	BHS	New Gym Lobby Bottle Filler Bottom	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 28, 2022 4:20
20	W01A-03 3066 (DF)	BHS	New Gym Lobby	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 28, 2022 4:18

For 8

SITE: BRUNSWICK HIGH SCHOOL 101 CUMMINGS DRIVE, BRUNSWICK, MD 21716
SAMPLER'S NAME: CHRISTOPHER WILCOME

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
21	W01A-04 3066 (DF)	BHS	Hallway Boy's Restroom by Locker Room	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 28, 2022 4:28
22	W01A-05 3066 (DF)	BHS	New Gym Visitor Locker Room	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	4:29 4/28/22 4:28
23	W01A-06 3066 (DF)	BHS	Main Hall at Main Office	2	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 28, 2022 3:57
24	W01A-06 3066 (DF) B	BHS	Main Hall at Main Office	2	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 28, 2022 3:57
25	W01A-07 3066 (DF)	BHS	2nd Floor RM 213	2	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 28, 2022 4:14
26	W01A-07 3066 (DF) B	BHS	2nd Floor RM 213	2	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 28, 2022 4:14
27	W01A-08 3066 (DF)	BHS	AT Rm 606	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 28, 2022 4:56
28	W01A-08 3066 (DF) B	BHS	AT Rm 606	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 28, 2022 4:56
29	W01A-09 3066 (DF) B	BHS	Aux Gym Right Side/Girls Locker Room	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 28, 2022 4:32
30	W01A-09 3066 (DF) B	BHS	Aux Gym Right Side/Girls Locker Room	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 28, 2022 4:32

SITE: BRUNSWICK HIGH SCHOOL 101 CUMMINGS DRIVE, BRUNSWICK, MD 21716
 SAMPLER'S NAME: CHRISTOPHER WILCOXE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
31	W01A-10 3066 (DF) B	BHS	Aux Gym Left Side/Boys Locker Room	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 28, 2022 4:30
32	W01A-10 3066 (DF) B	BHS	Aux Gym Left Side/Boys Locker Room	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 28, 2022 4:36
33	W01A-11 3066 (DF)	BHS	Upstairs @ RM 200	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 28, 2022 4:11
34	W01A-11 3066 (DF) B	BHS	Upstairs @ RM 200	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 28, 2022 4:11
35	W01B-01 3066 (DF)	BHS	Hall @ Cafe	2	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 28, 2022 4:44
36	W01B-05 3066 (DF)	BHS	Hallway at Rm 604	2	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 28, 2022 4:48
37	W01B-08 3066 (DF)	BHS	Hall outside Gym Lobby	2	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 28, 2022 4:36
38	W01B-13 3066 (DF)	BHS	In Rear Stairwell, 1st Floor	2	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 28, 2022 4:08
39	W01B-14 3066 (DF)	BHS	In Rear Stairwell, 1st Floor	2	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 28, 2022 4:08

20180

70505

SITE: BRUNSWICK HIGH SCHOOL 101 CUMMINGS DRIVE, BRUNSWICK, MD 21716
 SAMPLER'S NAME: CHRISTOPHER WILCOME

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
9	S23-017 3066 (HE)	BHS	Room 104 Home Economics	2	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 30, 2022 7:51
15	S23-062 3066 (OT)	BHS	Maintenance Office	2	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 30, 2022 8:17
17	W01A-01 3066 (DF) R	BHS	Aud Lobby Hi Lo	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 30, 2022 7:59
23	W01A-06 3066 (DF)	BHS	Main Hall at Main Office	2	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 30, 2022 7:48
24	W01A-06 3066 (DF) B	BHS	Main Hall at Main Office	2	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 30, 2022 7:49
33	W01A-11 3066 (DF)	BHS	Upstairs @ RM 200	2	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 30, 2022 7:56
39	W01B-14 3066 (DF)	BHS	In Rear Stairwell, 1st Floor	2	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 30, 2022 7:53