



Project: Frederick Co Schools

Analytical Results

Project Number: Hillcrest Elementary
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
10-Mar-22 15:38

Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K17-01 1022 (IM)	E069947-01	Kitchen	Lead	< 1.0	ug/L	3/9/2022 9:38:00AM	MAP
K31-06 1022 (KS)	E069947-02	Kitchen	Lead	4.7	ug/L	3/9/2022 9:38:00AM	MAP
K31-08 1022 (KS)	E069947-03	Kitchen	Lead	1.3	ug/L	3/9/2022 9:38:00AM	MAP
Portable 009-15-E13X15E069947-04		Pre-K portable	Lead	< 1.0	ug/L	3/9/2022 9:38:00AM	MAP
Portable 009-15-E13X15E069947-05		Pre-K portable	Lead	< 1.0	ug/L	3/9/2022 9:38:00AM	MAP
Portable 00915E13X150E069947-06		Pre-K portable	Lead	< 1.0	ug/L	3/9/2022 9:38:00AM	MAP
Portable 00915E13X150E069947-07		Pre-K portable	Lead	< 1.0	ug/L	3/9/2022 9:38:00AM	MAP
Portable 157-04E400T-VE069947-08		Parent Resource Center	Lead	< 1.0	ug/L	3/9/2022 9:38:00AM	MAP
Portable 162-14-E13X15E069947-09		4th and 5th grade Portable	Lead	< 1.0	ug/L	3/9/2022 9:38:00AM	MAP
Portable 162-14-E13X15E069947-10		4th and 5th grade Portable	Lead	< 1.0	ug/L	3/9/2022 9:38:00AM	MAP
Portable 162-14E13X15(E069947-11		4th and 5th grade Portable	Lead	< 1.0	ug/L	3/9/2022 9:38:00AM	MAP
Portable 162-14E13X15(E069947-12		4th and 5th grade Portable	Lead	< 1.0	ug/L	3/9/2022 9:38:00AM	MAP
Portable160-10E3X150TE069947-13		Cafeteria Portable	Lead	< 1.0	ug/L	3/9/2022 9:38:00AM	MAP
Portable160-10E3X150TE069947-14		Cafeteria Portable	Lead	< 1.0	ug/L	3/9/2022 9:38:00AM	MAP
Portable160-10E3X150TE069947-15		Cafeteria Portable	Lead	< 1.0	ug/L	3/9/2022 9:38:00AM	MAP
S23-11 1022 (NO)	E069947-16	Health Room	Lead	< 1.0	ug/L	3/9/2022 9:38:00AM	MAP
S23-14 1022 (TL)	E069947-17	Teacher Lounge	Lead	< 1.0	ug/L	3/9/2022 9:38:00AM	MAP
W01A-01 1022 (DF)	E069947-18	Expectation Expy/1st Grade Hall	Lead	< 1.0	ug/L	3/9/2022 9:38:00AM	MAP

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools

Analytical Results

Project Number: Hillcrest Elementary

Client Name: TIDEWATER

Project Manager: Meneka Rodrigo

Reported:

10-Mar-22 15:38

W01A-01 1022 (DF) B	E069947-19	Expectation Expy/1st Grade Hall	Lead	< 1.0	ug/L	3/9/2022	9:38:00AM	MAP
W01A-02 1022 (DF)	E069947-20	Expectation Expy.	Lead	< 1.0	ug/L	3/9/2022	9:38:00AM	MAP
W01A-03 1022 (DF)	E069947-21	Gym/Cafeteria	Lead	< 1.0	ug/L	3/9/2022	9:38:00AM	MAP
W01A-03 1022 (DF) B	E069947-22	Gym/Cafeteria	Lead	< 1.0	ug/L	3/9/2022	9:38:00AM	MAP
W01A-04 1022 (DF)	E069947-23	Excellence Ave.	Lead	< 1.0	ug/L	3/9/2022	9:38:00AM	MAP
W01A-05 1022 (DF)	E069947-24	Excellence Ave.	Lead	< 1.0	ug/L	3/9/2022	9:38:00AM	MAP
W01A-06 1022 (DF)	E069947-25	Winning Way	Lead	< 1.0	ug/L	3/9/2022	9:38:00AM	MAP
W01A-07 1022 (DF)	E069947-26	Winning Way	Lead	< 1.0	ug/L	3/9/2022	9:38:00AM	MAP
W01A-08 1022 (DF) L	E069947-27	Budding Blvd.	Lead	< 1.0	ug/L	3/9/2022	9:38:00AM	MAP
W01A-08 1022 (DF) R	E069947-28	Budding Blvd.	Lead	< 1.0	ug/L	3/9/2022	9:38:00AM	MAP

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools


Analytical Results

Project Number: Hillcrest Elementary
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
10-Mar-22 15:38

Notes and Definitions

DET Analyte DETECTED
ND Analyte NOT DETECTED at or above the reporting limit
NR Not Reported
dry Sample results reported on a dry weight basis
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

SITE: HILLCREST ELEMENTARY SCHOOL 1285 Hillcrest Drive, Frederick, MD 21703
 SAMPLER'S NAME: WALTER GONZALES

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1 ✓	K17-01 1022 (IM)	HES	Kitchen	3	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	March 8, 2022 4:18
2 ✓	K31-06 1022 (KS)	HES	Kitchen	3	D2010.60 Plumbing Fixture (Kitchen Sink)	March 8, 2022 4:20
3 ✓	K31-08 1022 (KS)	HES	Kitchen	3	D2010.60 Plumbing Fixture (Kitchen Sink)	March 8, 2022 4:20
4 ✓	Portable 009-15-E13X150T-W01A-01 (DF)	HES	Pre-K portable	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 4:22
5 ✓	Portable 009-15-E13X150T-W01A-01 (DF) B	HES	Pre-K portable	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 4:22
6 ✓	Portable 00915E13X150T-W01A-02 (DF) L	HES	Pre-K portable	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 4:22
7 ✓	Portable 00915E13X150T-W01A-02 (DF) R	HES	Pre-K portable	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 4:25
8 ✓	Portable 157-04E400T-W01A-01 (DF)	HES	4th and 5th grade Portable Pre-K portable Pc (Refrigerated Drinking Fountain)	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 4:25
9 ✓	Portable 162-14-E13X150T-W01A-01 (DF)	HES	4th and 5th grade Portable	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 4:35

609147

SITE: HILLCREST ELEMENTARY SCHOOL
 1285 Hillcrest Drive, Frederick, MD 21703
 SAMPLER'S NAME: WALTER GONZALES

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
10	Portable 162-14-E13X150T-W01A-01 (DF) B	HES	4th and 5th grade Portable	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 4:35
11	Portable 162-14E13X150T-W01A-02 (DF) L	HES	4th and 5th grade Portable	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 4:36
12	Portable 162-14E13X150T-W01A-02 (DF) R	HES	4th and 5th grade Portable	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 4:36
13	Portable 160-10E3X150T-W01A-01(DF) L	HES	Cafeteria Portable	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 4:47
14	Portable 160-10E3X150T-W01A-01(DF) R	HES	Cafeteria Portable	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 4:48
15	Portable 160-10E3X150T-W01A-01(DF) B	HES	Cafeteria Portable	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 4:48
16	S23-11 1022 (NO)	HES	Health Room	3	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 8, 2022 4:55
17	S23-14 1022 (TL)	HES	Teacher Lounge	3	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 8, 2022 4:55
18	W01A-01 1022 (DF)	HES	Expectation Expy/1st Grade Hall	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 4:57

SITE: HILLCREST ELEMENTARY SCHOOL **1285 Hillcrest Drive, Frederick, MD 21703**
SAMPLER'S NAME: WALTER GONZALES

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
19	W01A-01 1022 (DF) B	HES	Expectation Expy/1st Grade Hall	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 5:00
20	W01A-02 1022 (DF)	HES	Expectation Expy.	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 5:00
21	W01A-03 1022 (DF)	HES	Gym/Cafeteria	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 5:10
22	W01A-03 1022 (DF) B	HES	Gym/Cafeteria	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 5:10
23	W01A-04 1022 (DF)	HES	Excellence Ave.	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 5:20
24	W01A-05 1022 (DF)	HES	Excellence Ave.	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 5:20
25	W01A-06 1022 (DF)	HES	Winning Way	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 5:30
26	W01A-07 1022 (DF)	HES	Winning Way	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 5:30
27	W01A-08 1022 (DF) L	HES	Budding Blvd.	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 5:35

SITE: HILLCREST ELEMENTARY SCHOOL **1285 Hillcrest Drive, Frederick, MD 21703**
SAMPLER'S NAME: WALTER GONZALES

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
28	W01A-08 1022 (DF) R	HES	Budding Blvd.	3	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 8, 2022 5:45