



Project: Frederick Co Schools

Analytical Results

Project Number: Monocacy Middle School
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
07-Apr-22 14:20

Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K17-01 2016 (IM)	E070253-01	Kitchen	Lead	< 1.0	ug/L	4/6/2022 2:17:40PM	MAP
K31-04 2016 (KS)	E070253-02	Kitchen	Lead	1.5	ug/L	4/6/2022 2:21:14PM	MAP
S23-14 2016 (HE)	E070253-03	B62/Home Ec	Lead	< 1.0	ug/L	4/6/2022 2:31:56PM	MAP
S23-15 2016 (HE)	E070253-04	B62/Home Ec	Lead	< 1.0	ug/L	4/6/2022 2:35:29PM	MAP
S23-16 2016 (HE)	E070253-05	B62/Home Ec	Lead	< 1.0	ug/L	4/6/2022 2:39:04PM	MAP
S23-17 2016 (HE)	E070253-06	B62/Home Ec	Lead	2.6	ug/L	4/6/2022 2:42:38PM	MAP
S23-18 2016 (HE)	E070253-07	B62/Home Ec	Lead	< 1.0	ug/L	4/6/2022 2:46:13PM	MAP
S23-19 2016 (HE)	E070253-08	B62/Home Ec	Lead	52.6	ug/L	4/6/2022 2:56:56PM	MAP
S23-25 2016 (NO)	E070253-09	Nurses Office B/R, see map	Lead	< 1.0	ug/L	4/6/2022 3:00:31PM	MAP
S23-26 2016 (NO)	E070253-10	Nurses Office B/R, see map	Lead	< 1.0	ug/L	4/6/2022 3:04:07PM	MAP
S23-86 2016 (TL)	E070253-11	A63/Teacher's Lounge	Lead	< 1.0	ug/L	4/6/2022 3:07:41PM	MAP
W01A-01 2016 (DF)	E070253-12	C-1 Hallway	Lead	< 1.0	ug/L	4/6/2022 3:18:24PM	MAP
W01A-02 2016 (DF)	E070253-13	C-1 Hallway	Lead	< 1.0	ug/L	4/6/2022 3:21:58PM	MAP
W01A-03 2016 (DF) L-RE070253-14		A3 Hallway	Lead	< 1.0	ug/L	4/6/2022 3:25:32PM	MAP
W01A-03 2016 (DF) L-RE070253-15		A3 Hallway	Lead	< 1.0	ug/L	4/6/2022 3:29:07PM	MAP
W01A-03 2016 (DF) L-RE070253-16		A3 Hallway	Lead	< 1.0	ug/L	4/6/2022 3:39:50PM	MAP
W01A-05 2016 (DF) L-RE070253-17		A5 Hallway By Media	Lead	< 1.0	ug/L	4/6/2022 3:43:25PM	MAP
W01A-05 2016 (DF) L-RE070253-18		A5 Hallway By Media	Lead	< 1.0	ug/L	4/6/2022 3:47:00PM	MAP

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools

Analytical Results

Project Number: Monocacy Middle School
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
07-Apr-22 14:20

W01A-07 2016 (DF) L-RE070253-19	B2 Hallway By Lobby	Lead	< 1.0	ug/L	4/6/2022	3:50:35PM	MAP
W01A-07 2016 (DF) L-RE070253-20	B2 Hallway By Lobby	Lead	< 1.0	ug/L	4/6/2022	3:54:10PM	MAP
W01A-07 2016 (DF) L-RE070253-21	B2 Hallway By Lobby	Lead	< 1.0	ug/L	4/6/2022	4:01:19PM	MAP
W01A-09 2016 (DF) E070253-22	Room C43	Lead	2.7	ug/L	4/6/2022	4:12:03PM	MAP
W01A-10 2016 (DF) E070253-23	Room C48	Lead	< 1.0	ug/L	4/6/2022	4:22:47PM	MAP
W01A-11 2016 (DF) E070253-24	Girl's Locker Room	Lead	< 1.0	ug/L	4/6/2022	4:26:21PM	MAP
W01A-13 2016 (DF) L-RE070253-25	Cafeteria	Lead	< 1.0	ug/L	4/6/2022	4:29:56PM	MAP
W01A-13 2016 (DF) L-RE070253-26	Cafeteria	Lead	< 1.0	ug/L	4/6/2022	4:33:31PM	MAP
W01A-13 2016 (DF) L-RE070253-27	Cafeteria	Lead	< 1.0	ug/L	4/6/2022	4:37:06PM	MAP
W01B-09 2016 (DF) E070253-28	Outside Storage Room C23	Lead	< 1.0	ug/L	4/6/2022	4:40:41PM	MAP

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools


Analytical Results

Project Number: Monocacy Middle School
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
07-Apr-22 14:20

Notes and Definitions

DET Analyte DETECTED
ND Analyte NOT DETECTED at or above the reporting limit
NR Not Reported
dry Sample results reported on a dry weight basis
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

SITE: MONOCACY MIDDLE SCHOOL 8009 Opossumtown Pike, Frederick, MD 21702
 SAMPLER'S NAME: DUREKA ALUWHARE

70253

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1	K17-01 2016 (IM)	MOMS	Kitchen	4	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	April 5, 2022 4:10
2	K31-04 2016 (KS)	MOMS	Kitchen	4	D2010.60 Plumbing Fixture (Kitchen Sink)	April 5, 2022 4:10
3	S23-14 2016 (HE)	MOMS	B62/Home Ec	4	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 5, 2022 4:18
4	S23-15 2016 (HE)	MOMS	B62/Home Ec	4	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 5, 2022 4:18
5	S23-16 2016 (HE)	MOMS	B62/Home Ec	4	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 5, 2022 4:18
6	S23-17 2016 (HE)	MOMS	B62/Home Ec	4	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 5, 2022 4:19
7	S23-18 2016 (HE)	MOMS	B62/Home Ec	4	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 5, 2022 4:19
8	S23-19 2016 (HE)	MOMS	B62/Home Ec	4	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 5, 2022 4:19
9	S23-25 2016 (NO)	MOMS	Nurses Office B/R, see map	4	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 5, 2022 4:25
10	S23-26 2016 (NO)	MOMS	Nurses Office B/R, see map	4	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 5, 2022 4:25

SITE: MONOCACY MIDDLE SCHOOL 8009 Opossumtown Pike, Frederick, MD 21702
 SAMPLER'S NAME: DUREKA ALUWHARE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
11	WS23-86 2016 (TL)	MOMS	A63/Teacher's Lounge	4	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 5, 2022 4:24
12	WO1A-01 2016 (DF)	MOMS	C-1 Hallway	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 5, 2022 4:30
13	WO1A-02 2016 (DF)	MOMS	C-1 Hallway	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 5, 2022 4:30
14	WO1A-03 2016 (DF) L-R-B (left)	MOMS	A3 Hallway	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 5, 2022 4:40
15	WO1A-03 2016 (DF) L-R-B (right)	MOMS	A3 Hallway	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 5, 2022 4:40
16	WO1A-03 2016 (DF) L-R-B (bottle filler)	MOMS	A3 Hallway	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 5, 2022 4:40
17	WO1A-05 2016 (DF) L-R (left)	MOMS	A5 Hallway By Media	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 5, 2022 4:42
18	WO1A-05 2016 (DF) L-R (right)	MOMS	A5 Hallway By Media	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 5, 2022 4:42
19	WO1A-07 2016 (DF) L-R-B (left)	MOMS	B2 Hallway By Lobby	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 5, 2022 4:45
20	WO1A-07 2016 (DF) L-R-B (right)	MOMS	B2 Hallway By Lobby	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 5, 2022 4:45

SITE: MONOCACY MIDDLE SCHOOL 8009 Opossumtown Pike, Frederick, MD 21702
 SAMPLER'S NAME: DUREKA ALUWHARE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
21	W01A-07 2016 (DF) L-R-B (bottle filler)	MOMS	B2 Hallway By Lobby	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 5, 2022 4:45
22	W01A-09 2016 (DF)	MOMS	Room C43	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 5, 2022 4:50
23	W01A-10 2016 (DF)	MOMS	Room C48	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 5, 2022 4:50
24	W01A-11 2016 (DF)	MOMS	Girls Locker Room	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 5, 2022 4:55
25	W01A-13 2016 (DF) L-R-B (left)	MOMS	Cafeteria	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 5, 2022 5:02
26	W01A-13 2016 (DF) L-R-B (right)	MOMS	Cafeteria	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 5, 2022 5:02
27	W01A-13 2016 (DF) L-R-B (bottle filler)	MOMS	Cafeteria	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 5, 2022 5:02
28	W01B-09 2016 (DF)	MOMS	Outside Storage Room C23	4	D2010.60 Plumbing Fixture (Non-Refrigerated Drinking Fountain)	April 5, 2022 5:07

Client: Frederick County Public Schools
ATTN: Accounts Payable 191 South East St
Frederick, MD 21701

Project: Monocacy Middle School
April 2022

Site: Monocacy Middle School
8009 Opossumtown Pike
Frederick, MD 21702

Work order: FWD0290

Received at lab: 04/12/22 11:01
Date Reported: 04/13/22 16:20
Collected by: Marc Angleberger, ID: 0659MA
Treatment: N/A


Source: S23-19-2016 HE

(Drinking Water)(Grab - Flushed)

Collected: 4/12/2022 5:28:00AM

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	Prepared	Analyzed	Analyst	Qual	Method
FWD0290-01	Lead	<5	ppb	5	04/13/22 09:32	04/13/22 11:36	KMW		SM3113-B


Sara E. Randall, President

*Fredericktowne Labs, Inc. is a State Certified Water Quality Laboratory
Maryland Cert. No. 116 Virginia Cert. No. 00444
West Virginia Cert. 415 MDOT WBE Cert. No.: 91-158*

