



Project: Frederick Co Schools

Analytical Results

Project Number: North Frederick Elementary School
 Client Name: TIDEWATER
 Project Manager: Meneka Rodrigo

Reported:
 29-Mar-22 09:33

Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K17-01 1010 (IM)	E070157-01	Kitchen	Lead	< 1.0	ug/L	3/26/2022 1:22:54PM	SES
K31-03 1010 (KS)	E070157-02	Stainless By Kitchen Office	Lead	< 1.0	ug/L	3/26/2022 1:26:45PM	SES
S23-002 1010 (NO)	E070157-03	Health A102	Lead	< 1.0	ug/L	3/26/2022 1:38:14PM	SES
S23-006 1010 (TL)	E070157-04	Lounge A113	Lead	< 1.0	ug/L	3/26/2022 1:42:05PM	SES
S23-081 1010 (TL)	E070157-05	B208	Lead	< 1.0	ug/L	3/26/2022 1:45:57PM	SES
W01A-01 1010 (DF) L-RE070157-06		A Wing 1st Floor	Lead	< 1.0	ug/L	3/26/2022 1:49:44PM	SES
W01A-01 1010 (DF) L-RE070157-07		A Wing 1st Floor	Lead	4.6	ug/L	3/26/2022 5:27:21PM	SES
W01A-01 1010 (DF) L-RE070157-08		A Wing 1st Floor	Lead	< 1.0	ug/L	3/26/2022 2:04:56PM	SES
W01A-02 1010 (DF) L-RE070157-09		A Wing 2nd Floor	Lead	< 1.0	ug/L	3/26/2022 2:08:44PM	SES
W01A-02 1010 (DF) L-RE070157-10		A Wing 2nd Floor	Lead	< 1.0	ug/L	3/26/2022 2:12:34PM	SES
W01A-03 1010 (DF) L-RE070157-11		B Wing 1st Floor	Lead	< 1.0	ug/L	3/26/2022 2:24:02PM	SES
W01A-03 1010 (DF) L-RE070157-12		B Wing 1st Floor	Lead	< 1.0	ug/L	3/26/2022 2:27:51PM	SES
W01A-04 1010 (DF) L-RE070157-13		B Wing 2nd Floor	Lead	< 1.0	ug/L	3/26/2022 2:31:41PM	SES
W01A-04 1010 (DF) L-RE070157-14		B Wing 2nd Floor	Lead	< 1.0	ug/L	3/26/2022 2:35:32PM	SES
W01A-04 1010 (DF) L-RE070157-15		B Wing 2nd Floor	Lead	< 1.0	ug/L	3/26/2022 2:39:22PM	SES
W01A-05 1010 (DF) L-RE070157-16		1st Floor by Elevator	Lead	< 1.0	ug/L	3/26/2022 2:43:10PM	SES
W01A-05 1010 (DF) L-RE070157-17		1st Floor by Elevator	Lead	< 1.0	ug/L	3/26/2022 2:50:45PM	SES
W01A-05 1010 (DF) L-RE070157-18		1st Floor by Elevator	Lead	< 1.0	ug/L	3/26/2022 3:09:49PM	SES

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools

Analytical Results

Project Number: North Frederick Elementary School

Client Name: TIDEWATER

Project Manager: Meneka Rodrigo

Reported:

29-Mar-22 09:33

W01A-06 1010 (DF) L-RE070157-19	Gym	Lead	< 1.0	ug/L	3/26/2022	3:13:38PM	SES
W01A-06 1010 (DF) L-RE070157-20	Gym	Lead	< 1.0	ug/L	3/26/2022	3:17:27PM	SES
W01A-07 1010 (BF) E070157-21	Cafeteria	Lead	< 1.0	ug/L	3/26/2022	3:21:16PM	SES

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools


Analytical Results

Project Number: North Frederick Elementary School
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
29-Mar-22 09:33

Notes and Definitions

DET Analyte DETECTED
ND Analyte NOT DETECTED at or above the reporting limit
NR Not Reported
dry Sample results reported on a dry weight basis
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

SITE: NORTH FREDERICK ELEMENTARY SCHOOL 1010 Fairview Avenue, Frederick, MD 21701
 SAMPLER'S NAME: DUREKA ALUWHARE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1	K17-01 1010 (IM)	NFES	Kitchen	4	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	March 25, 2022 4:03
2	K31-03 1010 (KS)	NFES	Stainless By Kitchen Office	4	D2010.60 Plumbing Fixture (Kitchen Sink)	March 25, 2022 4:05
3	S23-002 1010 (NO)	NFES	Health A102	4	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 25, 2022 4:10
4	S23-006 1010 (TL)	NFES	Lounge A113	4	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 25, 2022 4:12
5	S23-081 1010 (TL)	NFES	B208	4	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 25, 2022 4:17
6	W01A-01 1010 (DF) L-R-B (left)	NFES	A Wing 1st Floor	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 25, 2022 4:20
7	W01A-01 1010 (DF) L-R-B (right)	NFES	A Wing 1st Floor	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 25, 2022 4:20
8	W01A-01 1010 (DF) L-R-B (bottle filler)	NFES	A Wing 1st Floor	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 25, 2022 4:20
9	W01A-02 1010 (DF) L-R (left)	NFES	A Wing 2nd Floor	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 25, 2022 4:25
10	W01A-02 1010 (DF) L-R (right)	NFES	A Wing 2nd Floor	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 25, 2022 4:25

70157

SITE: NORTH FREDERICK ELEMENTARY SCHOOL 1010 Fairview Avenue, Frederick, MD 21701
 SAMPLERS NAME: DUREKA ALLUWHARE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
11 ✓	W01A-03 1010 (DF) L-R (left)	NFES	B Wing 1st Floor	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 25, 2022 4:30
12 ✓	W01A-03 1010 (DF) L-R (right)	NFES	B Wing 1st Floor	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 25, 2022 4:30
13 ✓	W01A-04 1010 (DF) L-R-B (left)	NFES	B Wing 2nd Floor	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 25, 2022 4:40
14 ✓	W01A-04 1010 (DF) L-R-B (right)	NFES	B Wing 2nd Floor	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 25, 2022 4:40
15 ✓	W01A-04 1010 (DF) L-R-B (bottle filler)	NFES	B Wing 2nd Floor	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 25, 2022 4:40
16 ✓	W01A-05 1010 (DF) L-R-B (left)	NFES	1st Floor by Elevator	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 25, 2022 4:45
17 ✓	W01A-05 1010 (DF) L-R-B (right)	NFES	1st Floor by Elevator	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 25, 2022 4:45
18 ✓	W01A-05 1010 (DF) L-R-B (bottle filler)	NFES	1st Floor by Elevator	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 25, 2022 4:45
19 ✓	W01A-06 1010 (DF) L-R (left)	NFES	Gym	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 25, 2022 4:50
20 ✓	W01A-06 1010 (DF) L-R (right)	NFES	Gym	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 25, 2022 4:50

SITE: NORTH FREDERICK ELEMENTARY SCHOOL 1010 Fairview Avenue, Frederick, MD 21701
 SAMPLER'S NAME: DUREKA ALLUWHARE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
21	W01A-07 1010 (BF)	NFES	Cafeteria	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 25, 2022 4:55