



Project: Frederick Co Schools

Analytical Results

Project Number: Oakdale Elementary School

Client Name: TIDEWATER

Project Manager: Meneka Rodrigo

Reported:

18-Apr-22 14:36

Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K17-01 1080 (IM)	E070357-01	Kitchen	Lead	< 1.0	ug/L	4/15/2022 12:24:40PM	RAS
K31-03 1080 (KS)	E070357-02	Kitchen	Lead	< 1.0	ug/L	4/15/2022 12:35:23PM	RAS
K31-04 1080 (KS)	E070357-03	Kitchen	Lead	6.4	ug/L	4/15/2022 12:38:57PM	RAS
S23-71 1080 (NO)	E070357-04	Room 208/Health Room	Lead	< 1.0	ug/L	4/15/2022 12:42:32PM	RAS
S23-73 1080 (TL)	E070357-05	Room 212 Teacher Lounge	Lead	< 1.0	ug/L	4/15/2022 12:46:08PM	RAS
W01A-01 1080 (DF)	E070357-06	Pre- Kindergarten / By Elev. 1st Floor	Lead	< 1.0	ug/L	4/15/2022 12:49:43PM	RAS
W01A-02 1080 (DF)	E070357-07	Corridor Room 325	Lead	< 1.0	ug/L	4/15/2022 1:00:28PM	RAS
W01A-03 1080 (DF)	E070357-08	By Elev. 2nd Floor	Lead	< 1.0	ug/L	4/15/2022 1:04:04PM	RAS
W01A-04 1080 (DF)	E070357-09	By Gym Restroom	Lead	< 1.0	ug/L	4/15/2022 1:07:41PM	RAS
W01A-05 1080 (DF)	E070357-10	By Gym Restroom	Lead	< 1.0	ug/L	4/15/2022 1:11:13PM	RAS
W01A-06 1080 (DF)	E070357-11	2nd Floor / By 426	Lead	< 1.0	ug/L	4/15/2022 1:14:45PM	RAS
W01A-07 1080 (DF)	E070357-12	1st Floor / New Addition	Lead	< 1.0	ug/L	4/15/2022 1:25:25PM	RAS
W01A-07 1080 (DF) B	E070357-13	1st Floor / New Addition	Lead	< 1.0	ug/L	4/15/2022 1:28:59PM	RAS
W01A-08 1080 (DF)	E070357-14	1st Floor / New Addition	Lead	< 1.0	ug/L	4/15/2022 1:32:33PM	RAS
W01A-09 1080 (DF)	E070357-15	2nd Floor / New Addition	Lead	< 1.0	ug/L	4/15/2022 1:43:16PM	RAS
W01A-10 1080 (DF)	E070357-16	2nd Floor / New Addition	Lead	< 1.0	ug/L	4/15/2022 1:46:50PM	RAS
W01A-10 1080 (DF) B	E070357-17	2nd Floor / New Addition	Lead	< 1.0	ug/L	4/15/2022 1:54:00PM	RAS
W01A-11 1080 (DF)	E070357-18	By Gym Office	Lead	< 1.0	ug/L	4/15/2022 1:57:36PM	RAS

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.




Project: Frederick Co Schools

Analytical Results

Project Number: Oakdale Elementary School
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
18-Apr-22 14:36

W01A-12 1080 (DF)	E070357-19	By Gym Office	Lead	< 1.0	ug/L	4/15/2022	2:01:08PM	RAS
-------------------	------------	---------------	------	-------	------	-----------	-----------	-----



Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools


Analytical Results

Project Number: Oakdale Elementary School
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
18-Apr-22 14:36

Notes and Definitions

DET Analyte DETECTED
ND Analyte NOT DETECTED at or above the reporting limit
NR Not Reported
dry Sample results reported on a dry weight basis
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

SITE: OAKDALE ELEMENTARY SCHOOL 5830 Oakdale School Road, Jiamsville, MD 21754
 SAMPLER'S NAME: Dureka Aluwihare

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1	K17-01 1080 (IM)	OES	Kitchen	8	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	April 14, 2022 5:10
2	K31-03 1080 (KS)	OES	Kitchen	8	D2010.60 Plumbing Fixture (Kitchen Sink)	April 14, 2022 5:12
3	K31-04 1080 (KS)	OES	Kitchen	8	D2010.60 Plumbing Fixture (Kitchen Sink)	April 14, 2022 5:12
4	S23-71 1080 (NO)	OES	Room 208/Health Room	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 14, 2022 5:15
5	S23-73 1080 (TL)	OES	Room 212 Teacher Lounge	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 14, 2022 5:20
6	W01A-01 1080 (DF)	OES	Pre- Kindergarten / By Elev. 1st Floor	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 5:22
7	W01A-02 1080 (DF)	OES	Corridor Room 325	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 5:25
8	W01A-03 1080 (DF)	OES	By Elev. 2nd Floor	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 5:40
9	W01A-04 1080 (DF)	OES	By Gym Restroom	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 5:45

20357
1 of 3

SITE: OAKDALE ELEMENTARY SCHOOL 5830 Oakdale School Road, Ijamsville, MD 21754
 SAMPLER'S NAME: Dureka Aluwihare


No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
10	W01A-05 1080 (DF)	OES	By Gym Restroom	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 S: 45
11	W01A-06 1080 (DF)	OES	2nd Floor / By 426	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 S: 37
12	W01A-07 1080 (DF)	OES	1st Floor / New Addition	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 S: 30
13	W01A-07 1080 (DF) B	OES	1st Floor / New Addition	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 S: 30
14	W01A-08 1080 (DF)	OES	1st Floor / New Addition	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 S: 30
15	W01A-09 1080 (DF)	OES	2nd Floor / New Addition	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 S: 35
16	W01A-10 1080 (DF)	OES	2nd Floor / New Addition	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 S: 35
17	W01A-10 1080 (DF) B	OES	2nd Floor / New Addition	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 S: 35
18	W01A-11 1080 (DF)	OES	By Gym Office	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 S: 48

2022
2022

20357
3 of 3

SITE: OAKDALE ELEMENTARY SCHOOL 5830 Oakdale School Road, Jamsville, MD 21754
SAMPLER'S NAME: Dureka Aluwihare

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
19	W01A-12 1080 (DF)	OES	By Gym Office	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 5:48


Dureka Aluwihare 4/14/22