



Project: Frederick Co Schools

Analytical Results

Project Number: Spring Ridge Elementary
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
23-Mar-22 14:29

Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K17-01 1007 (IM)	E070085-01	Kitchen	Lead	< 1.0	ug/L	3/19/2022 10:35:09AM	SES
K31-06 1007 (KS)	E070085-02	Kitchen Prep Area	Lead	< 1.0	ug/L	3/19/2022 10:38:42AM	SES
S23-16 1007 (TL)	E070085-03	Teacher Lounge	Lead	< 1.0	ug/L	3/19/2022 10:49:25AM	SES
S23-23 1007 (NO)	E070085-04	Health Room	Lead	< 1.0	ug/L	3/19/2022 10:53:00AM	SES
W01A-01 1007 (DF)	E070085-05	Gym Corridor	Lead	< 1.0	ug/L	3/19/2022 10:56:35AM	SES
W01A-02 1007 (DF)	E070085-06	Main Entrance Lobby	Lead	< 1.0	ug/L	3/19/2022 11:00:11AM	SES
W01A-02 1007 (DF) B	E070085-07	Main Entrance Lobby	Lead	< 1.0	ug/L	3/19/2022 11:10:55AM	SES
W01A-03 1007 (DF)	E070085-08	Main Entrance Lobby	Lead	< 1.0	ug/L	3/19/2022 11:14:31AM	SES
W01A-04 1007 (DF)	E070085-09	B Corridor / 100 Hallway	Lead	< 1.0	ug/L	3/19/2022 11:18:08AM	SES
W01A-04 1007 (DF) B	E070085-10	B Corridor / 100 Hallway	Lead	1.2	ug/L	3/19/2022 11:21:40AM	SES
W01A-05 1007 (DF)	E070085-11	D Corridor / 200 Hallway	Lead	< 1.0	ug/L	3/19/2022 11:25:12AM	SES
W01A-06 1007 (DF)	E070085-12	C Corridor / 300 Hallway	Lead	< 1.0	ug/L	3/19/2022 11:35:51AM	SES
W01A-06 1007 (DF) B	E070085-13	C Corridor / 300 Hallway	Lead	< 1.0	ug/L	3/19/2022 11:39:25AM	SES

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools


Analytical Results

Project Number: Spring Ridge Elementary
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
23-Mar-22 14:29

Notes and Definitions

DET Analyte DETECTED
ND Analyte NOT DETECTED at or above the reporting limit
NR Not Reported
dry Sample results reported on a dry weight basis
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

SITE: SPRING RIDGE ELEMENTARY SCHOOL 9051 Ridgely Drive, Frederick, MD 21701
 SAMPLER'S NAME: PHILLIP RANKINE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1	K17-01 1007 (IM)	SRES	Kitchen	8	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	March 18, 2022 4:59
2	K31-06 1007 (KS)	SRES	Kitchen Prep Area	8	D2010.60 Plumbing Fixture (Kitchen Sink)	March 18, 2022 4:52
3	S23-16 1007 (TL)	SRES	Teacher Lounge	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 18, 2022 5:09
4	S23-23 1007 (NO)	SRES	Health Room	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 18, 2022 5:09
5	W01A-01 1007 (DF)	SRES	Gym Corridor	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 18, 2022 5:01
6	W01A-02 1007 (DF)	SRES	Main Entrance Lobby	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 18, 2022 5:03
7	W01A-02 1007 (DF) B	SRES	Main Entrance Lobby	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 18, 2022 5:04
8	W01A-03 1007 (DF)	SRES	Main Entrance Lobby	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 18, 2022 5:05
9	W01A-04 1007 (DF)	SRES	B Corridor / 100 Hallway	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 18, 2022 5:10
10	W01A-04 1007 (DF) B	SRES	B Corridor / 100 Hallway	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 18, 2022 5:11

70888

SITE: SPRING RIDGE ELEMENTARY SCHOOL 9051 Ridgely Drive, Frederick, MD 21701

SAMPLER'S NAME: PHILLIP RANKINE

Handwritten initials

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
11	W01A-05 1007 (DF)	SRES	D Corridor / 200 Hallway	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 18, 2022 <i>S: 13</i>
12	W01A-06 1007 (DF)	SRES	C Corridor / 300 Hallway	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 18, 2022 <i>S: 15</i>
13	W01A-06 1007 (DF) B	SRES	C Corridor / 300 Hallway	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 18, 2022 <i>S: 16</i>

Handwritten signature: Phillip Rankine

301 3329094