



Project: Frederick Co Schools

Analytical Results

Project Number: Tuscarora HS
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
08-Feb-22 11:32

Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K17-01 3077 (IM)	E069614-01	Kitchen	Lead	< 1.0	ug/L	2/7/2022 1:51:28PM	SES
K17-04 3077 (IM)	E069614-02	Maintenance Area	Lead	< 1.0	ug/L	2/7/2022 1:55:00PM	SES
K17-07 3077 (IM)	E069614-03	A113	Lead	< 1.0	ug/L	2/7/2022 1:58:33PM	SES
K17-08 3077 (IM)	E069614-04	B130/Home Ec	Lead	< 1.0	ug/L	2/7/2022 2:05:38PM	SES
K17-09 3077 (IM)	E069614-05	Mail Room	Lead	< 1.0	ug/L	2/7/2022 2:23:28PM	SES
K31-08 3077 (KS)	E069614-06	Kitchen	Lead	1.4	ug/L	2/7/2022 2:27:02PM	SES
K31-09 3077 (KS)	E069614-07	Kitchen	Lead	3.7	ug/L	2/7/2022 2:30:36PM	SES
S23-001 3077 (NO)	E069614-08	A101	Lead	1.1	ug/L	2/7/2022 2:34:11PM	SES
S23-037 3077 (TL)	E069614-09	A157	Lead	1.4	ug/L	2/7/2022 2:37:46PM	SES
S23-038 3077 (OT)	E069614-10	A162	Lead	< 1.0	ug/L	2/7/2022 2:41:21PM	SES
S23-136 3077 (HE)	E069614-11	B130/Home Ec	Lead	1.0	ug/L	2/7/2022 2:44:54PM	SES
S23-137 3077 (HE)	E069614-12	B130/Home Ec	Lead	< 1.0	ug/L	2/7/2022 2:48:27PM	SES
S23-138 3077 (HE)	E069614-13	B130/Home Ec	Lead	< 1.0	ug/L	2/7/2022 2:52:00PM	SES
S23-139 3077 (HE)	E069614-14	B130/Home Ec	Lead	1.9	ug/L	2/7/2022 3:02:42PM	SES
S23-140 3077 (HE)	E069614-15	B130/Home Ec	Lead	1.2	ug/L	2/7/2022 3:13:22PM	SES
S23-141 3077 (HE)	E069614-16	B130/Home Ec	Lead	1.2	ug/L	2/7/2022 3:16:57PM	SES
S23-142 3077 (HE)	E069614-17	B130	Lead	< 1.0	ug/L	2/7/2022 3:20:31PM	SES
S23-204 3077 (TL)	E069614-18	A249	Lead	1.2	ug/L	2/7/2022 3:24:06PM	SES

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools

Analytical Results

Project Number: Tuscarora HS
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
08-Feb-22 11:32

S23-245 3077 (OT)	E069614-19	A113	Lead	< 1.0	ug/L	2/7/2022	3:27:40PM	SES
S23-247 3077 (OT)	E069614-20	D127	Lead	1.9	ug/L	2/7/2022	3:31:16PM	SES
S23-248 3077 (OT)	E069614-21	Mail Room	Lead	< 1.0	ug/L	2/7/2022	3:34:49PM	SES
S23-249 3077 (TL)	E069614-22	D115	Lead	3.6	ug/L	2/7/2022	3:45:32PM	SES
W01A-01 3077 (DF)	E069614-23	Room D107	Lead	< 1.0	ug/L	2/7/2022	3:49:05PM	SES
W01A-02 3077 (DF)	E069614-24	Room D103	Lead	< 1.0	ug/L	2/7/2022	3:56:12PM	SES
W01A-03 3077 (DF)	E069614-25	Main St Outside Auditorium	Lead	< 1.0	ug/L	2/7/2022	4:06:54PM	SES
W01A-04 3077 (DF)	L-FE069614-26	Main St By Cafeteria	Lead	< 1.0	ug/L	2/7/2022	4:10:29PM	SES
W01A-04 3077 (DF)	L-FE069614-27	Main St By Cafeteria	Lead	< 1.0	ug/L	2/7/2022	4:14:03PM	SES
W01A-04 3077 (DF)	L-FE069614-28	Main St By Cafeteria	Lead	< 1.0	ug/L	2/7/2022	4:17:39PM	SES
W01A-05 3077 (DF)	L-FE069614-29	Corridor 21 By Girl's Locker Room	Lead	< 1.0	ug/L	2/7/2022	4:28:23PM	SES
W01A-05 3077 (DF)	L-FE069614-30	Corridor 21 By Girl's Locker Room	Lead	< 1.0	ug/L	2/7/2022	4:31:58PM	SES
W01A-06 3077 (DF)	L-FE069614-31	Corridor 21 By Boy's Locker Room	Lead	< 1.0	ug/L	2/7/2022	4:35:31PM	SES
W01A-06 3077 (DF)	L-FE069614-32	Corridor 21 By Boy's Locker Room	Lead	< 1.0	ug/L	2/7/2022	4:39:05PM	SES
W01A-07 3077 (DF)	L-FE069614-33	Green Hallway 1st Floor By Restroom	Lead	< 1.0	ug/L	2/7/2022	4:42:40PM	SES
W01A-07 3077 (DF)	L-FE069614-34	Green Hallway 1st Floor By Restroom	Lead	< 1.0	ug/L	2/7/2022	4:46:13PM	SES
W01A-08 3077 (DF)	L-FE069614-35	Corridor 12 Blue Hallway 1st Floor By	Lead	< 1.0	ug/L	2/7/2022	4:56:56PM	SES
W01A-08 3077 (DF)	L-FE069614-36	Corridor 12 Blue Hallway 1st Floor By	Lead	< 1.0	ug/L	2/7/2022	5:00:30PM	SES
W01A-08 3077 (DF)	L-FE069614-37	Corridor 12 Blue Hallway 1st Floor By	Lead	< 1.0	ug/L	2/7/2022	5:11:15PM	SES
W01A-09 3077 (DF)	L-FE069614-38	Blue Hallway By A147	Lead	< 1.0	ug/L	2/7/2022	5:14:50PM	SES
W01A-09 3077 (DF)	L-FE069614-39	Blue Hallway By A147	Lead	< 1.0	ug/L	2/7/2022	5:18:26PM	SES

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools

Analytical Results

Project Number: Tuscarora HS
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
08-Feb-22 11:32

W01A-10 3077 (DF) L-RE069614-40	Red Hallway By A270	Lead	< 1.0	ug/L	2/7/2022	5:22:00PM	SES
W01A-10 3077 (DF) L-RE069614-41	Red Hallway By A270	Lead	< 1.0	ug/L	2/7/2022	5:25:34PM	SES
W01A-12 3077 (DF) L-FE069614-42	Red Hallway By Restrooms A250	Lead	< 1.0	ug/L	2/7/2022	5:29:08PM	SES
W01A-12 3077 (DF) L-FE069614-43	Red Hallway By Restrooms A250	Lead	< 1.0	ug/L	2/7/2022	5:32:42PM	SES
W01A-12 3077 (DF) L-FE069614-44	Red Hallway By Restrooms A250	Lead	< 1.0	ug/L	2/7/2022	5:39:50PM	SES
W01A-13 3077 (DF) L-RE069614-45	Yellow Hallway By Restroom A246	Lead	< 1.0	ug/L	2/7/2022	5:57:42PM	SES
W01A-13 3077 (DF) L-FE069614-46	Yellow Hallway By Restroom A246	Lead	< 1.0	ug/L	2/7/2022	6:01:17PM	SES

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools


Analytical Results

Project Number: Tuscarora HS
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
08-Feb-22 11:32

Notes and Definitions

DET Analyte DETECTED
ND Analyte NOT DETECTED at or above the reporting limit
NR Not Reported
dry Sample results reported on a dry weight basis
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

SITE: TUSCARORA HIGH SCHOOL 5312 BALLENGER CREEK PIKE, #7008, FREDERICK, MD 21703
 SAMPLER'S NAME: CHERUKA WEERAKOON

	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
✓	K17-01 3077 (IM)	THS	Kitchen	6	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	February 4, 2022 4:42 am
✓	K17-04 3077 (IM)	THS	Maintenance Area	6	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	February 4, 2022 5:42 am
✓	K17-07 3077 (IM)	THS	A113	6	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	February 4, 2022 4:57 am
✓	K17-08 3077 (IM)	THS	B130/Home Ec	6	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	February 4, 2022 5:48 am
✓	K17-09 3077 (IM)	THS	Mail Room	6	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	February 4, 2022 5:56 am
✓	K31-08 3077 (KS)	THS	Kitchen	6	D2010.60 Plumbing Fixture (Kitchen Sink)	February 4, 2022 6:39 am
✓	K31-09 3077 (KS)	THS	Kitchen	6	D2010.60 Plumbing Fixture (Kitchen Sink)	February 4, 2022 6:41 am
✓	S23-001 3077 (NO)	THS	A101	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 4, 2022 5:04 am
✓	S23-037 3077 (TL)	THS	A157	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 4, 2022 4:14 am
✓	S23-038 3077 (HE) (HE COT)	THS	A162	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 4, 2022 4:16 am
✓	S23-136 3077 (HE)	THS	B130/Home Ec	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 4, 2022 4:05 am

SITE: TUSCARORA HIGH SCHOOL 5312 BALLENGER CREEK PIKE, #7008, FREDERICK, MD 21703
 SAMPLER'S NAME: CHERUKA WEERAKOON

Name	Site	Area-Room number	Area	Category	Sampling Date and Time
S23-137 3077 (HE)	THS	B130/Home Ec	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 4, 2022 4:06 am
S23-138 3077 (HE)	THS	B130/Home Ec	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 4, 2022 4:07 am
S23-139 3077 (HE)	THS	B130/Home Ec	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 4, 2022 4:09 am
S23-140 3077 (HE)	THS	B130/Home Ec	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 4, 2022 4:10 am
S23-141 3077 (HE)	THS	B130/Home Ec	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 4, 2022 4:11 am
S23-142 3077 (HE)	THS	B130	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 4, 2022 4:12 am
S23-204 3077 (TL)	THS	A249	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 4, 2022 5:32 am
S23-245 3077 (OT)	THS	A113	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 4, 2022 4:56 am
S23-247 3077 (OT)	THS	D127	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 4, 2022 5:12 am
S23-248 3077 (OT)	THS	Mail Room	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 4, 2022 4:02 am
S23-249 3077 (TL)	THS	D115	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 4, 2022 5:18 am

SITE: TUSCARORA HIGH SCHOOL 5312 BALLENGER CREEK PIKE, #7008, FREDERICK, MD 21703
 SAMPLER'S NAME: CHERUKA WEERAKOON

Name	Site	Area-Room number	Area	Category	Sampling Date and Time
W01A-01 3077 (DF)	THS	Room D107	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 4, 2022 5:15 am
W01A-02 3077 (DF)	THS	Room D103	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 4, 2022 5:05 am
W01A-03 3077 (DF)	THS	Main St Outside Auditorium	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 4, 2022 5:02 am
W01A-04 3077 (DF) L-R-B (left)	THS	Main St By Cafeteria	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 4, 2022 4:33 am
W01A-04 3077 (DF) L-R-B (right)	THS	Main St By Cafeteria	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 4, 2022 4:34 am
W01A-04 3077 (DF) L-R-B (bottle filler)	THS	Main St By Cafeteria	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 4, 2022 4:35 am
W01A-05 3077 (DF) L-R (left)	THS	Corridor 21 By Girl's Locker Room	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 4, 2022 4:49 am
W01A-05 3077 (DF) L-R (right)	THS	Corridor 21 By Girl's Locker Room	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 4, 2022 4:50 am
W01A-06 3077 (DF) L-R (left)	THS	Corridor 21 By Boy's Locker Room	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 4, 2022 4:51 am
W01A-06 3077 (DF) L-R (right)	THS	Corridor 21 By Boy's Locker Room	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 4, 2022 4:52 am
W01A-07 3077 (DF) L-R (left)	THS	Green Hallway 1st Floor By Restrooms A153	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 4, 2022 4:11 am

69614

SITE: TUSCARORA HIGH SCHOOL 5312 BALLENGER CREEK PIKE, #7008, FREDERICK, MD 21703
 SAMPLER'S NAME: CHERUKA WEERAKOON

Name	Site	Area-Room number	Area	Category	Sampling Date and Time
W01A-07 3077 (DF) L-R (right)	THS	Green Hallway 1st Floor By Restrooms A153	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 4, 2022 4:12 am
W01A-08 3077 (DF) L-R-B (left)	THS	Corridor 12 Blue Hallway 1st Floor By Restrooms A148	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 4, 2022 4:25 am
W01A-08 3077 (DF) L-R-B (right)	THS	Corridor 12 Blue Hallway 1st Floor By Restrooms A148	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 4, 2022 4:26 am
W01A-08 3077 (DF) L-R-B (bottle filler)	THS	Corridor 12 Blue Hallway 1st Floor By Restrooms A148	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 4, 2022 4:27 am
W01A-09 3077 (DF) L-R (left)	THS	Blue Hallway By A147	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 4, 2022 4:30 am
W01A-09 3077 (DF) L-R (right)	THS	Blue Hallway By A147	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 4, 2022 4:31 am
W01A-10 3077 (DF) L-R (left)	THS	Red Hallway By A270	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 4, 2022 5:24 am
W01A-10 3077 (DF) L-R (right)	THS	Red Hallway By A270	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 4, 2022 5:26 am
W01A-12 3077 (DF) L-R-B (left)	THS	Red Hallway By Restrooms A250	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 4, 2022 5:27 am
W01A-12 3077 (DF) L-R-B (right)	THS	Red Hallway By Restrooms A250	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 4, 2022 5:28 am
W01A-12 3077 (DF) L-R-B (bottle filler)	THS	Red Hallway By Restrooms A250	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 4, 2022 5:29 am

SITE: TUSCARORA HIGH SCHOOL 5312 BALLENGER CREEK PIKE, #7008, FREDERICK, MD 21703
 SAMPLER'S NAME: CHERUKA WEERAKOON

Name	Site	Area-Room number	Area	Category	Sampling Date and Time
✓ 45 W01A-13 3077 (DF) L-R (left)	THS	Yellow Hallway By Restroom A246	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 4, 2022
✓ 46 W01A-13 3077 (DF) L-R (right)	THS	Yellow Hallway By Restroom A246	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 4, 2022



Cheruka Weerakoon

2/4/2022

8:24 am



5.35 am

5.36 am