



Project: Frederick Co Schools

Analytical Results

Project Number: Thurmont Middle School
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
04-Apr-22 14:07

Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K17-01 2044 (IM)	E070228-01	Kitchen	Lead	< 1.0	ug/L	4/2/2022 1:46:33PM	SES
K31-01 2044 (KS) L	E070228-02	Kitchen	Lead	16.8	ug/L	4/2/2022 1:50:05PM	SES
K31-01 2044 (KS) R	E070228-03	Kitchen	Lead	8.3	ug/L	4/2/2022 2:00:44PM	SES
S23-01 2044 (HE)	E070228-04	Room 110/Home-Ec	Lead	1.8	ug/L	4/2/2022 2:04:18PM	SES
S23-02 2044 (HE)	E070228-05	Room 110/Home-Ec	Lead	2.1	ug/L	4/2/2022 2:07:52PM	SES
S23-03 2044 (HE)	E070228-06	Room 110/Home-Ec	Lead	2.1	ug/L	4/2/2022 2:18:35PM	SES
S23-04 2044 (HE)	E070228-07	Room 110/Home-Ec	Lead	1.6	ug/L	4/2/2022 2:22:10PM	SES
S23-05 2044 (HE)	E070228-08	Room 110/Home-Ec	Lead	1.9	ug/L	4/2/2022 2:25:44PM	SES
S23-06 2044 (HE)	E070228-09	Room 110/Home-Ec	Lead	1.7	ug/L	4/2/2022 2:29:20PM	SES
S23-07 2044 (HE)	E070228-10	Room 110/Home-Ec	Lead	2.0	ug/L	4/2/2022 2:32:55PM	SES
S23-114 2044 (NO)	E070228-11	Health Room	Lead	< 1.0	ug/L	4/2/2022 2:36:28PM	SES
S23-119 2044 (TL)	E070228-12	Teacher Lounge	Lead	3.1	ug/L	4/2/2022 2:43:33PM	SES
W01A-01 2044 (DF)	E070228-13	2nd floor by Boy's bathroom	Lead	< 1.0	ug/L	4/2/2022 3:01:22PM	SES
W01A-02 2044 (DF)	E070228-14	2nd Floor By Girl's Restroom	Lead	< 1.0	ug/L	4/2/2022 3:04:56PM	SES
W01A-02 2044 (DF) B	E070228-15	2nd Floor By Girl's Restroom	Lead	< 1.0	ug/L	4/2/2022 3:08:30PM	SES
W01A-03 2044 (DF)	E070228-16	Hall By R-605	Lead	< 1.0	ug/L	4/2/2022 3:12:04PM	SES
W01A-04 2044 (DF)	E070228-17	Hallway By Boiler Room	Lead	< 1.0	ug/L	4/2/2022 3:15:39PM	SES
W01A-04 2044 (DF) B	E070228-18	Hallway By Boiler Room	Lead	< 1.0	ug/L	4/2/2022 3:19:14PM	SES

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools

Analytical Results

Project Number: Thurmont Middle School
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
04-Apr-22 14:07

W01A-05 2044 (DF) L	E070228-19	Gym Lobby 305	Lead	< 1.0	ug/L	4/2/2022	3:22:50PM	SES
W01A-05 2044 (DF) R	E070228-20	Gym Lobby 305	Lead	< 1.0	ug/L	4/2/2022	3:26:23PM	SES
W01A-05 2044 (DF) B	E070228-21	Gym Lobby 305	Lead	< 1.0	ug/L	4/2/2022	3:29:55PM	SES
W01A-07 2044 (DF)	E070228-22	Girl's Locker Room	Lead	< 1.0	ug/L	4/2/2022	3:33:28PM	SES
W01A-08 2044 (DF)	E070228-23	Boy's Locker Room	Lead	< 1.0	ug/L	4/2/2022	3:51:17PM	SES

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools


Analytical Results

Project Number: Thurmont Middle School
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
04-Apr-22 14:07

Notes and Definitions

DET Analyte DETECTED
ND Analyte NOT DETECTED at or above the reporting limit
NR Not Reported
dry Sample results reported on a dry weight basis
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

E070228

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1	K17-01 2044 (IM)	TMS	Kitchen	1	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	March 31, 2022 4:05
2	K31-01 2044 (KS) L	TMS	Kitchen	1	D2010.60 Plumbing Fixture (Kitchen Sink)	March 31, 2022 4:08
3	K31-01 2044 (KS) R	TMS	Kitchen	1	D2010.60 Plumbing Fixture (Kitchen Sink)	March 31, 2022 4:08
4	S23-01 2044 (HE)	TMS	Room 110/Home-Ec	1	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 31, 2022 4:20
5	S23-02 2044 (HE)	TMS	Room 110/Home-Ec	1	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 31, 2022 4:20
6	S23-03 2044 (HE)	TMS	Room 110/Home-Ec	1	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 31, 2022 4:20
7	S23-04 2044 (HE)	TMS	Room 110/Home-Ec	1	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 31, 2022 4:25
8	S23-05 2044 (HE)	TMS	Room 110/Home-Ec	1	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 31, 2022 4:25
9	S23-06 2044 (HE)	TMS	Room 110/Home-Ec	1	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 31, 2022 4:25
10	S23-07 2044 (HE)	TMS	Room 110/Home-Ec	1	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 31, 2022 4:25

SITE: THURMONT MIDDLE SCHOOL 2020, 408 E. Main Street, Thurmont, MD 21788
SAMPLER'S NAME: DUREKA ALUWHARE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
11	S23-114 2044 (NO)	TMS	Health Room	1	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 31, 2022 4:30
12	S23-119 2044 (TL)	TMS	Teacher Lounge	1	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 31, 2022 4:34
13	W01A-01 2044 (DF)	TMS	2nd floor by Boy's bathroom	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 31, 2022 4:34
14	W01A-02 2044 (DF)	TMS	2nd Floor By Girl's Restroom	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 31, 2022 4:48
15	W01A-02 2044 (DF) B	TMS	2nd Floor By Girl's Restroom	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 31, 2022 4:48
16	W01A-03 2044 (DF)	TMS	Hall By R-605	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 31, 2022 4:50
17	W01A-04 2044 (DF)	TMS	Hallway By Boiler Room	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 31, 2022 4:52
18	W01A-04 2044 (DF) B	TMS	Hallway By Boiler Room	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 31, 2022 4:52
9	W01A-05 2044 (DF) L	TMS	Gym Lobby 305	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 31, 2022 4:46
0	W01A-05 2044 (DF) R	TMS	Gym Lobby 305	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 31, 2022 4:40

SITE: THURMONT MIDDLE SCHOOL 2020, 408 E. Main Street, Thurmont, MD 21788
 SAMPLER'S NAME: DUREKA ALUWHARE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
21	W01A-05 2044 (DF) B	TMS	Gym Lobby 305	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 31, 2022 4:40
22	W01A-07 2044 (DF)	TMS	Girls Locker Room	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 31, 2022 4:45
23	W01A-08 2044 (DF)	TMS	Boys Locker Room	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 31, 2022 4:47

Client: Frederick County Public Schools
ATTN: Accounts Payable 191 South East St
Frederick, MD 21701

Project: Thurmont Middle School
April 2022

Site: Thurmont Middle School
2020, 408 E. Main St.
Thurmont, MD 21788

Work order: FWD0222

Received at lab: 04/08/22 10:22
Date Reported: 04/11/22 17:00
Collected by: Marc Angleberger, ID: 0659MA
Treatment: N/A

Source: K31-01-2044KSL

(Drinking Water)(Grab - Flushed)

Collected: 4/7/2022 7:37:00AM

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	Prepared	Analyzed	Analyst	Qual	Method
FWD0222-01	Lead	<5	ppb	5	04/11/22 10:41	04/11/22 12:07	KMW		SM3113-B


Source: K31-02-2044KSR

(Drinking Water)(Grab - Flushed)

Collected: 4/7/2022 7:39:00AM

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	Prepared	Analyzed	Analyst	Qual	Method
FWD0222-02	Lead	<5	ppb	5	04/11/22 10:41	04/11/22 12:33	KMW		SM3113-B


Sara E. Randall, President

Rush

CHAIN OF CUSTODY

FREDERICKTOWNE LABS, INC.
 3020 VENTRIE CT., PO BOX 245, MYERSVILLE, MD 21773
 301-293-3340 OR FAX 301-293-2366

Page: 1 of 1

FTL Acct. No.: **344-** *FWD00222*

Compliance Sample (regulated): Yes No

Collected By: (Please Print)
Marc Angleberger
MA-0659

Project: *Thurmont Middle School*
2020, 408 E. Main St. Thurmont, MD 21788

Affiliation:
 Frederick County Public Schools

Analyses To Be Performed

Lab ID	Field Sample ID	Site Description	Collection Date		Collection Time		Matrix <i>(DW/WW)</i>	pH	Res. Cl	DO	Temp	<i>(Grab)</i> Comp	Rec'd Temp (at lab)	Preservation
			Start	End	Start	End								
	<i>Flush</i>	<i>K31-01-2044</i>	<i>4-7-22</i>		<i>7:37 AM</i>		<i>DW</i>				<input checked="" type="checkbox"/>		<i>Lead</i>	
	<i>Flush</i>	<i>K31-02-2044</i>	<i>4-7-22</i>		<i>7:39 AM</i>		<i>DW</i>				<input checked="" type="checkbox"/>		<i>Lead</i>	

Relinquished By: *Marc R Angleberger* Date/Time: *4-8-22 10:30 AM*

Received By: *Nicole Daily* Date/Time: *4/8/22*

Relinquished By: *Marc R. Angleberger* Date/Time: _____

Received By: *Need Bag* Date/Time: *10:22*

Relinquished By: _____ Date/Time: _____

Received By: _____ Date/Time: _____

Relinquished By: _____ Date/Time: _____

Received By: _____ Date/Time: _____

Method of Shipment: _____ Lead: Yes No

Condition of Sample(s) upon Receipt: *17.9*