



Project: Frederick Co Schools

## Analytical Results

Project Number: Tuscarora Elementary School  
 Client Name: TIDEWATER  
 Project Manager: Meneka Rodrigo

Reported:  
 08-Apr-22 16:11

### Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K17-01 1081 (IM)	E070269-01	Kitchen	Lead	< 1.0	ug/L	4/7/2022 4:37:48PM	MAP
K17-03 1081 (IM)	E070269-02	Room 221/Staff Lounge	Lead	< 1.0	ug/L	4/7/2022 4:41:22PM	MAP
K31-02 1081 (KS)	E070269-03	Kitchen	Lead	< 1.0	ug/L	4/7/2022 4:44:55PM	MAP
K31-06 1081 (KS)	E070269-04	Kitchen	Lead	1.6	ug/L	4/7/2022 4:55:37PM	MAP
S23-18 1081 (NO)	E070269-05	Health Suite/Room 210A	Lead	< 1.0	ug/L	4/7/2022 4:59:12PM	MAP
S23-20 1081 (TL)	E070269-06	Room 221/Staff Lounge	Lead	4.3	ug/L	4/7/2022 5:02:47PM	MAP
W01A-01 1081 (DF)	E070269-07	Gym Hallway	Lead	< 1.0	ug/L	4/7/2022 5:06:22PM	MAP
W01A-02 1081 (DF)	E070269-08	Gym Hallway	Lead	< 1.0	ug/L	4/7/2022 5:17:07PM	MAP
W01A-03 1081 (DF)	E070269-09	Main Hallway Back	Lead	< 1.0	ug/L	4/7/2022 5:20:40PM	MAP
W01A-04 1081 (DF)	E070269-10	Main Hallway Back	Lead	< 1.0	ug/L	4/7/2022 5:24:14PM	MAP
W01A-05 1081 (DF)	E070269-11	1st Floor By Elevator	Lead	< 1.0	ug/L	4/7/2022 5:27:48PM	MAP
W01A-05 1081 (DF) B	E070269-12	1st Floor By Elevator	Lead	< 1.0	ug/L	4/7/2022 5:38:30PM	MAP
W01A-06 1081 (DF)	E070269-13	Kindergarten Hallway	Lead	< 1.0	ug/L	4/7/2022 5:42:04PM	MAP
W01A-07 1081 (DF)	E070269-14	2nd Floor By Room 413	Lead	< 1.0	ug/L	4/7/2022 5:45:39PM	MAP
W01A-08 1081 (DF)	E070269-15	2nd Floor By Elevator	Lead	< 1.0	ug/L	4/7/2022 5:49:13PM	MAP
W01A-08 1081 (DF) B	E070269-16	2nd Floor By Elevator	Lead	< 1.0	ug/L	4/7/2022 5:59:57PM	MAP

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools


## Analytical Results

Project Number: Tuscarora Elementary School  
Client Name: TIDEWATER  
Project Manager: Meneka Rodrigo

Reported:  
08-Apr-22 16:11

## Notes and Definitions

DET Analyte DETECTED  
ND Analyte NOT DETECTED at or above the reporting limit  
NR Not Reported  
dry Sample results reported on a dry weight basis  
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

SITE: TUSCARORA ELEMENTARY SCHOOL      6321 Lambert Drive, Frederick, MD 21703  
 SAMPLER'S NAME: DUREKA ALUWHARE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1	K17-01 1081 (IM)	TUES	Kitchen	6	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	April 6, 2022 6:20
2	K17-03 1081 (IM)	TUES	Room 221/Staff Lounge	6	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	April 6, 2022 6:24
3	K31-02 1081 (KS)	TUES	Kitchen	6	D2010.60 Plumbing Fixture (Kitchen Sink)	April 6, 2022 6:20
4	K31-06 1081 (KS)	TUES	Kitchen	6	D2010.60 Plumbing Fixture (Kitchen Sink)	April 6, 2022 6:20
5	S23-18 1081 (NO)	TUES	Health Suite/Room 210A	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 6, 2022 6:28
6	S23-20 1081 (TL)	TUES	Room 221/Staff Lounge	6	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 6, 2022 6:30
7	W01A-01 1081 (DF)	TUES	Gym Hallway	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 6, 2022 6:35
8	W01A-02 1081 (DF)	TUES	Gym Hallway	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 6, 2022 6:35
9	W01A-03 1081 (DF)	TUES	Main Hallway Back	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 6, 2022 6:38
10	W01A-04 1081 (DF)	TUES	Main Hallway Back	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 6, 2022 6:38

SITE: TUSCARORA ELEMENTARY SCHOOL 6321 Lambert Drive, Frederick, MD 21703  
 SAMPLERS NAME: DUREKA ALUWHARE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
✓ 11	W01A-05 1081 (DF)	TUES	1st Floor By Elevator	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 6, 2022 6:45
✓ 12	W01A-05 1081 (DF) B	TUES	1st Floor By Elevator	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 6, 2022 6:40
✓ 13	W01A-06 1081 (DF)	TUES	Kindergarten Hallway	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 6, 2022 6:45
✓ 14	W01A-07 1081 (DF)	TUES	2nd Floor By Room 413	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 6, 2022 6:52
✓ 15	W01A-08 1081 (DF)	TUES	2nd Floor By Elevator	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 6, 2022 7:00
✓ 16	W01A-08 1081 (DF) B	TUES	2nd Floor By Elevator	6	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 6, 2022 7:00