



Project: Frederick Co Schools

Analytical Results

Project Number: Career Technology Center
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
22-Feb-22 10:53

Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K17-01 3017 (IM)	E069761-01	Room A-154/Spire's Kitchen	Lead	< 1.0	ug/L	2/21/2022 11:23:03AM	SES
K17-02 3017 (IM)	E069761-02	Room 110/Teacher Lounge	Lead	< 1.0	ug/L	2/21/2022 11:26:38AM	SES
K31-01 3017 (KS)	E069761-03	Room A-154/Spire's Kitchen	Lead	< 1.0	ug/L	2/21/2022 11:30:14AM	SES
K31-02 3017 (KS)	E069761-04	Room A-154/Spire's Kitchen	Lead	< 1.0	ug/L	2/21/2022 11:40:58AM	SES
K31-03 3017 (KS)	E069761-05	Room A-154/Spire's Kitchen	Lead	1.2	ug/L	2/21/2022 11:44:34AM	SES
K31-04 3017 (KS)	E069761-06	Room A-154/Spire's Kitchen	Lead	< 1.0	ug/L	2/21/2022 11:48:11AM	SES
K31-05 3017 (KS)	E069761-07	Room A-154/Spire's Kitchen	Lead	< 1.0	ug/L	2/21/2022 11:51:43AM	SES
K31-06 3017 (KS)	E069761-08	Room A-154/Spire's Kitchen	Lead	1.2	ug/L	2/21/2022 11:55:15AM	SES
K31-08 3017 (KS)	E069761-09	Room A-154/Spire's Kitchen	Lead	2.5	ug/L	2/21/2022 12:05:55PM	SES
S23-61 3017 (NO)	E069761-10	Room 158/ Health Room	Lead	9.0	ug/L	2/21/2022 12:09:28PM	SES
S23-85 3017 (TL)	E069761-11	Room 110/Teacher Lounge	Lead	< 1.0	ug/L	2/21/2022 12:13:02PM	SES
W01A-01 3017 (DF)	E069761-12	Front Hallway, by Main Entrance	Lead	< 1.0	ug/L	2/21/2022 12:23:45PM	SES
W01A-01 3017 (DF) B	E069761-13	Front Hallway, by Main Entrance	Lead	< 1.0	ug/L	2/21/2022 12:27:19PM	SES
W01A-02 3017 (DF)	E069761-14	Hallway By Room 148/Media	Lead	< 1.0	ug/L	2/21/2022 12:30:54PM	SES
W01A-02 3017 (DF) B	E069761-15	Hallway By Room 148/Media	Lead	< 1.0	ug/L	2/21/2022 12:34:29PM	SES
W01A-04 3017 (DF)	E069761-16	Room A-154/Spire's Kitchen	Lead	< 1.0	ug/L	2/21/2022 12:38:04PM	SES
W01A-05 3017 (DF)	E069761-17	Room 125/Cosmetology	Lead	< 1.0	ug/L	2/21/2022 12:41:37PM	SES
W01A-06 3017 (DF)	E069761-18	Room A101/ Auto Body	Lead	< 1.0	ug/L	2/21/2022 12:48:42PM	SES

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools

Analytical Results

Project Number: Career Technology Center
 Client Name: TIDEWATER
 Project Manager: Meneka Rodrigo

Reported:
 22-Feb-22 10:53

W01A-07 3017 (DF)	E069761-19	Room A115/ TV Lobby	Lead	< 1.0	ug/L	2/21/2022	1:06:31PM	SES
W01A-08 3017 (DF)	E069761-20	Room A113/ Tech Ed	Lead	1.1	ug/L	2/21/2022	1:10:05PM	SES
W01A-09 3017 (DF)	E069761-21	Room A128/ Computer Lab	Lead	< 1.0	ug/L	2/21/2022	1:13:39PM	SES
W01A-10 3017 (DF)	E069761-22	Room A-142/ Digital Design	Lead	< 1.0	ug/L	2/21/2022	1:17:14PM	SES
W01A-11 3017 (DF)	E069761-23	Room 162 Biology Lab	Lead	< 1.0	ug/L	2/21/2022	1:20:49PM	SES
W01A-12 3017 (DF)	E069761-24	Room 127/ Welding	Lead	1.1	ug/L	2/21/2022	1:24:24PM	SES
W01A-13 3017 (DF)	E069761-25	Room 171 /Diesel & Truck	Lead	< 1.0	ug/L	2/21/2022	1:27:59PM	SES
W01A-14 3017 (DF)	E069761-26	By Room142-2 Guidance	Lead	16.8	ug/L	2/21/2022	1:31:32PM	SES
W01A-15 3017 (DF)	E069761-27	Room189/ Carpentry	Lead	< 1.0	ug/L	2/21/2022	1:35:05PM	SES
W01A-16 3017 (DF)	E069761-28	Room 197/ Masonry	Lead	< 1.0	ug/L	2/21/2022	1:38:38PM	SES
W01A-17 3017 (DF)	E069761-29	Room 203/ Electricity	Lead	< 1.0	ug/L	2/21/2022	1:56:27PM	SES
W01A-18 3017 (DF)	E069761-30	Blue Hallway, by Room 211	Lead	< 1.0	ug/L	2/21/2022	2:00:01PM	SES
W01A-18 3017 (DF) B	E069761-31	Blue Hallway, by Room 211	Lead	< 1.0	ug/L	2/21/2022	2:03:35PM	SES
W01A-19 3017 (DF)	E069761-32	Room 212/ HVACR-Shop	Lead	< 1.0	ug/L	2/21/2022	2:07:09PM	SES
W01A-20 3017 (DF)	E069761-33	Room 220/ Landscaping	Lead	< 1.0	ug/L	2/21/2022	2:10:44PM	SES

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools


Analytical Results

Project Number: Career Technology Center
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
22-Feb-22 10:53

Notes and Definitions

DET Analyte DETECTED
ND Analyte NOT DETECTED at or above the reporting limit
NR Not Reported
dry Sample results reported on a dry weight basis
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

SITE: CAREER TECHNOLOGY CENTER 7922 OPOSSUMTOWN PIKE, FREDERICK, MD 21702
 NAME: PHILLIP RANKINE

Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1 K17-01 3017 (IM)	CTC	Room A-154/Spire's Kitchen	4	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	February 18, 2022 4:06
2 K17-02 3017 (IM)	CTC	Room 110/Teacher Lounge	4	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	February 18, 2022 4:28
3 K31-01 3017 (KS)	CTC	Room A-154/Spire's Kitchen	4	D2010.60 Plumbing Fixture (Kitchen Sink)	February 18, 2022 4:06
4 K31-02 3017 (KS)	CTC	Room A-154/Spire's Kitchen	4	D2010.60 Plumbing Fixture (Kitchen Sink)	February 18, 2022 4:09
5 K31-03 3017 (KS)	CTC	Room A-154/Spire's Kitchen	4	D2010.60 Plumbing Fixture (Kitchen Sink)	February 18, 2022 4:11
6 K31-04 3017 (KS)	CTC	Room A-154/Spire's Kitchen	4	D2010.60 Plumbing Fixture (Kitchen Sink)	February 18, 2022 4:12
7 K31-05 3017 (KS)	CTC	Room A-154/Spire's Kitchen	4	D2010.60 Plumbing Fixture (Kitchen Sink)	February 18, 2022 4:15
8 K31-06 3017 (KS)	CTC	Room A-154/Spire's Kitchen	4	D2010.60 Plumbing Fixture (Kitchen Sink)	February 18, 2022 4:16
9 K31-08 3017 (KS)	CTC	Room A-154/Spire's Kitchen	4	D2010.60 Plumbing Fixture (Kitchen Sink)	February 18, 2022 4:21
10 S23-61 3017 (NO)	CTC	Room 158/ Health Room	4	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 18, 2022 4:28

69761

SITE: CAREER TECHNOLOGY CENTER 7922 OPOSSUMTOWN PIKE, FREDERICK, MD 21702
 NAME: PHILLIP RANKINE

Name	Site	Area-Room number	Area	Category	Sampling Date and Time
11 S23-85 3017 (TL)	CTC	Room 110/Teacher Lounge	4	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 18, 2022 10:28
12 W01A-01 3017 (DF)	CTC	Front Hallway, by Main Entrance	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain) <i>Bottle Filler</i>	February 18, 2022 11:00
					February 18, 2022 11:02
13 W01A-01 3017 (DF) B	CTC	Front Hallway, by Main Entrance	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 18, 2022 11:02
14 W01A-02 3017 (DF)	CTC	Hallway By Room 148/Media	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain) <i>Bottle Filler</i>	February 18, 2022 11:30
15 W01A-02 3017 (DF) B	CTC	Hallway By Room 148/Media	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 18, 2022 11:31
					February 18, 2022 11:10
16 W01A-04 3017 (DF)	CTC	Room A-154/Spire's Kitchen	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 18, 2022 11:10
17 W01A-05 3017 (DF)	CTC	Room 125/Cosmetology	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 18, 2022 11:31
18 W01A-06 3017 (DF)	CTC	Room A101/ Auto Body	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 18, 2022 11:36
19 W01A-07 3017 (DF)	CTC	Room A115/ TV Lobby	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 18, 2022 11:37
20 W01A-08 3017 (DF)	CTC	Room A113/ Tech Ed	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 18, 2022 11:50


SITE: CAREER TECHNOLOGY CENTER 7922 OPOSSUMTOWN PIKE, FREDERICK, MD 21702
 NAME: PHILLIP RANKINE

Name	Site	Area-Room number	Area	Category	Sampling Date and Time
21 W01A-09 3017 (DF)	CTC	Room A128/ Computer Lab	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 18, 2022 4:46
22 W01A-10 3017 (DF)	CTC	Room A-142/ Digital Design	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 18, 2022 4:45
23 W01A-11 3017 (DF)	CTC	Room 162 Biology Lab	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 18, 2022 4:49
24 W01A-12 3017 (DF)	CTC	Room 127/ Welding	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 18, 2022 4:52
25 W01A-13 3017 (DF)	CTC	Room 171 /Diesel & Truck	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 18, 2022 4:51
26 W01A-14 3017 (DF)	CTC	By Room142-2 Guidance	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 18, 2022 4:54
27 W01A-15 3017 (DF)	CTC	Room189/ Carpentry	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 18, 2022 4:59
28 W01A-16 3017 (DF)	CTC	Room 197/ Masonry	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 18, 2022 4:58
29 W01A-17 3017 (DF)	CTC	Room 203/ Electricity	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 18, 2022 5:01
30 W01A-18 3017 (DF)	CTC	Blue Hallway, by Room 211	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 18, 2022 5:02

SITE: CAREER TECHNOLOGY CENTER 7922 OPOSSUMTOWN PIKE, FREDERICK, MD 21702
 NAME: PHILLIP RANKINE

Name	Site	Area-Room number	Area	Category	Sampling Date and Time
31 W01A-18 3017 (DF) B	CTC	Blue Hallway, by Room 211	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 18, 2022 5:05
32 W01A-19 3017 (DF)	CTC	Room 212/ HVACR-Shop	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 18, 2022 5:05
33 W01A-20 3017 (DF)	CTC	Room 220/ Landscaping	4	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 18, 2022 5:05

Phillip Rankine



301 332 9094 @

33 / 33

From 2/18/22