



Project: Frederick Co Schools

Analytical Results

Project Number: Oakdale High School
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
08-Apr-22 16:08

Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K17-01 3083 (IM)	E070268-01	Kitchen	Lead	< 1.0	ug/L	4/7/2022 1:07:17PM	MAP
K31-01 3083 (KS)	E070268-02	Kitchen	Lead	4.5	ug/L	4/7/2022 1:10:51PM	MAP
K31-03 3083 (KS)	E070268-03	Kitchen	Lead	1.7	ug/L	4/7/2022 1:21:34PM	MAP
K31-05 3083 (KS)	E070268-04	Kitchen	Lead	11.2	ug/L	4/7/2022 1:25:09PM	MAP
S23-089 3083 (NO)	E070268-05	Room B167/Health Room	Lead	< 1.0	ug/L	4/7/2022 1:28:44PM	MAP
S23-090 3083 (HE)	E070268-06	Room B112/Home Ec	Lead	< 1.0	ug/L	4/7/2022 1:32:19PM	MAP
S23-091 3083 (HE)	E070268-07	Room B112/Home Ec	Lead	1.1	ug/L	4/7/2022 1:43:04PM	MAP
S23-092 3083 (HE)	E070268-08	Room B112/Home Ec	Lead	1.4	ug/L	4/7/2022 1:46:41PM	MAP
S23-093 3083 (HE)	E070268-09	Room B112/Home Ec	Lead	2.0	ug/L	4/7/2022 1:50:17PM	MAP
S23-094 3083 (HE)	E070268-10	Room B112/Home Ec	Lead	2.3	ug/L	4/7/2022 1:53:49PM	MAP
S23-095 3083 (HE)	E070268-11	Room B112/Home Ec	Lead	4.6	ug/L	4/7/2022 1:57:22PM	MAP
S23-096 3083 (HE)	E070268-12	Room B112/Home Ec	Lead	1.1	ug/L	4/7/2022 2:08:01PM	MAP
S23-097 3083 (TL)	E070268-13	Room A129	Lead	< 1.0	ug/L	4/7/2022 2:11:35PM	MAP
W01A-01 3083 (DF) L	E070268-14	Hallway A12 / By Restrooms	Lead	< 1.0	ug/L	4/7/2022 2:15:09PM	MAP
W01A-01 3083 (DF) R	E070268-15	Hallway A12 / By Restrooms	Lead	< 1.0	ug/L	4/7/2022 2:25:52PM	MAP
W01A-01 3083 (DF) B	E070268-16	Hallway A12 / By Restrooms	Lead	< 1.0	ug/L	4/7/2022 2:29:26PM	MAP
W01A-02 3083 (DF) L	E070268-17	Hallway B13 / By Restrooms	Lead	< 1.0	ug/L	4/7/2022 2:33:01PM	MAP
W01A-02 3083 (DF) R	E070268-18	Hallway B13 / By Restrooms	Lead	< 1.0	ug/L	4/7/2022 2:36:36PM	MAP

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools

Analytical Results

Project Number: Oakdale High School
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
08-Apr-22 16:08

W01A-03 3083 (DF) L	E070268-19	Hallway A22 / By Restrooms	Lead	< 1.0	ug/L	4/7/2022	2:40:11PM	MAP
W01A-03 3083 (DF) R	E070268-20	Hallway A22 / By Restrooms	Lead	< 1.0	ug/L	4/7/2022	2:43:44PM	MAP
W01A-03 3083 (DF) B	E070268-21	Hallway A22 / By Restrooms	Lead	< 1.0	ug/L	4/7/2022	2:50:49PM	MAP
W01A-04 3083 (DF) L	E070268-22	Hallway B23 / By Restrooms	Lead	< 1.0	ug/L	4/7/2022	3:08:38PM	MAP
W01A-04 3083 (DF) R	E070268-23	Hallway B23 / By Restrooms	Lead	< 1.0	ug/L	4/7/2022	3:12:12PM	MAP
W01A-04 3083 (DF) B	E070268-24	Hallway B23 / By Restrooms	Lead	< 1.0	ug/L	4/7/2022	3:15:46PM	MAP
W01A-05 3083 (DF) L	E070268-25	Lobby C100 / By Restrooms	Lead	< 1.0	ug/L	4/7/2022	3:19:20PM	MAP
W01A-05 3083 (DF) R	E070268-26	Lobby C100 / By Restrooms	Lead	< 1.0	ug/L	4/7/2022	3:22:55PM	MAP
W01A-05 3083 (DF) B	E070268-27	Lobby C100 / By Restrooms	Lead	< 1.0	ug/L	4/7/2022	3:26:30PM	MAP
W01A-06 3083 (DF) L	E070268-28	Hallway C12 / By Girl's Locker Room	Lead	< 1.0	ug/L	4/7/2022	3:30:05PM	MAP
W01A-07 3083 (DF) L	E070268-30	Hallway C12 / By Boy's Locker Room	Lead	< 1.0	ug/L	4/7/2022	3:33:38PM	MAP
W01A-07 3083 (DF) R	E070268-31	Hallway C12 / By Boy's Locker Room	Lead	< 1.0	ug/L	4/7/2022	3:37:11PM	MAP
W01A-07 3083 (DF) B	E070268-32	Hallway C12 / By Boy's Locker Room	Lead	< 1.0	ug/L	4/7/2022	3:54:59PM	MAP
W01A-08 3083 (DF) L	E070268-33	Lobby C110 / By Gym	Lead	< 1.0	ug/L	4/7/2022	3:58:32PM	MAP
W01A-08 3083 (DF) R	E070268-34	Lobby C110 / By Gym	Lead	< 1.0	ug/L	4/7/2022	4:02:06PM	MAP
W01A-09 3083 (DF) L	E070268-35	Lobby D100 / By Girl's Restroom	Lead	< 1.0	ug/L	4/7/2022	4:05:40PM	MAP
W01A-09 3083 (DF) R	E070268-36	Lobby D100 / By Girl's Restroom	Lead	< 1.0	ug/L	4/7/2022	4:09:14PM	MAP
W01A-09 3083 (DF) B	E070268-37	Lobby D100 / By Girl's Restroom	Lead	< 1.0	ug/L	4/7/2022	4:12:49PM	MAP
W01A-10 3083 (DF)	E070268-38	Room D149	Lead	< 1.0	ug/L	4/7/2022	4:16:24PM	MAP
W01A-11 3083 (DF)	E070268-39	Room D153	Lead	< 1.0	ug/L	4/7/2022	4:19:59PM	MAP

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools


Analytical Results

Project Number: Oakdale High School
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
08-Apr-22 16:08

Notes and Definitions

DET Analyte DETECTED
ND Analyte NOT DETECTED at or above the reporting limit
NR Not Reported
dry Sample results reported on a dry weight basis
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

SITE: OAKDALE HIGH SCHOOL 8009 Opossumtown Pike, Frederick, MD 21702
SAMPLER'S NAME: Udayanga Dias

70268

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1	K17-01 3083 (IM)	OHS	Kitchen	8	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	April 6, 2022 0429
2	K31-01 3083 (KS)	OHS	Kitchen	8	D2010.60 Plumbing Fixture (Kitchen Sink)	April 6, 2022 0434
3	K31-03 3083 (KS)	OHS	Kitchen	8	D2010.60 Plumbing Fixture (Kitchen Sink)	April 6, 2022 0433
4	K31-05 3083 (KS)	OHS	Kitchen	8	D2010.60 Plumbing Fixture (Kitchen Sink)	April 6, 2022 0428
5	S23-089 3083 (NO)	OHS	Room B167/Health Room	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 6, 2022 0436
6	S23-090 3083 (HE)	OHS	Room B112/Home Ec	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 6, 2022 0448
7	S23-091 3083 (HE)	OHS	Room B112/Home Ec	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 6, 2022 0449
8	S23-092 3083 (HE)	OHS	Room B112/Home Ec	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 6, 2022 0450
9	S23-093 3083 (HE)	OHS	Room B112/Home Ec	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 6, 2022 0452
10	S23-094 3083 (HE)	OHS	Room B112/Home Ec	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 6, 2022 0453

SITE: OAKDALE HIGH SCHOOL 8009 Opossumtown Pike, Frederick, MD 21702
SAMPLER'S NAME: Udayanga Dias

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
11	S23-095 3083 (HE)	OHS	Room B112/Home Ec	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 6, 2022 <i>0447</i>
12	S23-096 3083 (HE)	OHS	Room B112/Home Ec	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 6, 2022 <i>0446</i>
13	S23-097 3083 (TL)	OHS	Room A129	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 6, 2022 <i>0457</i>
14	W01A-01 3083 (DF) L	OHS	Hallway A12 / By Restrooms	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 6, 2022 <i>0455</i>
15	W01A-01 3083 (DF) R	OHS	Hallway A12 / By Restrooms	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 6, 2022 <i>0456</i>
16	W01A-01 3083 (DF) B	OHS	Hallway A12 / By Restrooms	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 6, 2022 <i>0456</i>
17	W01A-02 3083 (DF) L	OHS	Hallway B13 / By Restrooms	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 6, 2022 <i>0444</i>
18	W01A-02 3083 (DF) R	OHS	Hallway B13 / By Restrooms	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 6, 2022 <i>0444</i>
19	W01A-03 3083 (DF) L	OHS	Hallway A22 / By Restrooms	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 6, 2022 <i>0502</i>
20	W01A-03 3083 (DF) R	OHS	Hallway A22 / By Restrooms	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 6, 2022 <i>0502</i>

SITE: OAKDALE HIGH SCHOOL 8009 Opossumtown Pike, Frederick, MD 21702
SAMPLER'S NAME: Udayanga Dias

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
21	W01A-03 3083 (DF) B	OHS	Hallway A22 / By Restrooms	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 6, 2022 0502
22	W01A-04 3083 (DF) L	OHS	Hallway B23 / By Restrooms	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 6, 2022 0459
23	W01A-04 3083 (DF) R	OHS	Hallway B23 / By Restrooms	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 6, 2022 0459
24	W01A-04 3083 (DF) B	OHS	Hallway B23 / By Restrooms	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 6, 2022 0500
25	W01A-05 3083 (DF) L	OHS	Lobby C100 / By Restrooms	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 6, 2022 0420
26	W01A-05 3083 (DF) R	OHS	Lobby C100 / By Restrooms	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 6, 2022 0420
27	W01A-05 3083 (DF) B	OHS	Lobby C100 / By Restrooms	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 6, 2022 0421
28	W01A-06 3083 (DF) L	OHS	Hallway C12 / By Girls Locker Room	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 6, 2022 0410
29	W01A-06 3083 (DF) R	OHS	Hallway C12 / By Girls Locker Room	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 6, 2022 0411
30	W01A-07 3083 (DF) L	OHS	Hallway C12 / By Boy's Locker Room	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 6, 2022 0414

(No. sample, Not Functioning)

SITE: OAKDALE HIGH SCHOOL 8009 Opossumtown Pike, Frederick, MD 21702
SAMPLER'S NAME: Udayanga Dias

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
31	W01A-07 3083 (DF) R	OHS	Hallway C12 / By Boy's Locker Room	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 6, 2022 0415
32	W01A-07 3083 (DF) B	OHS	Hallway C12 / By Boy's Locker Room	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 6, 2022 0415
33	W01A-08 3083 (DF) L	OHS	Lobby C110 / By Gym	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 6, 2022 0417
34	W01A-08 3083 (DF) R	OHS	Lobby C110 / By Gym	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 6, 2022 0418
35	W01A-09 3083 (DF) L	OHS	Lobby D100 / By Girl's Restroom	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 6, 2022 0423
36	W01A-09 3083 (DF) R	OHS	Lobby D100 / By Girl's Restroom	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 6, 2022 0423
37	W01A-09 3083 (DF) B	OHS	Lobby D100 / By Girl's Restroom	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 6, 2022 0424
38	W01A-10 3083 (DF)	OHS	Room D149	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 6, 2022 0439
39	W01A-11 3083 (DF)	OHS	Room D153	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 6, 2022 0440