



Project: Frederick Co Schools

## Analytical Results

Project Number: Oakdale Middle School  
Client Name: TIDEWATER  
Project Manager: Meneka Rodrigo

Reported:  
18-Apr-22 14:40

### Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K17-01 2078 (IM)	E070358-01	Kitchen	Lead	< 1.0	ug/L	4/15/2022 2:04:40PM	RAS
K17-03 2078 (IM)	E070358-02	D125/Staff Lounge	Lead	< 1.0	ug/L	4/15/2022 2:15:20PM	RAS
K31-02 2078 (KS)	E070358-03	Kitchen	Lead	3.0	ug/L	4/15/2022 2:26:02PM	RAS
K31-03 2078 (KS)	E070358-04	Kitchen	Lead	1.6	ug/L	4/15/2022 2:29:36PM	RAS
K31-06 2078 (KS)	E070358-05	Kitchen	Lead	3.5	ug/L	4/15/2022 2:33:10PM	RAS
S23-021 2078 (TL)	E070358-06	D125/Staff Lounge	Lead	1.1	ug/L	4/15/2022 2:36:45PM	RAS
S23-063 2078 (HE)	E070358-07	Room A219	Lead	< 1.0	ug/L	4/15/2022 2:40:20PM	RAS
S23-064 2078 (HE)	E070358-08	Room A219	Lead	< 1.0	ug/L	4/15/2022 2:43:55PM	RAS
S23-065 2078 (HE)	E070358-09	Room A219	Lead	< 1.0	ug/L	4/15/2022 2:47:30PM	RAS
S23-066 2078 (HE)	E070358-10	Room A219	Lead	< 1.0	ug/L	4/15/2022 2:51:03PM	RAS
S23-067 2078 (HE)	E070358-11	Room A219	Lead	< 1.0	ug/L	4/15/2022 2:54:36PM	RAS
S23-068 2078 (HE)	E070358-12	Room A219	Lead	< 1.0	ug/L	4/15/2022 3:12:25PM	RAS
S23-069 2078 (HE)	E070358-13	Room A219	Lead	3.6	ug/L	4/15/2022 3:15:58PM	RAS
S23-070 2078 (HE)	E070358-14	Room A219	Lead	< 1.0	ug/L	4/15/2022 3:23:07PM	RAS
S23-106 2078 (NO)	E070358-15	Room D106/Health Room	Lead	1.1	ug/L	4/15/2022 3:26:41PM	RAS
S23-107 2078 (OT)	E070358-16	Room C146	Lead	< 1.0	ug/L	4/15/2022 3:30:16PM	RAS
S23-108 2078 (TL)	E070358-17	Room B123	Lead	2.0	ug/L	4/15/2022 3:33:51PM	RAS
W01A-01 2078 (DF) L	E070358-18	Corridor "C", By C152	Lead	< 1.0	ug/L	4/15/2022 3:37:26PM	RAS

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools

## Analytical Results

Project Number: Oakdale Middle School

Client Name: TIDEWATER

Project Manager: Meneka Rodrigo

Reported:

18-Apr-22 14:40

W01A-01 2078 (DF) R	E070358-19	Corridor "C", By C152	Lead	< 1.0	ug/L	4/15/2022	3:41:00PM	RAS
W01A-02 2078 (DF) L	E070358-20	1st Floor, B Wing By B109	Lead	< 1.0	ug/L	4/15/2022	3:51:42PM	RAS
W01A-02 2078 (DF) R	E070358-21	1st Floor, B Wing By B109	Lead	< 1.0	ug/L	4/15/2022	3:55:16PM	RAS
W01A-02 2078 (DF) B	E070358-22	1st Floor, B Wing By B109	Lead	< 1.0	ug/L	4/15/2022	4:05:57PM	RAS
W01A-03 2078 (DF) L	E070358-23	1st Floor, B Wing By B108	Lead	< 1.0	ug/L	4/15/2022	4:09:31PM	RAS
W01A-03 2078 (DF) R	E070358-24	1st Floor, B Wing By B108	Lead	< 1.0	ug/L	4/15/2022	4:13:05PM	RAS
W01A-04 2078 (DF) L	E070358-25	Main Hallway By Room C134	Lead	< 1.0	ug/L	4/15/2022	4:16:40PM	RAS
W01A-04 2078 (DF) R	E070358-26	Main Hallway By Room C134	Lead	< 1.0	ug/L	4/15/2022	4:20:15PM	RAS
W01A-04 2078 (DF) B	E070358-27	Main Hallway By Room C134	Lead	< 1.0	ug/L	4/15/2022	4:23:50PM	RAS
W01A-05 2078 (DF) L	E070358-28	Main Hallway By Room C134	Lead	< 1.0	ug/L	4/15/2022	4:34:35PM	RAS
W01A-06 2078 (DF) L	E070358-30	2nd Floor By Girl's Restroom B204	Lead	< 1.0	ug/L	4/15/2022	4:38:09PM	RAS
W01A-06 2078 (DF) R	E070358-31	2nd Floor By Girl's Restroom B204	Lead	< 1.0	ug/L	4/15/2022	4:41:43PM	RAS
W01A-06 2078 (DF) B	E070358-32	2nd Floor By Girl's Restroom B204	Lead	< 1.0	ug/L	4/15/2022	4:55:59PM	RAS
W01A-07 2078 (DF) L	E070358-33	2nd Floor By Boy's Restroom B203	Lead	< 1.0	ug/L	4/15/2022	4:59:33PM	RAS
W01A-07 2078 (DF) R	E070358-34	2nd Floor By Boy's Restroom B203	Lead	< 1.0	ug/L	4/15/2022	5:03:07PM	RAS
W01A-08 2078 (DF) L	E070358-36	HALLWAY E100.1	Lead	< 1.0	ug/L	4/15/2022	5:06:42PM	RAS
W01A-08 2078 (DF) R	E070358-37	HALLWAY E100.1	Lead	< 1.0	ug/L	4/15/2022	5:17:26PM	RAS
W01A-09 2078 (DF) L	E070358-38	HALLWAY E100.1	Lead	< 1.0	ug/L	4/15/2022	5:21:02PM	RAS
W01A-09 2078 (DF) R	E070358-39	HALLWAY E100.1	Lead	< 1.0	ug/L	4/15/2022	5:24:37PM	RAS
W01A-09 2078 (DF) B	E070358-40	HALLWAY E100.1	Lead	< 1.0	ug/L	4/15/2022	5:28:11PM	RAS
W01A-10 2078 (DF) L	E070358-41	HALLWAY E100.2	Lead	< 1.0	ug/L	4/15/2022	5:31:45PM	RAS

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools

## Analytical Results

Project Number: Oakdale Middle School

Client Name: TIDEWATER

Project Manager: Meneka Rodrigo

Reported:

18-Apr-22 14:40

W01A-10 2078 (DF) R	E070358-42	HALLWAY E100.2	Lead	< 1.0	ug/L	4/15/2022	5:42:28PM	RAS
W01A-10 2078 (DF) B	E070358-43	HALLWAY E100.2	Lead	< 1.0	ug/L	4/15/2022	5:46:02PM	RAS
W01A-11 2078 (DF) L	E070358-44	HALLWAY E100.2	Lead	< 1.0	ug/L	4/15/2022	5:49:37PM	RAS
W01A-11 2078 (DF) R	E070358-45	HALLWAY E100.2	Lead	< 1.0	ug/L	4/15/2022	6:00:20PM	RAS
W01A-11 2078 (DF) B	E070358-46	HALLWAY E100.2	Lead	< 1.0	ug/L	4/15/2022	6:03:55PM	RAS

Stephen Shelley, Laboratory Director

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*



Project: Frederick Co Schools


## Analytical Results

Project Number: Oakdale Middle School  
Client Name: TIDEWATER  
Project Manager: Meneka Rodrigo

Reported:  
18-Apr-22 14:40

## Notes and Definitions

DET Analyte DETECTED  
ND Analyte NOT DETECTED at or above the reporting limit  
NR Not Reported  
dry Sample results reported on a dry weight basis  
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

SITE: OAKDALE MIDDLE SCHOOL 5810 Oakdale School Road, Jhamsville, MD 21754  
 NAME: CHRISTOPHER WILLCOME

70358  
 1 of 6

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1	K17-01 2078 (IM)	OMS	Kitchen	8	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	April 14, 2022 3:58
2	K17-03 2078 (IM)	OMS	D125/Staff Lounge	8	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	April 14, 2022 4:06
3	K31-02 2078 (KS)	OMS	Kitchen	8	D2010.60 Plumbing Fixture (Kitchen Sink)	April 14, 2022 3:59
4	K31-03 2078 (KS)	OMS	Kitchen	8	D2010.60 Plumbing Fixture (Kitchen Sink)	April 14, 2022 3:58
5	K31-06 2078 (KS)	OMS	Kitchen	8	D2010.60 Plumbing Fixture (Kitchen Sink)	April 14, 2022 4:00
6	S23-021 2078 (TL)	OMS	D125/Staff Lounge	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 14, 2022 4:02
7	S23-063 2078 (HE)	OMS	Room A219	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 14, 2022 4:35
8	S23-064 2078 (HE)	OMS	Room A219	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 14, 2022 4:41
9	S23-065 2078 (HE)	OMS	Room A219	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 14, 2022 4:40

SITE: OAKDALE MIDDLE SCHOOL 5810 Oakdale School Road, Ijamsville, MD 21754  
 NAME: CHRISTOPHER WILCOME

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
10	S23-066 2078 (HE)	OMS	Room A219	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 14, 2022 4:39
11	S23-067 2078 (HE)	OMS	Room A219	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 14, 2022 4:38
12	S23-068 2078 (HE)	OMS	Room A219	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 14, 2022 4:38
13	S23-069 2078 (HE)	OMS	Room A219	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 14, 2022 4:37
14	S23-070 2078 (HE)	OMS	Room A219	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 14, 2022 4:36
15	S23-106 2078 (NO)	OMS	Room D106/Health Room	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 14, 2022 4:09
16	S23-107 2078 (OT)	OMS	Room C146	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 14, 2022 4:13
17	S23-108 2078 (TL)	OMS	Room B123	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 14, 2022 4:18
18	W01A-01 2078 (DF) L	OMS	Corridor "C", By C152	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 4:10

2038  
2060

SITE: OAKDALE MIDDLE SCHOOL 5810 Oakdale School Road, Jhamsville, MD 21754  
 NAME: CHRISTOPHER WILLCOME

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
19	W01A-01 2078 (DF) R	OMS	Corridor "C", By C152	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 4:11
20	W01A-02 2078 (DF) L	OMS	1st Floor, B Wing By B109	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 4:21
21	W01A-02 2078 (DF) R	OMS	1st Floor, B Wing By B109	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 4:21
22	W01A-02 2078 (DF) B	OMS	1st Floor, B Wing By B109	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 4:21
23	W01A-03 2078 (DF) L	OMS	1st Floor, B Wing By B108	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 4:23
24	W01A-03 2078 (DF) R	OMS	1st Floor, B Wing By B108	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 4:23
25	W01A-04 2078 (DF) L	OMS	Main Hallway By Room C134	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 3:57
26	W01A-04 2078 (DF) R	OMS	Main Hallway By Room C134	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 3:54
27	W01A-04 2078 (DF) B	OMS	Main Hallway By Room C134	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 3:54

20358  
3 of 6

SITE: OAKDALE MIDDLE SCHOOL 5810 Oakdale School Road, Jhamsville, MD 21754  
 NAME: CHRISTOPHER WILLCOME

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
28	W01A-05 2078 (DF) L	OMS	Main Hallway By Room C134	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 4:18
29	W01A-05 2078 (DF) R	OMS	Main Hallway By Room C134	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 N/A Dose not work
30	W01A-06 2078 (DF) L	OMS	2nd Floor By Girl's Restroom B204	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 4:22
31	W01A-06 2078 (DF) R	OMS	2nd Floor By Girl's Restroom B204	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 4:23
32	W01A-06 2078 (DF) B	OMS	2nd Floor By Girl's Restroom B204	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 4:27
33	W01A-07 2078 (DF) L	OMS	2nd Floor By Boy's Restroom B203	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 4:31
34	W01A-07 2078 (DF) R	OMS	2nd Floor By Boy's Restroom B203	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 4:31
35	W01A-07 2078 (DF) B	OMS	2nd Floor By Boy's Restroom B203	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 N/A Dose not work
36	W01A-08 2078 (DF) L	OMS	HALLWAY E100.1	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 4:51

20358  
4 of 6



SITE: OAKDALE MIDDLE SCHOOL 5810 Oakdale School Road, Jhamsville, MD 21754  
 NAME: CHRISTOPHER WILCOMBE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
37	W01A-08 2078 (DF) R	OMS	HALLWAY E100.1	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 4:58a
38	W01A-09 2078 (DF) L	OMS	HALLWAY E100.1	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 4:55
39	W01A-09 2078 (DF) R	OMS	HALLWAY E100.1	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 4:56
40	W01A-09 2078 (DF) B	OMS	HALLWAY E100.1	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 4:56
41	W01A-10 2078 (DF) L	OMS	HALLWAY E100.2	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 4:56
42	W01A-10 2078 (DF) R	OMS	HALLWAY E100.2	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 4:57
43	W01A-10 2078 (DF) B	OMS	HALLWAY E100.2	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 4:57
44	W01A-11 2078 (DF) L	OMS	HALLWAY E100.2	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 4:58
45	W01A-11 2078 (DF) R	OMS	HALLWAY E100.2	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 4:59

7058  
5 of 6

70358  
6086

SITE: OAKDALE MIDDLE SCHOOL 5810 Oakdale School Road, Jiamsville, MD 21754  
NAME: CHRISTOPHER WILCOMBE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
46	W01A-11 2078 (DF) B	OMS	HALLWAY E100.2	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 14, 2022 4:59