



Project: Frederick Co Schools

## Analytical Results

Project Number: Rock Creek School  
Client Name: TIDEWATER  
Project Manager: Meneka Rodrigo

Reported:  
11-Feb-22 09:50

### Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K17-02 8024 (IM)	E069654-01	Room 707/Staff Lounge Fridge	Lead	< 1.0	ug/L	2/10/2022 1:39:06PM	MAP
K17-03 8024 (IM)	E069654-02	Room 707/Staff Lounge Fridge	Lead	< 1.0	ug/L	2/10/2022 1:57:03PM	MAP
K31-01 8024 (KS)	E069654-03	Kitchen Near Serving Area	Lead	3.0	ug/L	2/10/2022 2:00:35PM	MAP
S23-02 8024 (NO)	E069654-04	Health suite restroom	Lead	< 1.0	ug/L	2/10/2022 2:04:08PM	MAP
S23-06 8024 (HE)	E069654-05	Classroom 305	Lead	1.9	ug/L	2/10/2022 2:07:40PM	MAP
S23-07 8024 (HE)	E069654-06	Classroom 305	Lead	< 1.0	ug/L	2/10/2022 2:11:13PM	MAP
S23-08 8024 (OT)	E069654-07	Classroom B101	Lead	1.3	ug/L	2/10/2022 2:14:47PM	MAP
S23-10 8024 (OT)	E069654-08	Classroom B105	Lead	1.5	ug/L	2/10/2022 2:18:20PM	MAP
S23-12 8024 (OT)	E069654-09	Classroom B107	Lead	1.4	ug/L	2/10/2022 2:21:54PM	MAP
S23-14 8024 (OT)	E069654-10	Classroom B108	Lead	1.9	ug/L	2/10/2022 2:32:37PM	MAP
S23-16 8024 (OT)	E069654-11	Classroom B106	Lead	1.4	ug/L	2/10/2022 2:36:12PM	MAP
S23-18 8024 (OT)	E069654-12	Classroom B102	Lead	1.6	ug/L	2/10/2022 2:46:57PM	MAP
S23-25 8024 (OT)	E069654-13	Classroom 315	Lead	1.8	ug/L	2/10/2022 2:50:29PM	MAP
S23-43 8024 (TL)	E069654-14	Room 707/Staff Lounge	Lead	1.1	ug/L	2/10/2022 2:54:02PM	MAP
S23-49 8024 (OT)	E069654-15	Classroom E101	Lead	2.3	ug/L	2/10/2022 2:57:34PM	MAP
S23-51 8024 (OT)	E069654-16	Classroom E103	Lead	1.2	ug/L	2/10/2022 3:01:07PM	MAP
S23-53 8024 (OT)	E069654-17	Classroom E107	Lead	1.8	ug/L	2/10/2022 3:04:41PM	MAP
S23-55 8024 (OT)	E069654-18	Classroom E108	Lead	1.3	ug/L	2/10/2022 3:15:23PM	MAP

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools

## Analytical Results

Project Number: Rock Creek School

Client Name: TIDEWATER

Project Manager: Meneka Rodrigo

Reported:

11-Feb-22 09:50

S23-57 8024 (OT)	E069654-19	Classroom E104	Lead	1.2	ug/L	2/10/2022	3:18:57PM	MAP
S23-59 8024 (OT)	E069654-20	Classroom E102	Lead	1.2	ug/L	2/10/2022	3:22:31PM	MAP
W01A-01 8024 (DF) L-RE069654-21		Green Hallway Next to B104	Lead	< 1.0	ug/L	2/10/2022	3:29:40PM	MAP
W01A-01 8024 (DF) L-RE069654-22		Green Hallway Next to B104	Lead	< 1.0	ug/L	2/10/2022	3:40:24PM	MAP
W01A-01 8024 (DF) L-RE069654-23		Green Hallway Next to B104	Lead	< 1.0	ug/L	2/10/2022	3:43:56PM	MAP
W01A-02 8024 (DF) L-RE069654-24		Pre-K Hallway Next to 315A	Lead	< 1.0	ug/L	2/10/2022	3:47:29PM	MAP
W01A-02 8024 (DF) L-RE069654-25		Pre-K Hallway Next to 315A	Lead	< 1.0	ug/L	2/10/2022	3:58:11PM	MAP
W01A-02 8024 (DF) L-RE069654-26		Pre-K Hallway Next to 315A	Lead	< 1.0	ug/L	2/10/2022	4:01:45PM	MAP
W01A-03 8024 (DF) L-RE069654-27		Aquatics next to locker rooms	Lead	< 1.0	ug/L	2/10/2022	4:05:18PM	MAP
W01A-03 8024 (DF) L-RE069654-28		Aquatics next to locker rooms	Lead	< 1.0	ug/L	2/10/2022	4:08:52PM	MAP
W01A-03 8024 (DF) L-RE069654-29		Aquatics next to locker rooms	Lead	< 1.0	ug/L	2/10/2022	4:12:26PM	MAP
W01A-04 8024 (DF) L-RE069654-30		Cafeteria next to kitchen	Lead	< 1.0	ug/L	2/10/2022	4:16:01PM	MAP
W01A-04 8024 (DF) L-RE069654-31		Cafeteria next to kitchen	Lead	< 1.0	ug/L	2/10/2022	4:19:35PM	MAP
W01A-04 8024 (DF) L-RE069654-32		Cafeteria next to kitchen	Lead	< 1.0	ug/L	2/10/2022	4:30:20PM	MAP
W01A-05 8024 (DF) L-RE069654-33		Yellow hallway next to E105	Lead	< 1.0	ug/L	2/10/2022	4:41:02PM	MAP
W01A-05 8024 (DF) L-RE069654-34		Yellow hallway next to E105	Lead	< 1.0	ug/L	2/10/2022	4:44:35PM	MAP
W01A-05 8024 (DF) L-RE069654-35		Yellow hallway next to E105	Lead	< 1.0	ug/L	2/10/2022	4:48:09PM	MAP
W01A-06 8024 (DF) L-RE069654-36		Hallway outside 716	Lead	< 1.0	ug/L	2/10/2022	4:51:42PM	MAP
W01A-06 8024 (DF) L-RE069654-37		Hallway outside 716	Lead	< 1.0	ug/L	2/10/2022	4:55:15PM	MAP
W01A-06 8024 (DF) L-RE069654-38		Hallway outside 716	Lead	< 1.0	ug/L	2/10/2022	4:58:49PM	MAP
W01A-07 8024 (DF) L-RE069654-39		Gym	Lead	< 1.0	ug/L	2/10/2022	5:02:24PM	MAP

Stephen Shelley, Laboratory Director

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*



Project: Frederick Co Schools

## Analytical Results

Project Number: Rock Creek School

Client Name: TIDEWATER

Project Manager: Meneka Rodrigo

Reported:

11-Feb-22 09:50

W01A-07 8024 (DF) L-RE069654-40	Gym	Lead	< 1.0	ug/L	2/10/2022	5:05:58PM	MAP
W01A-07 8024 (DF) L-RE069654-41	Gym	Lead	< 1.0	ug/L	2/10/2022	5:13:09PM	MAP
W01A-08 8024 (DF) L-RE069654-42	P&R Men/Women Restroom	Lead	< 1.0	ug/L	2/10/2022	5:31:01PM	MAP
W01A-08 8024 (DF) L-RE069654-43	P&R Men/Women Restroom	Lead	< 1.0	ug/L	2/10/2022	5:34:35PM	MAP
W01A-08 8024 (DF) L-RE069654-44	P&R Men/Women Restroom	Lead	< 1.0	ug/L	2/10/2022	5:38:09PM	MAP

Stephen Shelley, Laboratory Director

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*



Project: Frederick Co Schools


## Analytical Results

Project Number: Rock Creek School  
Client Name: TIDEWATER  
Project Manager: Meneka Rodrigo

Reported:  
11-Feb-22 09:50

## Notes and Definitions

DET Analyte DETECTED  
ND Analyte NOT DETECTED at or above the reporting limit  
NR Not Reported  
dry Sample results reported on a dry weight basis  
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

69654 69824

SITE: ROCK CREEK SCHOOL ADDRESS: 55 B WEST FREDERICK STREET, WALKERSVILLE, MD 21793  
 SAMPLER'S NAME: UDAYANGA DIAS

Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1 K17-02 8024 (IM)	RCS	Room 707/Staff Lounge Fridge	5	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	February 9, 2022 0442
2 K17-03 8024 (IM)	RCS	Room 707/Staff Lounge Fridge	5	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	February 9, 2022 0443
3 K31-01 8024 (KS)	RCS	Kitchen Near Serving Area	5	D2010.60 Plumbing Fixture (Kitchen Sink)	February 9, 2022 0439
4 S23-02 8024 (NO)	RCS	Health suite restroom	5	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 9, 2022 0407
5 S23-06 8024 (HE)	RCS	Classroom 305	5	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 9, 2022 0412
6 S23-07 8024 (HE)	RCS	Classroom 305	5	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 9, 2022 0411
7 S23-08 8024 (OT)	RCS	Classroom B101	5	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 9, 2022 0410
8 S23-10 8024 (OT)	RCS	Classroom B105	5	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 9, 2022 0415
9 S23-12 8024 (OT)	RCS	Classroom B107	5	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 9, 2022 0421
10 S23-14 8024 (OT)	RCS	Classroom B108	5	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 9, 2022 0423
11 S23-16 8024 (OT)	RCS	Classroom B106	5	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 9, 2022 0424

SITE: ROCK CREEK SCHOOL ADDRESS: 55 B WEST FREDERICK STREET, WALKERSVILLE, MD 21793  
 SAMPLER'S NAME: UDAYANGA DIAS

Name	Site	Area-Room number	Area	Category	Sampling Date and Time
12 S23-18 8024 (OT)	RCS	Classroom B102	5	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 9, 2022 0425
13 S23-25 8024 (OT)	RCS	Classroom 315	5	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 9, 2022 0430
14 S23-43 8024 (TL)	RCS	Room 707/Staff Lounge	5	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 9, 2022 0441
15 S23-49 8024 (OT)	RCS	Classroom E101	5	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 9, 2022 0445
16 S23-51 8024 (OT)	RCS	Classroom E103	5	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 9, 2022 0446
17 S23-53 8024 (OT)	RCS	Classroom E107	5	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 9, 2022 0451
18 S23-55 8024 (OT)	RCS	Classroom E108	5	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 9, 2022 0453
19 S23-57 8024 (OT)	RCS	Classroom E104	5	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 9, 2022 0454
20 S23-59 8024 (OT)	RCS	Classroom E102	5	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	February 9, 2022 0455
21 W01A-01 8024 (DF) L-R-B (left)	RCS	Green Hallway Next to B104	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 9, 2022 0417
22 W01A-01 8024 (DF) L-R-B (right)	RCS	Green Hallway Next to B104	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 9, 2022 0417

SITE: ROCK CREEK SCHOOL ADDRESS: 55 B WEST FREDERICK STREET, WALKERSVILLE, MD 21793  
 SAMPLER'S NAME: UDAYANGA DIAS

Name	Site	Area-Room number	Area	Category	Sampling Date and Time
W01A-01 8024 (DF) L-R-B (bottle filler)	RCS	Green Hallway Next to B104	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 9, 2022 0418
W01A-02 8024 (DF) L-R-B (left)	RCS	Pre-K Hallway Next to 315A	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 9, 2022 0428
W01A-02 8024 (DF) L-R-B (right)	RCS	Pre-K Hallway Next to 315A	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 9, 2022 0428
W01A-02 8024 (DF) L-R-B (bottle filler)	RCS	Pre-K Hallway Next to 315A	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 9, 2022 0429
W01A-03 8024 (DF) L-R-B (left)	RCS	Aquatics next to locker rooms	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 9, 2022 0432
W01A-03 8024 (DF) L-R-B (right)	RCS	Aquatics next to locker rooms	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 9, 2022 0436
W01A-03 8024 (DF) L-R-B (bottle filler)	RCS	Aquatics next to locker rooms	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 9, 2022 0437
W01A-04 8024 (DF) L-R-B (left)	RCS	Cafeteria next to kitchen	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 9, 2022 0432
W01A-04 8024 (DF) L-R-B (right)	RCS	Cafeteria next to kitchen	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 9, 2022 0433
W01A-04 8024 (DF) L-R-B (bottle filler)	RCS	Cafeteria next to kitchen	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 9, 2022 0433
W01A-05 8024 (DF) L-R-B (left)	RCS	Yellow hallway next to E105	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 9, 2022 0448

SITE: ROCK CREEK SCHOOL ADDRESS: 55 B WEST FREDERICK STREET, WALKERSVILLE, MD 21793  
 SAMPLER'S NAME: UDAYANGA DIAS

Name	Site	Area-Room number	Area	Category	Sampling Date and Time
34 W01A-05 8024 (DF) L-R-B (right)	RCS	Yellow hallway next to E105	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 9, 2022 0448
35 W01A-05 8024 (DF) L-R-B (bottle filler)	RCS	Yellow hallway next to E105	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 9, 2022 0449
36 W01A-06 8024 (DF) L-R-B (left)	RCS	Hallway outside 716	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 9, 2022 0455
37 W01A-06 8024 (DF) L-R-B (right)	RCS	Hallway outside 716	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 9, 2022 0458
38 W01A-06 8024 (DF) L-R-B (bottle filler)	RCS	Hallway outside 716	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 9, 2022 0459
39 W01A-07 8024 (DF) L-R-B (left)	RCS	Gym	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 9, 2022 0502
40 W01A-07 8024 (DF) L-R-B (right)	RCS	Gym	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 9, 2022 0502
41 W01A-07 8024 (DF) L-R-B (bottle filler)	RCS	Gym	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 9, 2022 0503
42 W01A-08 8024 (DF) L-R-B (left)	RCS	P&R Men/Women Restroom	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 9, 2022 0505
43 W01A-08 8024 (DF) L-R-B (right)	RCS	P&R Men/Women Restroom	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 9, 2022 0505
44 W01A-08 8024 (DF) L-R-B (bottle filler)	RCS	P&R Men/Women Restroom	5	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	February 9, 2022 0506

4 of 4

*[Signature]* 2/9/22 814 *[Signature]*