



Project: Frederick Co Schools

Analytical Results

Project Number: Thurmont Primary School
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
29-Mar-22 09:36

Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K17-01 1039 (IM)	E070158-01	Kitchen	Lead	< 1.0	ug/L	3/26/2022 3:25:06PM	SES
K31-01 1039 (KS)	E070158-02	Kitchen	Lead	8.5	ug/L	3/26/2022 3:28:56PM	SES
K31-02 1039 (KS)	E070158-03	Kitchen	Lead	9.6	ug/L	3/26/2022 3:32:47PM	SES
S23-01 1039 (NO)	E070158-04	417/ Nurses Office	Lead	2.0	ug/L	3/26/2022 3:36:35PM	SES
S23-02 1039 (TL)	E070158-05	215/Staff Lounge	Lead	2.4	ug/L	3/26/2022 3:40:23PM	SES
W01A-01 1039 (DF) L	E070158-06	Across R-417	Lead	1.6	ug/L	3/26/2022 3:44:10PM	SES
W01A-01 1039 (DF) R	E070158-07	Across R-417	Lead	2.8	ug/L	3/26/2022 4:03:15PM	SES
W01A-03 1039 (DF)	E070158-08	Gym	Lead	< 1.0	ug/L	3/26/2022 4:07:04PM	SES
W01A-04 1039 (DF)	E070158-09	Gym	Lead	1.1	ug/L	3/26/2022 4:10:53PM	SES
W01A-05 1039 (DF)	E070158-10	By R-207	Lead	< 1.0	ug/L	3/26/2022 4:14:43PM	SES
W01A-05 1039 (DF) B	E070158-11	By R-207	Lead	< 1.0	ug/L	3/26/2022 4:18:32PM	SES
W01A-06 1039 (DF)	E070158-12	By R-111	Lead	< 1.0	ug/L	3/26/2022 4:22:22PM	SES
W01A-07 1039 (DF) L	E070158-13	By R-503	Lead	< 1.0	ug/L	3/26/2022 4:26:12PM	SES
W01A-07 1039 (DF) R	E070158-14	By R-503	Lead	< 1.0	ug/L	3/26/2022 4:30:01PM	SES
W01A-07 1039 (DF) B	E070158-15	By R-503	Lead	< 1.0	ug/L	3/26/2022 4:41:28PM	SES

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools


Analytical Results

Project Number: Thurmont Primary School
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
29-Mar-22 09:36

Notes and Definitions

DET Analyte DETECTED
ND Analyte NOT DETECTED at or above the reporting limit
NR Not Reported
dry Sample results reported on a dry weight basis
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.


SITE: THURMONT PRIMARY SCHOOL 7989 Rocky Ridge Road, Thurmont, MD 21788
 SAMPLER'S NAME: PHILLIP RANKINE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1	K17-01 1039 (IM)	TPS	Kitchen	1	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	March 25, 2022 9:22
2	K31-01 1039 (KS)	TPS	Kitchen	1	D2010.60 Plumbing Fixture (Kitchen Sink)	March 25, 2022 9:20
3	K31-02 1039 (KS)	TPS	Kitchen	1	D2010.60 Plumbing Fixture (Kitchen Sink)	March 25, 2022 9:18
4	S23-01 1039 (NO)	TPS	417/ Nurses Office	1	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 25, 2022 9:24
5	S23-02 1039 (TL)	TPS	215/Staff Lounge	1	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 25, 2022 9:26
6	W01A-01 1039 (DF) L	TPS	Across R-417	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 25, 2022 9:10
7	W01A-01 1039 (DF) R	TPS	Across R-417	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 25, 2022 9:11
8	W01A-03 1039 (DF)	TPS	Gym	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 25, 2022 9:13
9	W01A-04 1039 (DF)	TPS	Gym	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 25, 2022 9:14

10158

SITE: THURMONT PRIMARY SCHOOL 7989 Rocky Ridge Road, Thurmont, MD 21788
SAMPLER'S NAME: PHILLIP RANKINE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
10	W01A-05 1039 (DF)	TPS	By R-207	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain) <i>2 Miller</i>	March 25, 2022 <i>5:28</i>
11	W01A-05 1039 (DF) B	TPS	By R-207	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 25, 2022 <i>5:30</i>
12	W01A-06 1039 (DF)	TPS	By R-111	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 25, 2022 <i>5:32</i>
13	W01A-07 1039 (DF) L	TPS	By R-503	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 25, 2022 <i>5:35</i>
14	W01A-07 1039 (DF) R	TPS	By R-503	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 25, 2022 <i>5:36</i>
15	W01A-07 1039 (DF) B	TPS	By R-503	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 25, 2022 <i>5:37</i>


 Phillip Rankine
 301 332-9114

Client: Frederick County Public Schools
ATTN: Accounts Payable 191 South East St
Frederick, MD 21701

Project: Thurmont Primary School
April 2022

Site: Thurmont Primary School
7989 Rocky Ridge Road
Thurmont MD, 21788

Work order: FWD0291

Received at lab: 04/12/22 11:01
Date Reported: 04/13/22 16:20
Collected by: Marc Angleberger, ID: 0659MA
Treatment: N/A

Source: K31-01-1039 KS

(Drinking Water)(Grab - Flushed)

Collected: 4/8/2022 12:42:00PM

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	Prepared	Analyzed	Analyst	Qual	Method
FWD0291-01	Lead	<5	ppb	5	04/13/22 09:32	04/13/22 11:45	KMW		SM3113-B

Source: K31-02-1039 KS

(Drinking Water)(Grab - Flushed)

Collected: 4/8/2022 12:45:00PM

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	Prepared	Analyzed	Analyst	Qual	Method
FWD0291-02	Lead	<5	ppb	5	04/13/22 09:32	04/13/22 11:54	KMW		SM3113-B


Sara E. Randall, President

*Fredericktowne Labs, Inc. is a State Certified Water Quality Laboratory
Maryland Cert. No. 116 Virginia Cert. No. 00444
West Virginia Cert. 415 MDOT WBE Cert. No.: 91-158*

Rush

CHAIN OF CUSTODY
 FREDERICKTOWNE LABS, INC.
 3020 VENTRIE CT., PO BOX 245, MYERSVILLE, MD 21773
 301-293-3340 OR FAX 301-293-2366

FTL Acct. No.: **344- FUDS291**

Compliance Sample (regulated): Yes No

Project: *Thurmont Primary School*
7989 Rocky Ridge Rd. Thurmont, MD 21788

Collected By: (Please Print) *Marc Anglerberger*
MM 0659
 Affiliation: **Frederick County Public Schools**

Analyses To Be Performed

Lab ID	Field Sample ID	Site Description	Collection Date		Collection Time		Matrix DW WW	pH	Res. Cl	DO	Temp	Grab/ Comp	Rec'd Temp (at lab)	Preservation	
			Start	End	Start	End								Yes	No
	<i>Flush</i>	<i>KS1-01-1039 KS</i>	<i>4-8-22</i>		<i>12:42</i>						<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>		
	<i>Flush</i>	<i>KS1-02-1039 KS</i>	<i>4-8-22</i>		<i>12:45 pm</i>		<input checked="" type="checkbox"/>				<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>		

Relinquished By: <i>Marc R. Anglerberger</i>	Date/Time: <i>4-12-22</i>	Received By: <i>Nicole Dally</i>	Date/Time: <i>4/12/22</i>	Treatment Devices Present:	Yes <input type="checkbox"/> No <input type="checkbox"/>
(Print): <i>Marc R. Anglerberger</i>	(Print): <i>Marc R. Anglerberger</i>	(Signature): <i>Nicole Dally</i>	(Signature): <i>Nicole Dally</i>	Describe Treatment Device(s):	
Relinquished By:	Date/Time:	Received By:	Date/Time:	Lead & Copper Samples - Water Last Used:	Date: _____ Time: _____
(Print):	(Print):	(Signature):	(Signature):	Method of Shipment:	Iced: Yes <input type="checkbox"/> No <input type="checkbox"/>
Relinquished By:	Date/Time:	Received By:	Date/Time:	Condition of Sample(s) upon Receipt:	<i>17.5°</i>
(Print):	(Print):	(Signature):	(Signature):		
(Signature):	(Signature):				