



Project: Frederick Co Schools

## Analytical Results

Project Number: Twin Ridge Elementary  
Client Name: TIDEWATER  
Project Manager: Meneka Rodrigo

Reported:  
11-Apr-22 16:06

### Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K17-01 1058 (IM)	E070304-01	Kitchen	Lead	< 1.0	ug/L	4/9/2022 4:37:04PM	SES
K31-04 1058 (KS)	E070304-02	Kitchen	Lead	3.0	ug/L	4/9/2022 4:40:39PM	SES
S23-42 1058 (NO)	E070304-03	Room 137 / Health Room	Lead	< 1.0	ug/L	4/9/2022 4:44:14PM	SES
S23-82 1058 (TL)	E070304-04	Teachers Lounge	Lead	1.2	ug/L	4/9/2022 4:47:47PM	SES
W01A-01 1058 (DF)	E070304-05	1st Floor	Lead	< 1.0	ug/L	4/9/2022 4:51:20PM	SES
W01A-01 1058 (DF) B	E070304-06	1st Floor	Lead	< 1.0	ug/L	4/9/2022 4:54:52PM	SES
W01A-02 1058 (DF)	E070304-07	1st Floor	Lead	3.4	ug/L	4/9/2022 5:12:41PM	SES
W01A-03 1058 (DF)	E070304-08	Gym	Lead	< 1.0	ug/L	4/9/2022 5:16:15PM	SES
W01A-04 1058 (DF)	E070304-09	1st Floor Hallway, West	Lead	< 1.0	ug/L	4/9/2022 5:19:48PM	SES
W01A-05 1058 (DF)	E070304-10	1st Floor Hallway, West	Lead	< 1.0	ug/L	4/9/2022 5:23:23PM	SES
W01A-06 1058 (DF)	E070304-11	2nd Floor Hallway, South	Lead	< 1.0	ug/L	4/9/2022 5:26:58PM	SES
W01A-07 1058 (DF)	E070304-12	2nd Floor Hallway, South	Lead	< 1.0	ug/L	4/9/2022 5:30:33PM	SES
W01A-08 1058 (DF)	E070304-13	2nd Floor Center	Lead	< 1.0	ug/L	4/9/2022 5:34:08PM	SES
W01A-08 1058 (DF) B	E070304-14	2nd Floor Center	Lead	< 1.0	ug/L	4/9/2022 5:37:42PM	SES
W01A-09 1058 (DF)	E070304-15	2nd Floor Center	Lead	< 1.0	ug/L	4/10/2022 10:49:17AM	SES
W01A-10 1058 (DF)	E070304-16	2nd Floor, East	Lead	< 1.0	ug/L	4/10/2022 10:56:23AM	SES
W01A-11 1058 (DF)	E070304-17	2nd Floor, East	Lead	< 1.0	ug/L	4/10/2022 11:07:04AM	SES

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools


## Analytical Results

Project Number: Twin Ridge Elementary  
Client Name: TIDEWATER  
Project Manager: Meneka Rodrigo

Reported:  
11-Apr-22 16:06

## Notes and Definitions

DET Analyte DETECTED  
ND Analyte NOT DETECTED at or above the reporting limit  
NR Not Reported  
dry Sample results reported on a dry weight basis  
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

70304

SITE: TWIN RIDGE ELEMENTARY SCHOOL 1106 Leafy Hollow Circle, Mt. Airy, MD 21771  
 SAMPLERS NAME: DUREKA ALUWHARE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1	K17-01 1058 (IM)	TRES	Kitchen	8	E1030.80 Foodservice Equipment (Ice Machine, Flake Or Cube)	April 8, 2022 5:05
2	K31-04 1058 (KS)	TRES	Kitchen	8	D2010.60 Plumbing Fixture (Kitchen Sink)	April 8, 2022 5:08
3	S23-42 1058 (NO)	TRES	Room 137 / Health Room	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 8, 2022 5:15
4	S23-82 1058 (TL)	TRES	Teachers Lounge	8	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	April 8, 2022 5:22
5	W01A-01 1058 (DF)	TRES	1st Floor	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 8, 2022 5:28
6	W01A-01 1058 (DF) B	TRES	1st Floor	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 8, 2022 5:28
7	W01A-02 1058 (DF)	TRES	1st Floor	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 8, 2022 5:30
8	W01A-03 1058 (DF)	TRES	Gym	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 8, 2022 5:38
9	W01A-04 1058 (DF)	TRES	1st Floor Hallway, West	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 8, 2022 5:46
10	W01A-05 1058 (DF)	TRES	1st Floor Hallway, West	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 8, 2022 5:46
11	W01A-06 1058 (DF)	TRES	2nd Floor Hallway, South	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 8, 2022 5:52

70304

SITE: TWIN RIDGE ELEMENTARY SCHOOL 1106 Leafy Hollow Circle, Mt. Airy, MD 21771  
SAMPLER'S NAME: DUREKA ALUWHARE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
12	W01A-07 1058 (DF)	TRES	2nd Floor Hallway, South	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 8, 2022 5:52
13	W01A-08 1058 (DF)	TRES	2nd Floor Center	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 8, 2022 5:55
14	W01A-08 1058 (DF) B	TRES	2nd Floor Center	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 8, 2022 5:55
15	W01A-09 1058 (DF)	TRES	2nd Floor Center	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 8, 2022 5:58
16	W01A-10 1058 (DF)	TRES	2nd Floor, East	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 8, 2022 6:00
17	W01A-11 1058 (DF)	TRES	2nd Floor, East	8	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	April 8, 2022 6:00

Dureka Aluwhare 4/8/22