



Project: Frederick Co Schools

Analytical Results

Project Number: Woodsboro Elementary School
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
28-Mar-22 11:51

Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
K31-01 1073 (KS)	E070146-01	Kitchen	Lead	3.0	ug/L	3/25/2022 1:49:54PM	RAS
S23-06 1073 (TL)	E070146-02	Lounge	Lead	2.3	ug/L	3/25/2022 2:00:33PM	RAS
S23-24 1073 (NO)	E070146-03	Health Room	Lead	2.0	ug/L	3/25/2022 2:11:16PM	RAS
W01A-01 1073 (DF) L	E070146-04	Hallway-Front Office	Lead	3.0	ug/L	3/25/2022 2:14:50PM	RAS
W01A-01 1073 (DF) R	E070146-05	Hallway-Front Office	Lead	2.7	ug/L	3/25/2022 2:18:24PM	RAS
W01A-01 1073 (DF) B	E070146-06	Hallway-Front Office	Lead	2.2	ug/L	3/25/2022 2:21:58PM	RAS
W01A-02 1073 (DF)	E070146-07	Gym Hallway	Lead	1.3	ug/L	3/25/2022 2:25:33PM	RAS
W01A-02 1073 (DF) B	E070146-08	Gym Hallway	Lead	1.2	ug/L	3/25/2022 2:29:08PM	RAS
W01A-03 1073 (DF)	E070146-09	Hallway At Boiler Room	Lead	< 1.0	ug/L	3/25/2022 2:32:44PM	RAS

Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Project: Frederick Co Schools


Analytical Results

Project Number: Woodsboro Elementary School
Client Name: TIDEWATER
Project Manager: Meneka Rodrigo

Reported:
28-Mar-22 11:51

Notes and Definitions

DET Analyte DETECTED
ND Analyte NOT DETECTED at or above the reporting limit
NR Not Reported
dry Sample results reported on a dry weight basis
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

SITE: WOODSBORO ELEMENTARY SCHOOL 101 Liberty Road, Woodsboro, MD 21798
 SAMPLER'S NAME: DUREKA ALUWHARE

No.	Name	Site	Area-Room number	Area	Category	Sampling Date and Time
1	K31-01 1073 (KS)	WOES	Kitchen	1	D2010.60 Plumbing Fixture (Kitchen Sink)	March 24, 2022 5:15
2	S23-06 1073 (TL)	WOES	Lounge	1	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 24, 2022 5:17
3	S23-24 1073 (NO)	WOES	Health Room	1	D2010.60 Plumbing Fixture (Non-Kitchen Lavatory/Sink)	March 24, 2022 5:19
4	W01A-01 1073 (DF) L	WOES	Hallway-Front Office	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 24, 2022 5:21
5	W01A-01 1073 (DF) R	WOES	Hallway-Front Office	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 24, 2022 5:21
6	W01A-01 1073 (DF) B	WOES	Hallway-Front Office	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 24, 2022 5:21
7	W01A-02 1073 (DF)	WOES	Gym Hallway	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 24, 2022 5:25
8	W01A-02 1073 (DF) B	WOES	Gym Hallway	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 24, 2022 5:28
9	W01A-03 1073 (DF)	WOES	Hallway At Boiler Room	1	D2010.60 Plumbing Fixture (Refrigerated Drinking Fountain)	March 24, 2022 5:30

70146